



TTC McNicoll Bus Garage TPAP Environmental Noise Assessment Toronto, ON

Novus Reference No. 13-0054

Version No. 5 (Final)

December 10, 2014

NOVUS PROJECT TEAM:

Scientist:	Kevin Carr, P.Phys.
Specialist:	R. L. Scott Penton, P.Eng.
Project Manager:	Scott Shayko, CET, B.Comm

This page intentionally left blank
for 2-sided printing purposes

Table of Contents

1.0	INTRODUCTION.....	1
2.0	PROPOSED FACILITY DESCRIPTION	2
3.0	APPLICABLE GUIDELINES.....	2
3.1	MOE Guideline D-6	2
3.2	MOE Publication NPC-300.....	4
4.0	POINTS OF RECEPTION.....	4
4.1	Vacant Lot Surrogate Receptors.....	5
5.0	NOISE MODELLING	6
5.1	Sound Level Measurements and Source Inputs	6
5.2	Worst-Case Operations.....	7
5.3	Ambient Noise Modelling and Resulting Guideline Limits.....	7
5.4	Noise Modelling Parameters	8
5.4.1	Ground Absorption.....	8
5.4.2	Reflection	8
5.4.3	Barrier Effects	9
5.4.4	Building Evaluations	9
5.5	Impact Assessment - Unmitigated Noise Levels, Normal Operations	9
5.6	Impact Assessment - Unmitigated Noise Levels, Generator Testing.....	11
5.7	Noise Control Measures and Mitigated Sound Levels	12
5.7.1	2150 McNicoll Vacant Lot.....	14
6.0	BUS TRAFFIC ON SURROUNDING ROADWAYS.....	14
6.1	MOE Draft Guideline for Noise and Vibration Assessment of Transit Projects ...	14
6.2	MOE Draft Noise Guidelines for Landfill Sites.....	16
6.3	Bus Road Traffic Conclusions	18
7.0	CONCLUSIONS.....	19
8.0	REFERENCES.....	20

List of Tables

Table 1:	Guideline D-6 Potential Influence Areas and Recommended Minimum Setback Distances for Industrial Land Uses	3
Table 2:	NPC-300 Exclusion Sound Level Limit Values	4
Table 3:	Representative Point of Reception Locations	5

Table 4: Summary of Road Traffic Data.....	8
Table 5: Predicted Unmitigated Noise Levels – Normal Operations.....	10
Table 6: Predicted Unmitigated Noise Levels – Generator Testing.....	11
Table 7: Predicted Mitigated Noise Levels – Normal Operations	13
Table 8: Assessment of Impacts – Receptors Along Redlea Ave	15
Table 9: Assessment of Impacts – Receptors Along McNicoll Ave.....	16
Table 10: MOE Noise Guidelines for Landfill Sites – Haul Route Noise Change Ranking	16
Table 11: Change in Noise Assessment – Redlea Avenue.....	17
Table 12: Change in Noise Assessment – McNicoll Avenue	18

List of Figures

- Figure 1: Context Plan
- Figure 2: Zoning Map
- Figure 3: Proposed Facility Layout
- Figure 4: Guideline D-6 Setbacks
- Figure 5: Unmitigated Noise Impact Contours – Daytime Operations
- Figure 6: Unmitigated Noise Impact Contours – Worst-case 3am Operations
- Figure 7: Unmitigated Noise Impact Contours – Worst-case 6am Operations
- Figure 8: Unmitigated Noise Impacts, Mon Sheong LTC – Daytime Operations
- Figure 9: Unmitigated Noise Impacts, Mon Sheong LTC – Night-time 3am Operations
- Figure 10: Unmitigated Noise Impacts, Mon Sheong LTC – Night-time 6am Operations
- Figure 11: Noise Impact Contours – Standby Generator Testing – Daytime Only
- Figure 12: Facility Layout Showing Recommended Mitigation Measures
- Figure 13: Mitigated Noise Impact Contours – Daytime Operations
- Figure 14: Mitigated Noise Impact Contours – Worst-case 3am Operations
- Figure 15: Mitigated Noise Impact Contours – Worst-case 6am Operations
- Figure 16: Mitigated Noise Impacts, Mon Sheong LTC – Daytime Operations
- Figure 17: Mitigated Noise Impacts, Mon Sheong LTC – Night-time 3am Operations
- Figure 18: Mitigated Noise Impacts, Mon Sheong LTC – Night-time 6am Operations

List of Appendices

- Appendix A: Zoning Maps
- Appendix B: Facility Drawings
- Appendix C: Detailed Modelling Inputs
- Appendix D: Road Traffic Information

1.0 INTRODUCTION

Novus Environmental Inc. (Novus) was retained by URS Canada Inc. (URS) on behalf of the Toronto Transit Commission (TTC) to prepare an environmental noise assessment for the proposed McNicoll Bus Garage located in the City of Toronto, Ontario. The TTC McNicoll Bus Garage (Facility) is proposed to be located on McNicoll Avenue, east of Kennedy Road in the City of Toronto, Ontario.

The purpose of the assessment is to evaluate the overall noise emissions of the proposed Facility with respect to relevant noise guidelines. The guideline most applicable to this project is the Ontario Ministry of the Environment (MOE) publication NPC-300 (MOE 2013).

Background sound levels in the vicinity of the proposed Facility are dominated by local road traffic from the neighbouring McNicoll Avenue, Kennedy Road, Midland Avenue, as well as rail traffic from the GO Rail line to the east. In addition, the future Redlea Avenue extension is predicted to contribute to the ambient environment in the area. Ambient road traffic modelling has been included in this assessment per NPC-300. Rail traffic volumes are not currently high enough to contribute to ambient levels per NPC-300. Although rail volumes are anticipated to significantly increase, rail noise has conservatively not been included in the ambient noise modelling calculations.

A scaled context plan and zoning map showing the site with respect to the surrounding area and modelled noise sensitive receptors is provided in **Figures 1 and 2**. A site layout plan, showing the proposed Facility arrangement and source locations, is provided in **Figure 3**. A land use zoning designation plan is also provided in **Appendix A**.

Noise sensitive locations surrounding the proposed Facility are as follows:

- Japanese Gospel Church of Toronto to the east;
- Mon Sheong Long Term Care Facility to the southwest;
- Mon Sheong Court to the southwest;
- Residential properties to the east, northwest, and southwest;
- Mary Ward Catholic Secondary School to the west;
- Scarborough Chinese Baptist Church to the north; and
- Toronto Chinese United Church to the northwest.

Without the inclusion of noise mitigation, impacts in excess of NPC-300 requirements are predicted to occur at the Mon Sheong facilities to the southwest. Mitigation has been recommended in order to meet requirements at all noise sensitive locations.

2.0 PROPOSED FACILITY DESCRIPTION

The project includes the construction of a new bus storage and maintenance facility for the Toronto Transit Commission (TTC). The proposed facility is located on McNicoll Avenue, east of Kennedy Road in the City of Toronto, Ontario. The proposed Facility will be used to house buses when they are not in use, and for minor maintenance and repair on the buses. The proposed Facility will operate 24 hours a day, seven days per week.

The proposed Facility is to be located in an area zoned Employment EH 0.5 under the new City of Toronto by-law. The proposed Facility is surrounded on all sides by Employment lands (zoned EH 0.5 under new City of Toronto By-law 569-2013, and as the Milliken Employment District under former City of Scarborough General Zoning By-law 24892). Further from the proposed Facility, Residential zonings are located to the east and west, and Commercial Residential to the southwest. See **Figure 2** and **Appendix A**.

Detailed Facility configurations were obtained from drawings provided by URS. Drawings used in the assessment are included in **Appendix B**. A site plan showing the location of significant noise sources, including rooftop heating, air conditioning and ventilation (HVAC) units, generators, bus routes and others, can be found in **Figure 3**.

3.0 APPLICABLE GUIDELINES

3.1 MOE Guideline D-6

The D-series of guidelines were developed by the Ontario Ministry of the Environment and Climate Change (MOECC) in 1995 as a means to assess recommended separation distances and other control measures for land use planning proposals in an effort to prevent or minimize ‘adverse effects’ from the encroachment of incompatible land uses where a facility either exists or is proposed. The guideline specifically addresses issues of odour, dust, noise and litter.

Guideline D-6 *Compatibility Between Industrial Facilities and Sensitive Land Uses*, addresses industrial land uses similar to the proposed bus facility. From the Guideline’s synopsis, Guideline D-6 is “intended to be applied in the land use planning process to prevent or minimize future land use problems due to the encroachment of sensitive land uses and industrial land uses on one another.” As the proposed project does not require a land use planning assessment (neither an Official Plan Amendment nor a Zoning By-law Amendment is required), Guideline D-6 does not strictly apply; regardless, it still can be used to consider what would generally be considered acceptable.

Guideline D-6 defines an Area of Influence and a Recommended Minimum Setback distance for three classes of industrial operation: light, medium, and heavy industrial uses. These distances are determined by industry class and are shown in the following table:

Table 1: Guideline D-6 Potential Influence Areas and Recommended Minimum Setback Distances for Industrial Land Uses

Industry Classification	Area of Influence	Recommended Setback Distance
Class I – Light Industrial	70 m	20 m
Class II – Medium Industrial	300 m	70 m
Class III – Heavy Industrial	1000 m	300 m

Based on the size of the facility and the nature of the use, the proposed McNicoll bus facility is consistent with a Class 2 industry, with an Area of Influence of 300 m, and a Recommended Minimum Setback Distance of 70 m. Setback distances are shown in **Figure 4**.

Guideline D-6 recommends that detailed assessments be conducted where sensitive land uses are located within the Area of Influence of the industrial facility. There are several sensitive receptors within the Area of Influence. See **Figure 4**. The closest sensitive use is the Mon Sheong residential development/ long term care facility. The detailed analyses presented in the subsequent sections of the report meet this requirement of Guideline D-6.

Guideline D-6 also provides a Recommended Minimum Setback Distance of 70 m for Class 2 facilities. The distances between the Mon Sheong facility and the McNicoll facility are:

- Property line to property line – 23 m
- Mon Sheong Building to closest on-site bus route – 30 m

While the Mon Sheong facility lies within the Recommended Minimum Setback Distance from the proposed McNicoll bus facility, Guideline D-6 is clear that the Minimum Setback Distance is a *recommendation* only. Section 4.10 of the Guideline allows for development to occur within the minimum setback for “redevelopment, infilling and mixed use” areas. This project would qualify as redevelopment or infilling. In such cases, Section 4.10 of the Guideline requires that a detailed assessment be conducted to show that the relevant noise guidelines are met (in this case, MOE Publication NPC-300, the successor guideline to former MOE Publication LU-131). The detailed analyses presented in the subsequent sections of the report show that this is the case. Thus, the minimum setback requirements of Guideline D-6 have been addressed.

3.2 MOE Publication NPC-300

Due to significant road traffic noise from surrounding roadways, the area is considered to be a Class 1 area under MOE Publication NPC-300. A Class 1 Area is defined as “an area with an acoustical environment typical of a major population centre, where the background sound level is dominated by the activities of people, usually road traffic, often referred to as ‘urban hum’.”

The Exclusion Limit Values for one-hour equivalent sound level (L_{eq} , dBA) for points of reception in a Class 1 area are summarized in the following table. There are no impulsive noise sources anticipated from the proposed Facility.

Table 2: NPC-300 Exclusion Sound Level Limit Values

Time Period	Exclusionary Sound Level Limits, 1h- L_{eq} (dBA) ^[1]
0700-1900h	50
1900-2300h	50
2300-0700h	45

Sound level limits do not apply to emergency equipment operating during emergency situations. However, emergency equipment operating in non-emergency situations, such as testing or maintenance of such equipment, requires assessment under NPC-300. The sound level limits for emergency equipment operating in non-emergency situations are 5 dB greater than the sound level limits otherwise applicable to stationary sources, as described above. Additionally, emergency equipment operating in non-emergency situations is to be assessed independently of all other stationary sources of noise.

4.0 POINTS OF RECEPTION

Noise sensitive areas are located in all locations from the proposed Facility. Noise sensitive areas and the representative locations are shown in **Figure 1**. **Figure 4** provides the Guideline D-6 setback distances from the proposed Facility. The following table summarizes the representative noise-sensitive areas considered in this assessment.

Table 3: Representative Point of Reception Locations

Receptor No.	Receptor Location	Description
R1	Mon Sheong Long Term Care Facility	4 storey institutional facility to the southwest
R2	Mon Sheong Court	11 storey institutional facility to the southwest
R3	1883 McNicoll Ave Apartments	Mixed Use Residential Apartment Building
R4	Mary Ward Catholic Secondary School	School to west (daytime receptor only)
R5	Residential (63 Shepton Way)	Representative of Low-Rise Residential to West
R6	Toronto Chinese United Church	Church to the northwest (daytime receptor only)
R7	Scarborough Chinese Baptist	Church to the north (daytime receptor only)
R8	Residential (106 Bellrock Dr.)	Representative of Low-Rise Residential to East
R9	Japanese Gospel Church of Toronto	Church to southeast (daytime receptor only)
V1	Vacant Lot, 2150 McNicoll	Vacant lot surrogate receptor on industrially zoned (M, MG, MS) vacant lot (daytime receptor only)

4.1 Vacant Lot Surrogate Receptors

There are two vacant lots near the project, as shown on **Figure 1**.

The vacant lot to the south of the proposed Facility located south of McNicoll Ave and west of the CNR/GO railway line falls under City of Toronto Zoning By-law 569-2013. The property is zoned EH – Employment Heavy Industrial Zone (EH 0.5). There are no sensitive uses permitted under the EH 0.5 zoning.

The vacant lot to the west of the proposed facility, located at 2150 McNicoll, north of McNicoll Ave and east of the CNR/GO railway line, falls under the former City of Scarborough General Zoning By-law 24892. This property is zoned as Industrial, General Industrial, and Special Industrial (M, MG, MS-414-913-991-1054). Under the M, MG and MS zonings, the following potentially sensitive land uses are permitted:

- Day nurseries
- Places of worship
- Educational and training facilities.

As a result, in accordance with NPC-300 requirements, a vacant lot surrogate receptor (V1) has been considered. As no building permit has been filed for the site, in accordance with NPC-300 requirements the receptor has been located at the centre of a 1 Ha portion of the lot consistent with the building pattern of the area, at height of 4.5 m above grade.

5.0 NOISE MODELLING

5.1 Sound Level Measurements and Source Inputs

Detailed sound level measurements were completed at the existing TTC Mount Dennis Bus Garage on July 11, 2013. The measured sound levels, in addition to mechanical data, engineering calculations, historical data, and data from the DEFRA Construction Noise Database were used as inputs to a predictive acoustical model to quantify outdoor noise emission associated with the proposed Facility. Modelled noise source locations are provided in **Figure 4**. Facility drawings are included in **Appendix B**. Detailed modelling inputs and calculations are included in **Appendix C**.

Exhaust fan sound levels were based on mechanical specifications and engineering calculations. Packaged Heating Ventilation and Air-Conditioning units (HVAC) were modelled based on provided manufacturer data.

Since the standby generator make and model number were not available at the time of this analysis, sound levels for the generator were assumed based on the sound data for a stage 1 environmental enclosure for a similarly sized unit. Although the proposed design called for the standby generator in the southwest corner of the site, this location has been updated for air quality purposes. Both locations have been considered, and the recommended mitigation for the standby generator would be effective in both locations. However, for the sake of simplicity, only the updated standby generator location (the northeast corner of the site) has been considered in this report.

Noise emissions from Bay Doors were estimated based on sound level measurements of idling buses, pressure washers, and an impact wrench taken on July 11, 2013. Sound level measurements were inputted into a spreadsheet model of the indoor configuration of each of the respective bays. Accounting for sound emissions, indoor reflections, and acoustic absorptions, noise emitted through bay doors was calculated. Based on the approximate dimensions of the doors, directivity patterns were applied to the sound emissions.

Emissions from the bus route were based on sound level measurements of bus pass-bys with and without acceleration. Estimated sound level emissions used these composite bus noise emissions, estimated speeds, distances travelled, and worst-case predicted number of buses travelling the route.

Refuelling of the buses was modelled based on sound levels from the DEFRA Construction Noise Database. The modelled source level was noted in the DEFRA database as a “Fuel Tanker Pumping.”

5.2 Worst-Case Operations

Based on information from TTC personnel, preliminary noise modelling has assumed two (2) potential worst-case scenarios, described briefly below:

- 1) 3 a.m. – Storage Bay at capacity (approximately 220 buses), all HVAC at capacity, the Repair Bay at capacity, Wash Bays operational, all Bay Doors open, and minimal bus traffic (approximately 14 buses per hour)
- 2) 6 a.m. – 103 buses exiting the facility, HVAC and bays operating at reduced capacity (approximately 25% of HVAC and Exhaust Fans operational over the given worst-case hour)

Maximum capacity emissions for each of the Bays are based on the following assumptions:

- Storage Bay – Approximately 50 buses idling per bay (the Storage Bay is split into four bays oriented north / south, and one bay intersecting these bays and the Wash Bay, to the east, oriented north / south)
- Wash Bay – Two buses being washed at a time, on average, for the entire worst-case hour
- Repair Bay – Approximately 15 buses idling, as well as a pressure washer and impact wrench each operating in worst-case locations for a total of 10 minutes per hour

In addition to the above operations, a 10 minute idling policy will be in place, meaning that buses will idle for a maximum of 10 minutes per worst-case hour. Maximum capacity emissions for the bus route were estimated based on a speed of 20 km/hr. Standby generator testing will be limited to daytime only testing.

In addition to the two worst-case maximum capacity scenarios, an additional daytime, regular operations scenario was considered.

5.3 Ambient Noise Modelling and Resulting Guideline Limits

The ambient sound levels from the surrounding roadways were modelled at the proposed development. Noise impacts from the proposed Facility were assessed based on the increased ambient noise from the surrounding roadways. Conservatively, ambient noise from high traffic volume railways lines was ignored.

Road traffic data was obtained from URS. Copies of the traffic data and calculations used in the analysis can be found in **Appendix D**. The following table summarizes the road traffic volumes used in the analysis.

Table 4: Summary of Road Traffic Data

Roadway Link	Traffic Levels (AADT)	Minimum Hourly Volumes			Commercial Traffic Breakdown		Vehicle Speed (km/h)
		Day	3am	6am	% Medium Trucks	% Heavy Trucks	
Kennedy Rd	28890	4.30 %	0.38 %	1.95 %	2.3 %	2.0 %	60
Redlea Ave	16840	4.30 %	0.38 %	1.95 %	2.3 %	2.0 %	50
McNicoll Ave	22800	4.30 %	0.38 %	1.95 %	2.3 %	2.0 %	50
Midland Ave	16560	4.30 %	0.38 %	1.95 %	2.3 %	2.0 %	50

Notes: [1] from URS TTC McNicoll Bus Garage Traffic Impact Study (assuming AADT = Peak PM * 10)

[2] from Average of Toronto Traffic data on file at Novus

Road traffic sound levels at the proposed development were predicted using Cadna/A, a commercially available noise propagation modelling software. Roadways were modelled as line sources of sound, with sound emission rates calculated using the ORNAMENT algorithms, the road traffic noise model of the MOE (MOE 1989). These predictions are equivalent to those made using the MOE's ORNAMENT or STAMSON v5.04 road traffic noise models.

5.4 Noise Modelling Parameters

The calculations were performed using Cadna/A, a computerized implementation of the ISO 9613-2 noise modelling standard (ISO 1996). The model took into consideration the layout of the proposed Facility, the location of the sources, and the surrounding buildings.

5.4.1 Ground Absorption

As described in ISO 9613-2, ground absorption values which can affect sound propagation can range between 0 and 1. A default ground factor of $G = 0.0$ was used to represent surrounding pavement / asphalt, with localized ground absorption added, representing the grass/ parkland areas, modelled with a ground factor of $G = 1.0$.

5.4.2 Reflection

An order of reflection of 2 was used in the modelling. That is to say, up to two reflections off of building walls were considered in predicting noise at offsite locations. The proposed Facility buildings and the surrounding buildings were modelled as reflective, with a typical absorption parameter of $\alpha = 0.2$.

Specific barriers required for noise control at the facility were modelled as absorptive, with a typical absorption parameter of $\alpha = 0.84$.

5.4.3 Barrier Effects

In calculating barrier effects, the following options were selected, which provide conservative estimates of barrier effects:

- Barriers which do not break the line of sight between the source and receiver are ignored (“no negative path length distance” option selected).
- The effect of noise barriers on reducing reflections from hard, reflective ground was ignored (“no subtraction of negative ground attenuation” option selected)

5.4.4 Building Evaluations

The “building evaluation” methodology of Cadna was used to evaluate noise impact on large buildings such as the Mon Sheong facilities, the McNicoll Ave apartments, the Mary Ward School, and the Scarborough Chinese Baptist Church. This procedure automatically models a series of receptor points along the façade, and allows for a more accurate estimate of potential impacts.

As both the ambient sound level due to road traffic (and the corresponding guideline limit) and the noise from the proposed Facility will vary depending on the location on the building, it is possible to have areas with low ambient and high noise levels from the Facility. The building evaluation approach allows for a façade location specific guideline limit to be determined, and then to be compared with the façade location specific noise from the Facility. Thus, compliance of noise limits over the entire receptor building can be determined.

5.5 Impact Assessment - Unmitigated Noise Levels, Normal Operations

Figures 5, 6 and 7 are plan view figures showing the applicable guideline limits, predicted noise from the facility, and compliance with NPC-300 requirements.

Figures 8, 9 and 10 provide 3-dimensional views of the Mon Sheong Long Term Care facility, showing the “building evaluation” predictions for applicable guidelines, facility noise, and excesses over the guideline limits.

The results are summarized in the following table:

Table 5: Predicted Unmitigated Noise Levels – Normal Operations

Receptor No.	Receptor Location	Time Period	Predicted TTC Facility Sound Level [1]	Guideline Limit [1]	Excess Over Guideline [2]
R1	Mon Sheong Long Term Care Façade	Daytime (7 am – 11 pm) Night-time, 3 am Night-time, 6 am	34 - 57 36 - 61 35 - 57	57 - 66 46 - 55 53 - 62	0 0 - 13 0 - 1
	Mon Sheong Long Term Care	Daytime (7 am – 11 pm) Night-time, 3 am	53 n/a	61 n/a	0 0
	Outdoor Amenity	Night-time, 6 am	n/a	n/a	0
R2	Mon Sheong Court	Daytime (7 am – 11 pm)	28 - 53	57 - 66	0
		Night-time, 3 am	31 - 58	45 - 56	0 - 13
		Night-time, 6 am	28 - 53	47 - 63	0 - 3
R3	1883 McNicoll Ave Apartments	Daytime (7 am – 11 pm)	46	65	0
		Night-time, 3 am	49	55	0
		Night-time, 6 am	46	62	0
R4	Mary Ward Secondary School	Daytime (7 am – 11 pm)	45	57	0
		Night-time, 3 am	n/a	n/a	0
		Night-time, 6 am	n/a	n/a	0
R5	Residential (63 Shepton)	Daytime (7 am – 11 pm)	41	58	0
		Night-time, 3 am	45	48	0
		Night-time, 6 am	42	55	0
R6	Toronto Chinese United Church	Daytime (7 am – 11 pm)	41	66	0
		Night-time, 3 am	n/a	n/a	0
		Night-time, 6 am	n/a	n/a	0
R7	Scarborough Chinese Baptist	Daytime (7 am – 11 pm)	47	58	0
		Night-time, 3 am	n/a	n/a	0
		Night-time, 6 am	n/a	n/a	0
R8	Residential (106 Bellrock)	Daytime (7 am – 11 pm)	44	63	0
		Night-time, 3 am	48	52	0
		Night-time, 6 am	46	60	0
R9	Japanese Gospel Church of Toronto	Daytime (7 am – 11 pm)	46	59	0
		Night-time, 3 am	n/a	n/a	0
		Night-time, 6 am	n/a	n/a	0
V1	Vacant Lot, 2150 McNicoll	Daytime (7 am – 11 pm)	50	57	0
		Night-time, 3 am	n/a	n/a	0
		Night-time, 6 am	n/a	n/a	0

Note:

- All values are L_{eq} (1-hr) sound exposures measured in dBA unless otherwise noted.
- [1] Values represent the range of predicted sound levels over the exposed façade
- [2] Excesses shown are calculated by subtracting the location-specific guideline limit from the corresponding location-specific Facility sound level.

5.6 Impact Assessment - Unmitigated Noise Levels, Generator Testing

The standby generator was considered separately from the other sources, per the requirements outlined in NPC-300. The generator will be tested during daytime hours only, and includes a “Stage 1” noise enclosure which reduces noise to a maximum sound level of 79 dBA at 7 m.

Modelled noise impacts were evaluated at all surrounding noise sensitive areas in **Figure 11**.

The results are summarized in the following table:

Table 6: Predicted Unmitigated Noise Levels – Generator Testing

Receptor No.	Receptor Location	Time Period	Predicted TTC Facility Sound Level [1]	Guideline Limit [1]	Excess Over Guideline [2]
R1	Mon Sheong Long Term Care Façade	Daytime (7 am – 11 pm)	22 - 38	57 - 66	0
	Mon Sheong Long Term Care Outdoor Amenity	Daytime (7 am – 11 pm)	30	61	0
R2	Mon Sheong Court	Daytime (7 am – 11 pm)	19 - 41	57 - 66	0
R3	1883 McNicoll Ave Apartments	Daytime (7 am – 11 pm)	37	65	0
R4	Mary Ward Secondary School	Daytime (7 am – 11 pm)	37	57	0
R5	Residential (63 Shepton)	Daytime (7 am – 11 pm)	37	58	0
R6	Toronto Chinese United Church	Daytime (7 am – 11 pm)	43	66	0
R7	Scarborough Chinese Baptist	Daytime (7 am – 11 pm)	50	58	0
R8	Residential (106 Bellrock)	Daytime (7 am – 11 pm)	37	63	0
R9	Japanese Gospel Church of Toronto	Daytime (7 am – 11 pm)	43	59	0
V1	Vacant Lot, 2150 McNicoll	Daytime (7 am – 11 pm)	46	57	0

Note:

-- All values are L_{eq} (1-hr) sound exposures measured in dBA unless otherwise noted.

[1] Values represent the range of predicted sound levels over the exposed façade

[2] Excesses shown are calculated by subtracting the location-specific guideline limit from the corresponding location-specific Facility sound level.

5.7 Noise Control Measures and Mitigated Sound Levels

Based on the predicted noise impacts for the normal operations scenario, noise mitigation measures are required. Based on discussions with TTC personnel, the preferred mitigation plan consists of the following mitigation measures:

- HVAC
 - Rotate all HVAC such that the louvres face north and/or east
- Storage bay doors and bus exit route
 - A canopy over top of the Storage Bay doors
 - Must be free of gaps or cracks, and must be a minimum of 10 kg/m²
 - A 5m high noise barrier along the western property line, between the Storage Bay doors and Mon Sheong to the west
 - Must be free of gaps or cracks, and must be a minimum of 20 kg/m²
 - Location as indicated in **Figure 12**
- Standby generator
 - Testing to be conducted during daytime hours only
 - An acoustic enclosure (stage 1 or better)
- Transpired Solar Collector HVAC outdoor air inlets
 - Relocate to the east of the Facility, eliminate, or silence
- Bus entrance route
 - Divert to northern entrance
- Maintenance bay doors on western façade
 - Keep shut at night

Figure 12 indicates the locations and specifications of the required noise mitigation measures.

Mitigated noise impacts modelled ambient noise, and resulting compliance were evaluated at all surrounding noise sensitive areas, as shown in **Figures 13, 14, and 15** for the daytime, 3am, and 6am periods, respectively.

Mitigated noise impacts, mapped on the façades of Mon Sheong Long Term Care, are shown in detail in **Figures 16, 17, and 18** for the daytime, 3am, and 6am periods, respectively.

Results are summarized in **Table 7**. As shown the table and in the above-noted figures, with the inclusion of the recommended mitigation measures, noise impacts are predicted to meet NPC-300 sound level requirements at all noise sensitive receptors.

Table 7: Predicted Mitigated Noise Levels – Normal Operations

Receptor No.	Receptor Location	Time Period	Predicted TTC Facility Sound Level [1]	Guideline Limit [1]	Excess Over Guideline [2]
R1	Mon Sheong	Daytime (7 am – 11 pm)	33 - 55	57 - 66	0
	Long Term Care	Night-time, 3 am	29 - 49	46 - 55	0
	Façade	Night-time, 6 am	33 - 49	53 - 62	0
	Mon Sheong	Daytime (7 am – 11 pm)	48	61	0
	Long Term Care	Night-time, 3 am	n/a	n/a	0
	Outdoor Amenity	Night-time, 6 am	n/a	n/a	0
R2	Mon Sheong Court	Daytime (7 am – 11 pm)	27 - 50	57 - 66	0
		Night-time, 3 am	22 - 45	45 - 56	0
		Night-time, 6 am	26 - 44	47 - 63	0
R3	1883 McNicoll Ave Apartments	Daytime (7 am – 11 pm)	41	65	0
		Night-time, 3 am	39	55	0
		Night-time, 6 am	39	62	0
R4	Mary Ward Secondary School	Daytime (7 am – 11 pm)	44	57	0
		Night-time, 3 am	n/a	n/a	0
		Night-time, 6 am	n/a	n/a	0
R5	Residential (63 Shepton)	Daytime (7 am – 11 pm)	42	58	0
		Night-time, 3 am	43	48	0
		Night-time, 6 am	41	55	0
R6	Toronto Chinese United Church	Daytime (7 am – 11 pm)	43	66	0
		Night-time, 3 am	n/a	n/a	0
		Night-time, 6 am	n/a	n/a	0
R7	Scarborough Chinese Baptist	Daytime (7 am – 11 pm)	50	58	0
		Night-time, 3 am	n/a	n/a	0
		Night-time, 6 am	n/a	n/a	0
R8	Residential (106 Bellrock)	Daytime (7 am – 11 pm)	46	63	0
		Night-time, 3 am	51	52	0
		Night-time, 6 am	47	60	0
R9	Japanese Gospel Church of Toronto	Daytime (7 am – 11 pm)	47	59	0
		Night-time, 3 am	n/a	n/a	0
		Night-time, 6 am	n/a	n/a	0
V1	Vacant Lot, 2150 McNicoll	Daytime (7 am – 11 pm)	-88	57	0
		Night-time, 3 am	n/a	n/a	0
		Night-time, 6 am	n/a	n/a	0

Note:

- All values are L_{eq} (1-hr) sound exposures measured in dBA unless otherwise noted.
- [1] Values represent the range of predicted sound levels over the exposed façade
- [2] Excesses shown are calculated by subtracting the location-specific guideline limit from the corresponding location-specific Facility sound level.

5.7.1 2150 McNicoll Vacant Lot

The lot located at 2150 McNicoll Ave, to the east of the proposed TTC facility, is currently vacant. While it is zoned for M, MG, and MS heavy and special industrial uses, including chemical manufacturing and metal smelting, the allowed uses also include educational facilities, daycares and places of worship. There have been no uses announced for the lot, and there are no current building permits for construction of any use at this location.

The modelling results presented above, conducted in accordance with NPC-300 requirements, show noise levels at the modelled VLSR location to be in compliance with the guideline limits.

The future construction of any of the allowed noise-sensitive uses on the 2150 McNicoll lot would be subject to Site Plan Approval from the City, and would require a noise impact assessment to be conducted for the proposed use. TTC will work with any future developer of the property, through the City's Site Plan Approval process and through the MOE's Environmental Compliance Approval process to ensure that compliance with the noise guidelines is maintained should a future noise sensitive use be proposed and installed at the 2150 McNicoll site.

6.0 BUS TRAFFIC ON SURROUNDING ROADWAYS

As part of their initial peer review, Valcoustics Canada Ltd, noise consultant for the Mon Sheong residents association, has raised the issue of changes in noise levels on local roadways as a potential area of concern. However, there are no specific Provincial guidelines for assessing the changes in noise levels on local roadways due to the installation of an industrial-type facility such as the one proposed. Instead, the MOE's guidelines focus on noise within the property boundary of the facility, including bus movements there. Regardless, in order to provide a more fulsome assessment of impacts and to address community concerns, TTC has requested that an assessment of off-site bus traffic be conducted.

There are two guidelines which can be used to provide some guidance as to what would normally be considered acceptable, as discussed below.

6.1 MOE Draft Guideline for Noise and Vibration Assessment of Transit Projects

The MOE's 2010 draft *Guideline for Noise and Vibration Assessment of Transit Projects* provides guidance on the assessment of noise impacts from transit projects, including new or expanded bus routes on existing roadways.

- No transit project should result in an increase in noise at a Point of Reception exceeding 5 dBA, either during the day (L_{eq} (16h)) or night (L_{eq} (8hr)); that is to say, the “With-

“Project” sound levels cannot exceed the “Background Sound Level” by more than 5 dBA.

- In areas with high existing background sound levels, a penalty is applied to create an “Adjusted Noise Impact” used in determining the With Project Sound Level.
- No pass-by of a bus should result in an L_{eq} (Passby) sound level in excess of 80 dBA.

An assessment of sound level values due to road traffic at a 15 m setback distance from the roadway centreline was completed for both Redlea Ave and McNicoll Ave, using the MOE’s ORNAMENT road traffic noise model.

Based on the traffic projections for the future Redlea Avenue performed by URS, the future Redlea Avenue will have approximately an annual average daily traffic (AADT) volume of 16,800 vehicles. The AADT of McNicoll Avenue is 22,800. Assuming traffic distributions consistent with non-industrial areas within the City of Toronto, both roadways will have approximately 2.3% medium and 2.0% heavy vehicles as background traffic. City buses were assumed to count as medium trucks from a noise perspective.

Assessment results are shown in the following tables:

Table 8: Assessment of Impacts – Receptors Along Redlea Ave

Time Period	Background Noise Level (dBA at 15 m)	With Project Noise Level (dBA at 15 m)	Adjustment Factor ^[1] (dBA)	Adjusted Noise Level ^[2] (dBA at 15 m)	Adjusted Noise Impact ^[3]	Meets Criteria?
Daytime (7am to 11pm)	65.9	66.2	1.1	67.4	1.5	Yes
Night-time (11 pm to 7 am)	59.3	61.6	1.2	62.8	3.5	Yes

Notes:

[1] Daytime – greater of: 0.1 x [Daytime “With Project Noise Level” L_{eq} (16hr) - 55]; or 0
Night-time – greater of: 0.1 x [Nighttime “With Project Noise Level” L_{eq} (8hr) - 50]; or 0

[2] With Project Noise Level + Adjustment Factor

[3] Adjusted Noise Level – Background Noise Level

Table 9: Assessment of Impacts – Receptors Along McNicoll Ave

Time Period	Background Noise Level (dBA at 15 m)	With Project Noise Level (dBA at 15 m)	Adjustment Factor ^[1] (dBA)	Adjusted Noise Level ^[2] (dBA at 15 m)	Adjusted Noise Impact ^[3]	Meets Criteria?
Daytime (7am to 11pm)	67.2	67.3	1.2	68.5	1.3	Yes
Night-time (11 pm to 7 am)	60.7	61.1	1.1	62.2	1.6	Yes

Notes:

[1] Daytime – greater of: $0.1 \times [\text{Daytime "With Project Nosie Level"} L_{eq} (16hr) - 55]$; or 0
Night-time – greater of: $0.1 \times [\text{Nighttime "With Project Nosie Level"} L_{eq} (8hr) - 50]$; or 0

[2] With Project Noise Level + Adjustment Factor

[3] Adjusted Noise Level – Background Noise Level

The additional bus traffic in both Redlea and McNicoll will not result in a change in daytime or nighttime sound levels greater than 5 dBA. In addition, as a typical “medium truck”, the L_{eq} (Pass-by) limit of 80 dBA will also be met for all buses.

Therefore, under the MOE *Guideline for Noise and Vibration Assessment of Transit Projects*, adverse impacts would not be anticipated, and an assessment of noise mitigation measures would not be required.

6.2 MOE Draft Noise Guidelines for Landfill Sites

The MOE’s draft *Noise Guidelines for Landfill Sites* (1998) do include assessment criteria for ranking preferred haul routes with respect to changes in noise levels. The Landfill Guideline requires a quantitative assessment of hourly sound levels on haul route links. Changes in sound levels can then be qualitatively ranked as follows:

Table 10: MOE Noise Guidelines for Landfill Sites – Haul Route Noise Change Ranking

Sound Level Increase (dBA)	Qualitative Rating
0 to 3 inclusive	Insignificant
> 3 to 5 inclusive	Noticeable
> 5 to 10 inclusive	Significant
> 10 and over	Very Significant

It should be noted that the Landfill Noise Guidelines do not prohibit the use of haul routes where significant impacts are predicted; instead they required that haul routes be selected which minimize the overall noise impact.

Change assessments for Redlea and McNicoll are shown in **Tables 11 and 12**.

Table 11: Change in Noise Assessment – Redlea Avenue

Hour Beginning	Background Traffic			Background Noise Level (dBA at 15m)	Project Bus Traffic	With Project Noise Level (dBA at 15 m)	Change in Sound Level (Project – Background)
	Autos	Medium Trucks	Heavy Trucks				
0000	227	5	5	59.9	2	60.1	0.2
0100	136	3	3	57.7	5	58.5	0.8
0200	84	2	2	55.5	20	59.2	3.7
0300	61	1	1	54.2	10	57.0	2.8
0400	58	1	1	54.0	14	57.7	3.7
0500	102	2	2	56.4	67	63.1	6.7
0600	315	7	6	61.3	72	64.9	3.6
0700	694	16	14	64.7	12	65.1	0.4
0800	1047	25	22	66.5	1	66.5	0.0
0900	1003	24	21	66.3	25	66.9	0.6
1000	870	21	18	65.7	43	66.8	1.1
1100	879	21	18	65.7	1	65.8	0.0
1200	936	22	19	66.0	-	-	-
1300	972	23	20	66.2	-	-	-
1400	1000	24	21	66.3	25	66.9	0.6
1500	1069	25	22	66.6	24	67.1	0.5
1600	1168	28	24	67.0	3	67.0	0.1
1700	1238	29	25	67.2	-	-	-
1800	1141	27	23	66.9	3	66.9	0.1
1900	945	22	19	66.1	37	66.9	0.9
2000	728	17	15	64.9	23	65.6	0.7
2100	608	14	12	64.1	2	64.2	0.1
2200	496	12	10	63.3	13	63.9	0.6
2300	349	8	7	61.7	12	62.5	0.8
TOTAL	32255	763	662	--	840	--	--

Table 12: Change in Noise Assessment – McNicoll Avenue

Hour Beginning	Background Traffic			Background Noise Level (dBA at 15m)	Project Bus Traffic	With Project Noise Level (dBA at 15 m)	Change in Sound Level (Project – Background)
	Autos	Medium Trucks	Heavy Trucks				
0000	307	7	6	61.2	-	-	-
0100	185	4	4	59.0	1	59.1	0.1
0200	114	3	2	56.9	4	57.6	0.8
0300	83	2	2	55.5	2	56.0	0.5
0400	79	2	2	55.3	3	56.1	0.8
0500	138	3	3	57.7	14	59.7	1.9
0600	427	10	9	62.6	15	63.4	0.8
0700	940	22	19	66.0	3	66.1	0.1
0800	1418	34	29	67.8	-	-	-
0900	1358	32	28	67.6	5	67.7	0.1
1000	1178	28	24	67.0	9	67.2	0.2
1100	1190	28	24	67.1	-	-	-
1200	1267	30	26	67.3	-	-	-
1300	1316	31	27	67.5	-	-	-
1400	1354	32	28	67.6	5	67.7	0.1
1500	1447	34	30	67.9	5	68.0	0.1
1600	1582	37	32	68.3	1	68.3	0.0
1700	1677	40	34	68.5	-	-	-
1800	1545	37	32	68.2	1	68.2	0.0
1900	1280	30	26	67.4	8	67.5	0.1
2000	985	23	20	66.2	5	66.4	0.1
2100	824	19	17	65.5	-	-	-
2200	671	16	14	64.6	3	64.7	0.1
2300	472	11	10	63.0	3	63.2	0.2
TOTAL	43671	1033	897	--	177	--	--

For the majority of the time, the noise change produce by bus traffic will be less than 3 dB and insignificant. The landfill noise guidelines would not warrant a change in haul route selection.

6.3 Bus Road Traffic Conclusions

There are no applicable guidelines for assessing the increases in road traffic noise due to traffic from an industrial-type facility. In the absence of specific requirements, this assessment has considered both the MOE *Guideline for Noise and Vibration Assessment of Transit Projects* and the *Noise Guidelines for Landfill Sites*. Under both guidelines, changes in sound levels due to the increase in bus traffic are unlikely to create an adverse effect. Neither guideline would require investigation of noise mitigation measures or changed to the selected route.

Therefore, it is concluded that the additional bus traffic on local roadways will not result in impacts at off-site receptors.

7.0 CONCLUSIONS

Novus was retained by URS to prepare an environmental noise assessment for the McNicoll Bus Garage planned to be located along McNicoll Avenue, east of Kennedy Road in the City of Toronto, Ontario.

Unmitigated noise impacts were predicted to exceed NPC-300 requirements. A noise mitigation plan has been developed. With the inclusion of the recommended mitigation, the proposed Facility is expected to meet both MOE Guideline D-6 and MOE Publication NPC-300 requirements at all surrounding noise sensitive receptors during all periods of the day and night.

Although not required by Provincial guidelines for this type of facility, an assessment of noise from bus traffic along local roadways has been conducted. Sound levels from bus activity along local roadways has been assessed and compared against criteria contained in the MOE *Guideline for Noise and Vibration Assessment of Transit Projects* and in the MOE *Noise Guidelines for Landfill Sites*. The assessment shows that under both guidelines, changes in sound levels due to the increase in bus traffic are unlikely to create an adverse effect. Neither guideline would require investigation of noise mitigation measures or changes to the selected routes. Therefore, the additional bus traffic on local roadways will not result in impacts at off-site receptors.

8.0 REFERENCES

ASHRAE, 2007, HVAC Applications, Chapter 47: Sound and Vibration Control

International Organization for Standardization, 1996, ISO 9613-2: Acoustics – Attenuation of Sound During Propagation Outdoors Part 2: General Method of Calculation, Geneva, Switzerland

Ontario Ministry of the Environment, 1978, Model Municipal Noise Control By-Law Publication NPC-103

Ontario Ministry of the Environment, 1978, Model Municipal Noise Control By-Law Publication NPC-104

Ontario Ministry of the Environment, 1989, Ontario Road Noise Analysis Method for Environment and Transportation (ORNAMENT)

Ontario Ministry of the Environment 1995, Publication NPC-233: Information to be Submitted for Approval of Stationary Sources of Sound

Ontario Ministry of the Environment 1998, Noise Guidelines for Landfill Sites (draft)

Ontario Ministry of the Environment 2010, Guideline for Noise and Vibration Assessment of Transit Projects (draft)

Ontario Ministry of the Environment, 2013, Publication NPC-300: Environmental Noise Guideline, Stationary and Transportation Sources – Approval and Planning

Figures

This page intentionally left blank
for 2-sided printing purposes




Figure No. 1
Context Plan

TTC McNicoll Bus Garage
Toronto, Ontario



Scale: 1: 5,000
Date: 14 / 11 / 21
File No.: 13-0054
Drawn By: KAC/ SLP

novus
ENVIRONMENTAL




Figure No. 2 **Zoning Map** From map.toronto.ca/maps/map.jsp?app=ZBL CONSULT

TTC McNicoll Bus Garage
Toronto, Ontario



True
Normal

Scale: n/a
Date: 14 / 11 / 2015
File No.: 13-005
Drawn By: SLE

novus
ENVIRONMENTAL





Figure No. 3
Proposed Facility Layout

TTC McNicoll Bus Garage
Toronto, Ontario



novus
ENVIRONMENTAL




Image © 2013 DigitalGlobe, Image © Google

Figure No. 4

Guideline D-6 Setbacks From Site

TTC McNicoll Bus Garage
Toronto, Ontario



Scale: 1: 6,000
Date: 14 / 11 / 24
File No.: 13-0054
Drawn By: SLP

novus
ENVIRONMENTAL




Figure No. 5

Unmitigated Noise Impact Contours Daytime Operations

TTC McNicoll Bus Garage
Toronto, Ontario



Scale: 1: 5,000
Date: 14 / 11 / 24
File No.: 13-0054
Drawn By: KAC

novus
ENVIRONMENTAL




Figure No. 6

Unmitigated Noise Impact Contours Worst-case 3am Operations

TTC McNicoll Bus Garage
Toronto, Ontario



Scale: 1: 5,000
Date: 14 / 11 / 24
File No.: 13-0054
Drawn By: KAC

novus
ENVIRONMENTAL




Figure No. 7

Unmitigated Noise Impact Contours Worst-case 6am Operations

TTC McNicoll Bus Garage
Toronto, Ontario



Scale: 1: 5,000
Date: 14 / 11 / 24
File No.: 13-0054
Drawn By: KAC

novus
ENVIRONMENTAL




Figure No. 8

**Preferred Design – Daytime Operations
Façade Noise Impacts – Mon Sheong LTC**

TTC McNicoll Bus Garage
Toronto, Ontario



Scale: n/a
Date: 14 / 11 / 24
File No.: 13-0054
Drawn By: KAC

novus
ENVIRONMENTAL




Figure No. 9

**Preferred Design – Worst-case 3am Operations
Façade Noise Impacts – Mon Sheong LTC**

TTC McNicoll Bus Garage
Toronto, Ontario



Scale: n/a
Date: 14 / 11 / 24
File No.: 13-0054
Drawn By: KAC

novus
ENVIRONMENTAL




Figure No. 10

**Preferred Design – Worst-case 6am Operations
Façade Noise Impacts – Mon Sheong LTC**

TTC McNicoll Bus Garage
Toronto, Ontario



Scale: n/a
Date: 14 / 11 / 24
File No.: 13-0054
Drawn By: KAC

novus
ENVIRONMENTAL




Figure No. 11

Noise Impact Contours Standby Generator Testing – Daytime Only

TTC McNicoll Bus Garage
Toronto, Ontario



Scale: 1: 5,000
Date: 14 / 11 / 24
File No.: 13-0054
Drawn By: KAC

novus
ENVIRONMENTAL





Figure No. 12

**Facility Layout
Showing Recommended Mitigation**

TTC McNicoll Bus Garage
Toronto, Ontario



Scale: 1: 2,000
Date: 14 / 11 / 24
File No.: 13-0054
Drawn By: KAC

novus
ENVIRONMENTAL





Figure No. 13

Mitigated Noise Impact Contours Daytime Operations

TTC McNicoll Bus Garage
Toronto, Ontario



Scale: 1: 5,000
Date: 14 / 11 / 24
File No.: 13-0054
Drawn By: KAC

novus
ENVIRONMENTAL




Figure No. 14

Mitigated Noise Impact Contours Worst-case 3am Operations

TTC McNicoll Bus Garage
Toronto, Ontario



Scale: 1: 5,000
Date: 14 / 11 / 24
File No.: 13-0054
Drawn By: KAC

novus
ENVIRONMENTAL




Figure No. 15

**Mitigated Noise Impact Contours
Worst-case 6am Operations**

TTC McNicoll Bus Garage
Toronto, Ontario



Scale: 1: 5,000
 Date: 14 / 11 / 24
 File No.: 13-0054
 Drawn By: KAC

novus
ENVIRONMENTAL




Figure No. 16

**Recommended Mitigation – Daytime
Façade Noise Impacts – Mon Sheong LTC**

TTC McNicoll Bus Garage
Toronto, Ontario



Scale: n/a
Date: 14 / 11 / 24
File No.: 13-0054
Drawn By: KAC

novus
ENVIRONMENTAL




Figure No. 17

**Recommended Mitigation – Worst-case 3am
Façade Noise Impacts – Mon Sheong LTC**

TTC McNicoll Bus Garage
Toronto, Ontario



Scale: n/a
Date: 14 / 11 / 24
File No.: 13-0054
Drawn By: KAC

novus
ENVIRONMENTAL




Figure No. 18

**Recommended Mitigation – Worst-case 6am
Façade Noise Impacts – Mon Sheong LTC**

TTC McNicoll Bus Garage
Toronto, Ontario




Scale: n/a
Date: 14 / 11 / 24
File No.: 13-0054
Drawn By: KAC

novus
ENVIRONMENTAL

Appendix A

This page intentionally left blank
for 2-sided printing purposes



TORONTO City Planning

Zoning - East District

August 2010

Maps must be read together with Zoning Bylaw text

Zone Categories

- [Yellow Box] Residential
- [Light Green Box] Parks and Open Space
- [Pink Box] Commercial Residential
- [Orange Box] Commercial Residential Employment
- [Blue Box] Institutional
- [Purple Box] Employment
- [Grey Box] Utility / Transportation
- [White Box with Black Lines] Not Part of This Bylaw

[Blue Line] Map Sheet Boundary

[Dashed Line] Properties

[Grey Line] Railway



[White Line] Hydro Line

N

0 20 40 80 120 160 Meters

1:4,000

55Q-32 55Q-33 56Q-31 56Q-32 56Q-33
WARDEN AVE MCNICOLL AVE MIDLAND AVE
55Q-22 55Q-23 56Q-21 56Q-22 56Q-23
BIRCHMOUNT RD KENNEDY RD FINCH AVE E
55Q-12 55Q-13 56Q-11 56Q-12 56Q-13
FDR 22





The new City-wide Zoning By-law 569-2013 was enacted on May 9, 2013. It has been appealed under section 34(19) of the Planning Act. Even though it is under appeal, the City's Chief Building Official and the Committee of Adjustment will apply the new By-law to applications filed after its enactment. Please consult with your advisors to determine whether the new by-law has any impact.

Amendments to By-law 569-2013 have been incorporated into this office consolidation. The original by-law and its amendments are with the City Clerk's office.

Zoning By-law
No. 569-2013, as amended (office consolidation) in pdf:
[Chapters 1 - 800](#)
[Chapters 900.1 – 900.7](#)
[Chapters 900.8 – 995](#)

City of Toronto Zoning By-law 569-2013, as amended (Office Consolidation)

Version Date: August 19, 2014

Table of Contents

[Back to Top of Bylaw](#)

Chapter 1 [Administration](#)

Chapter 2 [Compliance with this By-law](#)

Chapter 5 [Regulations Applying to all Zones](#)

Chapter 10 [Residential](#)

Chapter 15 [Residential Apartment](#)

Chapter 30 [Commercial](#)

Chapter 40 [Commercial Residential](#)

Chapter 50 [Commercial Residential Employment](#)

Chapter 60 [Employment Industrial](#)

60.5 [Regulations Applying to the Employment - Industrial Zone](#)

60.10 [Category](#)

60.10 [Employment Light Industrial](#)

Chapter 60 Employment Industrial

60.30 Employment Heavy Industrial Zone (EH)

60.30.1 General

60.30.1.10 Interpretation

(1) Application of This Section

The regulations in Section 60.30 apply to all lands, uses, **buildings** and **structures** in the EH zone.

(2) Interpretation of the Employment Heavy Industrial Zone Symbol

The zone symbol on the Zoning By-law Map for the Employment Heavy Industrial Zones consists of the letters EH, indicating the primary land use permitted in the respective zone.

(3) Interpretation of the EH Zone Label

In the EH zone, the numerical value following the zone symbol in the zone label, on the Zoning By-law Map, represents the permitted maximum floor space index of all land uses on a **lot**.

60.30.20 Permitted Uses

60.30.20.1 General

(1) Existing Place of Worship

	<u>Zone (EL)</u>	In the EH zone, a lawfully existing place of worship is permitted if it is on a lot with a front lot line or side lot line abutting a major street on the Policy Area Overlay Map; and
60.20	<u>Employment Industrial Zone (E)</u>	
60.30	<u>Employment Heavy Industrial Zone (EH)</u>	(A) any expansion or addition to the place of worship building must comply with Section 150.50 and the requirements for the EH zone; and (B) it may be replaced with a new place of worship building if it complies with Section 150.50 and the requirements for the EH zone.
60.30.1	<u>General</u>	
60.30.1.10	<u>Interpretation</u>	
60.30.20	<u>Permitted Uses</u>	
60.30.20.1	<u>General</u>	
60.30.20.10	<u>Permitted Use</u>	
60.30.20.20	<u>Permitted Use - with Conditions</u>	In the EH zone, the following uses are permitted: Ambulance Depot Animal Shelter Bindery Building Supply Yards Carpenter's Shop Chemical Materials Storage Cold Storage Contractors Establishment Custom Workshop Dry Cleaning or Laundry Plant Fire Hall Fuel Storage Industrial Sales and Service Use Laboratory Manufacturing Use , if it is not one of the following: 1) Ammunition, Firearms or Fireworks Factory; 2) Crude Petroleum Oil or Coal Refinery; 3) Explosives Factory; 4) Tannery Police Station Public Utility Public Works Yard Recovery Facility Service Shop Shipping Terminal Vehicle Depot Vehicle Repair Shop Warehouse Waste Transfer Station
60.30.20.100	<u>Conditions</u>	
60.30.30	<u>Lot Requirements</u>	
60.30.30.20	<u>Lot Frontage</u>	
60.30.30.21	<u>Lot Frontage Exemptions</u>	
60.30.40	<u>Principal Building Requirements</u>	
60.30.40.10	<u>Height</u>	
60.30.40.11	<u>Height Exemptions</u>	
60.30.40.70	<u>Setbacks</u>	
60.30.40.71	<u>Setbacks Exemptions</u>	
60.30.60	<u>Ancillary Buildings and Structures</u>	
60.30.60.1	<u>General</u>	
60.30.90	<u>Loading</u>	
60.30.90.10	<u>Location</u>	
60.40	<u>Employment Industrial Office Zone (EO)</u>	
Chapter 80	<u>Institutional</u>	
Chapter 90	<u>Open Space</u>	
Chapter 100	<u>Utility and</u>	
		Cogeneration Energy (10)

	<u>Transportation</u>	Crematorium (14) Open Storage (1) Outside Operations (2) Propane Transfer, Handling and Storage Facility (9)
Chapter 150	<u>Specific Use</u> <u>Regulations</u>	Renewable Energy (10) Transportation Use (12) Vehicle Service Shop (5,13)
Chapter 200	<u>Parking</u> <u>Space</u> <u>Regulations</u>	
Chapter 220	<u>Loading</u> <u>Space</u> <u>Regulations</u>	(1) <u>Use with Conditions - EH Zone</u>
Chapter 230	<u>Bicycle</u> <u>Parking</u> <u>Space</u> <u>Regulations</u>	In the EH zone, the following uses are permitted if they comply with the specific conditions associated with the reference number(s) for each use in Clause 60.30.20.100: Cogeneration Energy (10) Crematorium (14) Medical marihuana production facility (3) Open Storage (1) Outside Operations (2) Propane Transfer, Handling and Storage Facility (9)
Chapter 280	<u>Special</u> <u>Districts -</u> <u>Downtown</u>	Renewable Energy (10) Transportation Use (12) Vehicle Service Shop (5,13) [By-law: 0403-2014 Under Appeal]
Chapter 300	<u>Special</u> <u>Districts -</u> <u>Centres</u>	
Chapter 400	<u>Special</u> <u>Districts -</u> <u>Avenues</u>	
Chapter 500	<u>Special</u> <u>Districts -</u> <u>Heritage</u>	
Chapter 600	<u>Regulations</u> <u>for Overlay</u> <u>Zones</u>	In the EH zone:
Chapter 800	<u>Definitions</u>	(A) open storage must:
Chapter 900	<u>Site Specific</u> <u>Exceptions</u>	(i) not encroach into a required minimum building setback ; and
Chapter 970	<u>Appendices</u>	(ii) be enclosed by a fence; and
Chapter 990	<u>Zoning By-law</u> <u>Map</u>	
Chapter 995	<u>Overlay Maps</u>	(B) open storage may be for recyclable material or waste.

60.30.20.100 Conditions

(1) Open Storage

In the EH zone:

(A) **open storage** must:

(i) not encroach into a required minimum **building setback**; and

(ii) be enclosed by a fence; and

(B) **open storage** may be for **recyclable material** or waste.

(2) Outside Operations

In the EH zone, outside operations:

(A) must be combined with a permitted **manufacturing use**;

(B) may not encroach into a required minimum **building setback**; and

(C) must be enclosed by a fence.

(3) (THIS DOES NOT CURRENTLY CONTAIN A REGULATION)

(3) Medical Marihuana Production Facility

In the E zone, a **medical marihuana production facility** must comply with the specific use regulations in Section 150.60.

[By-law: 0403-2014 Under Appeal]

(4) (THIS DOES NOT CURRENTLY CONTAIN A REGULATION)

(5) Vehicle Service Shop

In the EH zone, a **vehicle service shop** must comply with the specific use regulations in Section 150.94.

(6) (THIS DOES NOT CURRENTLY CONTAIN A REGULATION)

(7) (THIS DOES NOT CURRENTLY CONTAIN A REGULATION)

(8) (THIS DOES NOT CURRENTLY CONTAIN A REGULATION)

(9) Propane Transfer, Handling and Storage Facility

In the EH zone, a propane transfer, handing and storage facility pertains to facilities which transfer, handle, or store propane in quantities equal to or greater than 5,000 U.S. Water Gallons (USWG) on the **lot**, and:

(A) may be on a **lot** that is at least 500 metres from a **lot** in the Residential Zone category, Residential Apartment Zone category, Commercial Zone category, Commercial Residential Zone category, Commercial Residential Employment Zone category, Institutional Zone category, or Open Space Zone category; and

(B) is not a permitted **manufacturing use** that involves propane in the manufacturing process, or in the operation of equipment or **vehicles** that is not subject to regulation (A) above.

(10) Renewable Energy Production or Cogeneration Energy Production

In a EH zone, **renewable energy** production or **cogeneration energy** production must be in combination with another permitted use on the **lot**, and comply with all Municipal, Provincial and Federal by-laws, statutes and regulations.

(11) (THIS DOES NOT CURRENTLY CONTAIN A REGULATION)

(12) Transportation Use

A **building** or **structure** on a **lot** in the EH zone and used as a **transportation use** must comply with all requirements for a **building** on that **lot**.

(13) Vehicle Service Shop - Open Storage

In the EH zone, a **vehicle service shop** may have **open storage** if it is:

- (A) less than 20% of the area of the **lot** that is not covered by wholly enclosed **buildings**; and
- (B) enclosed by a fence.

(14) Crematorium

In the EH zone, a **crematorium** must be a minimum of 300 metres from a **lot** that is not in the EL, E, EH or UT zone.

60.30.30 Lot Requirements

60.30.30.20 Lot Frontage

(1) Minimum Lot Frontage for Lots in the EH zone

In the EH zone, the required minimum **lot frontage** is 30.0 metres.

60.30.30.21 Lot Frontage Exemptions

(1) Permitted Lot Frontage for Lawfully Existing Lots

In the EH zone, if the **lawful lot frontage** of a **lawfully existing lot** is less than the required minimum **lot frontage**, that **lawful lot frontage** is the minimum **lot frontage** for that **lawfully existing lot**.


(2) Additions to Lawfully Existing Buildings

Any addition or extension to a **lawfully existing building** or **structure** on a **lot** referred to in regulation 60.30.30.21(1) must comply with all other applicable regulations of this By-law or be authorized by a Section 45 Planning Act minor variance.

Map Excerpted from Scarborough
General Zoning By-law 24982

CON. 4

STEELES COMMUNITY



CLAUSE VI - ZONE PROVISIONS

NOTE: PLEASE REFER BACK TO THE CLAUSE III - INTERPRETATION,
CLAUSE IV - DEFINITIONS AND CLAUSE V - GENERAL PROVISIONS SECTIONS
OF THE BY-LAW TO ENSURE COMPLIANCE WITH THOSE PROVISIONS OF THE BY-LAW.

1. Industrial Zone (M)

(a) Permitted Uses

- **Day Nurseries**
- Educational and Training Facility Uses
- **Industrial Uses**
- Offices, excluding Medical and Dental Offices
- **Places of Worship**
- **Recreational Uses**

(b) Supplementary Regulations

- (i) All uses shall be conducted wholly within an enclosed building.

2. General Industrial Zone (MG)

(a) Permitted Uses

- **Day Nurseries**
- Educational and Training Facility Uses
- **Industrial Uses**
- Offices, excluding Medical and Dental Offices
- **Open Storage**
- **Places of Worship**
- **Recreational Uses**

3. Special Industrial Zone (MS)

(a) Permitted Uses

- **Day Nurseries**
- Educational and Training Facility Uses
- **Industrial Uses**
- Offices, excluding Medical and Dental Offices

- **Open Storage**
- **Places of Worship**
- **Recreational Uses**
- **Special Industrial Uses**

4. Mixed Employment Zone (ME)

(a) Permitted Uses

- **Day Nurseries**
- Educational and Training Facility Uses
- **Financial Institutions**
- **Industrial Uses**
- Offices
- **Personal Service Shops**
- **Places of Worship**
- **Recreational Uses**
- **Restaurants**
- Retail Stores

(b) Supplementary Regulations

- (i) All Uses shall be conducted wholly within an enclosed building

5. Employment Zone (E)

(a) Permitted Uses

- **Day Nurseries**
- Educational and Training Facility Uses
- **Industrial Uses**
- Offices
- **Places of Worship**
- **Recreational Uses**


6. Office Uses Zone (OU)

(a) Permitted Uses:

- **Day Nurseries**
- Educational and Training Facility Uses
- **Financial Institutions**
- Libraries

Appendix B

This page intentionally left blank
for 2-sided printing purposes



Note : Calculated unit weights are shipping weights and do not reflect operating conditions, items which are field installed or ship loose.

(A)	LOUVRE Std Louvre	SIZE : 22 X 22
(B)	LOUVRE Std Louvre	SIZE : 14 X 14
(C)	GAS FIRED FURNACE, 20:1 TURNDOWN MAKE : HC MODEL : HE 1750 FUEL PRESSURE: 0.500 psi INPUT : 2250 MBH OUTPUT : 1800 MBH	
(D)	FILTERS : LIFT-OUT UPSTREAM VELOCITY : 500 FPM TYPE : 2" (MERV 8) Farr 30/30 SIZES : 6 @ 24 X 24 3 @ 24 X 12	
(E)	FAN : (RF) 27" EPF SW, Arrangement-3 AIR FLOW : 15000 CFM RPM : 1677 T.S.P. : 3.5 in wc CLASS : II MOTOR : 20 HP, ODP Prem-Eff, 460/3/60 RPM : 1750 (GROUNDED SHAFT) ISOLATORS : OS DEF : 2 in FEG75 η_{pt} : 73% η_t / η_{pt} : 94%	
(F)	FAN : (SF) 24" BAE DW, Arrangement-3 AIR FLOW : 15000 CFM RPM : 1499 T.S.P. : 3.75 in wc CLASS : II MOTOR : 15 HP, ODP Prem-Eff, 460/3/60 RPM : 1750 (GROUNDED SHAFT) ISOLATORS : OS DEF : 2 in FEG85 η_{pt} : 82% η_t / η_{pt} : 99%	
(G)	DRAIN PAN	
(H)	HEAT PIPE TYPE : Heat Pipe Technology, 6 ROW SIZES : 2 @ 30 X 144	
(I)	OA BYPASS DAMPER : OPPOSED BLADES MAKE : T.A. Morrison 1000 SIZE : 48 X 30	
(J)	FILTERS : LIFT-OUT UPSTREAM VELOCITY : 500 FPM TYPE : 2" (MERV 8) Farr 30/30 SIZES : 6 @ 24 X 24 3 @ 24 X 12	
(K)	OA HOOD TYPICAL OF 2	
(L)	OA DAMPER : OPPOSED BLADES MAKE : T.A. Morrison 1000 SIZE : 71 X 44	
(M)	EA LV DAMPER : PARALLEL BLADES MAKE : T.A. Morrison 1000 SIZE : 80 X 42	
(N)	LOUVRE Std Louvre SIZE : 80 X 42	
UNIT MOUNTING The unit is designed to be mounted on a roof curb.		


SDG VER: Jun 20 2014

PROJECT

MBG - TORONTO TRANSIT CENTER

OPENINGS AND DIMENSIONS MAY VARY
FROM CONTRACT DOCUMENTS. RETURN
OF APPROVED DRAWINGS CONSTITUTES
ACCEPTANCE OF THESE VARIANCES.

JOB NO.	49446	DRAWN BY	TN	DWG NO.	49446U26SD01	ACCESS SIDE	RIGHT	DWG UNITS	IN	SALES OFFICE	TRAN. VANCOUVER
TAG	AHU-1-3	DATE	JUN 26/14	TYPE	OUTDOOR	10:00		SCALE	N.T.S.	SALES ENGINEER	IVAN HOLD



Note : Calculated unit weights are shipping weights and do not reflect operating conditions, items which are field installed or ship loose.

(A)	LOUVRE Std Louvre	SIZE : 22 X 22
(B)	LOUVRE Std Louvre	SIZE : 14 X 14
(C)	GAS FIRED FURNACE, 20:1 TURNDOWN MAKE : HC MODEL : HE 2000 FUEL PRESSURE: 0.500 psi INPUT : 2500 MBH OUTPUT : 2000 MBH	
(D)	FILTERS : LIFT-OUT UPSTREAM VELOCITY : 500 FPM TYPE : 2" (MERV 8) Farr 30/30 SIZES : 9 @ 24 X 24	
(E)	FAN : (RF) 30" EPF SW, Arrangement-3 AIR FLOW : 18000 CFM RPM : 1480 T.S.P. : 3.5 in wc CLASS : II MOTOR : 20 HP, ODP Prem-Eff, 460/3/60 RPM : 1750 (GROUNDED SHAFT) ISOLATORS : OS DEF : 2 in FEG80 η_{pt} : 74% η_t / η_{pt} : 95%	
(F)	FAN : (SF) 27" BAE DW, Arrangement-3 AIR FLOW : 18000 CFM RPM : 1369 T.S.P. : 3.75 in wc CLASS : II MOTOR : 20 HP, ODP Prem-Eff, 460/3/60 RPM : 1750 (GROUNDED SHAFT) ISOLATORS : OS DEF : 2 in FEG90 η_{pt} : 85% η_t / η_{pt} : 97%	
(G)	DRAIN PAN	
(H)	HEAT PIPE TYPE : Heat Pipe Technology, 6 ROW SIZES : 2 @ 33.75 X 158	
(I)	OA BYPASS DAMPER : OPPOSED BLADES MAKE : T.A. Morrison 1000 SIZE : 58 X 30	
(J)	FILTERS : LIFT-OUT UPSTREAM VELOCITY : 375 FPM TYPE : 2" (MERV 8) Farr 30/30 SIZES : 12 @ 24 X 24	
(K)	OA HOOD TYPICAL OF 2	
(L)	OA DAMPER : OPPOSED BLADES MAKE : T.A. Morrison 1000 SIZE : 78 X 48	
(M)	EA LV DAMPER : PARALLEL BLADES MAKE : T.A. Morrison 1000 SIZE : 80 X 50	
(N)	LOUVRE Std Louvre SIZE : 80 X 50	
	UNIT MOUNTING The unit is designed to be mounted on a roof curb.	

SDG VER: Jun 20 2014


0 24 48 72 96

PROJECT

MBG - TORONTO TRANSIT CENTER

OPENINGS AND DIMENSIONS MAY VARY
FROM CONTRACT DOCUMENTS. RETURN
OF APPROVED DRAWINGS CONSTITUTES
ACCEPTANCE OF THESE VARIANCES.

JOB NO.	49446	DRAWN BY	TN	DWG NO.	49446U30SD01	ACCESS SIDE	RIGHT	DWG UNITS	IN	SALES OFFICE	TRAN. VANCOUVER
TAG	AHU-4	DATE	JUN 26/14	TYPE	OUTDOOR	10:00		SCALE	N.T.S.	SALES ENGINEER	IVAN HOLDY



Note : Calculated unit weights are shipping weights and do not reflect operating conditions, items which are field installed or ship loose.

(A)	LOUvre Std Louvre	SIZE : 22 X 22
(B)	LOUvre Std Louvre	SIZE : 14 X 14
(C)	GAS FIRED FURNACE, 20:1 TURNDOWN MAKE : HC MODEL : HE 1500 FUEL PRESSURE: 0.500 psi INPUT : 1875 MBH OUTPUT : 1500 MBH	
(D)	FILTERS : LIFT-OUT UPSTREAM VELOCITY : 500 FPM TYPE : 2" (MERV 8) Farr 30/30 SIZES : 6 @ 24 X 24 3 @ 24 X 12	
(E)	FAN : (RF) 27" EPF SW, Arrangement-3 AIR FLOW : 15000 CFM RPM : 1677 T.S.P. : 3.5 in wc CLASS : II MOTOR : 20 HP, ODP Prem-Eff, 460/3/60 RPM : 1750 (GROUNDED SHAFT) ISOLATORS : OS DEF : 2 in FEG75 η_{pt} : 73% η_t / η_{pt} : 94%	
(F)	FAN : (SF) 24" BAE DW, Arrangement-3 AIR FLOW : 15000 CFM RPM : 1499 T.S.P. : 3.75 in wc CLASS : II MOTOR : 15 HP, ODP Prem-Eff, 460/3/60 RPM : 1750 (GROUNDED SHAFT) ISOLATORS : OS DEF : 2 in FEG85 η_{pt} : 82% η_t / η_{pt} : 99%	
(G)	DRAIN PAN	
(H)	HEAT PIPE TYPE : Heat Pipe Technology, 6 ROW SIZES : 2 @ 30 X 144	
(I)	OA BYPASS DAMPER : OPPOSED BLADES MAKE : T.A. Morrison 1000 SIZE : 48 X 30	
(J)	FILTERS : LIFT-OUT UPSTREAM VELOCITY : 500 FPM TYPE : 2" (MERV 8) Farr 30/30 SIZES : 6 @ 24 X 24 3 @ 24 X 12	
(K)	OA HOOD TYPICAL OF 2	
(L)	OA DAMPER : OPPOSED BLADES MAKE : T.A. Morrison 1000 SIZE : 71 X 44	
(M)	EA LV DAMPER : PARALLEL BLADES MAKE : T.A. Morrison 1000 SIZE : 80 X 42	
(N)	LOUvre Std Louvre SIZE : 80 X 42	
	UNIT MOUNTING The unit is designed to be mounted on a roof curb.	


SDG VER: Jun 20 2014

PROJECT

MBG - TORONTO TRANSIT CENTER

OPENINGS AND DIMENSIONS MAY VARY
FROM CONTRACT DOCUMENTS. RETURN
OF APPROVED DRAWINGS CONSTITUTES
ACCEPTANCE OF THESE VARIANCES.

JOB NO.	49446	DRAWN BY	TN	DWG NO.	49446U31SD01	ACCESS SIDE	RIGHT	DWG UNITS	IN	SALES OFFICE	TRANSPORT VANCOUVER
TAG	5-7,9-11,13-15	DATE	JUN 26/14	TYPE	OUTDOOR	10:00		SCALE	N.T.S.	SALES ENGINEER	IVAN HOLDY



Note : Calculated unit weights are shipping weights and do not reflect operating conditions, items which are field installed or ship loose.

(A)	LOUVRE Std Louvre	SIZE : 22 X 22
(B)	LOUVRE Std Louvre	SIZE : 14 X 14
(C)	GAS FIRED FURNACE, 20:1 TURNDOWN MAKE : HC MODEL : HE 1750 FUEL PRESSURE: 0.500 psi INPUT : 2250 MBH OUTPUT : 1800 MBH	
(D)	FILTERS : LIFT-OUT UPSTREAM VELOCITY : 500 FPM TYPE : 2" (MERV 8) Farr 30/30 SIZES : 9 @ 24 X 24	
(E)	FAN : (RF) 30" EPF SW, Arrangement-3 AIR FLOW : 18000 CFM RPM : 1480 T.S.P. : 3.5 in wc CLASS : II MOTOR : 20 HP, ODP Prem-Eff, 460/3/60 RPM : 1750 (GROUNDED SHAFT) ISOLATORS : OS DEF : 2 in FEG80 η_{pt} : 74% η_t / η_{pt} : 95%	
(F)	FAN : (SF) 27" BAE DW, Arrangement-3 AIR FLOW : 18000 CFM RPM : 1369 T.S.P. : 3.75 in wc CLASS : II MOTOR : 20 HP, ODP Prem-Eff, 460/3/60 RPM : 1750 (GROUNDED SHAFT) ISOLATORS : OS DEF : 2 in FEG90 η_{pt} : 85% η_t / η_{pt} : 97%	
(G)	DRAIN PAN	
(H)	HEAT PIPE TYPE : Heat Pipe Technology, 6 ROW SIZES : 2 @ 33.75 X 158	
(I)	OA BYPASS DAMPER : OPPOSED BLADES MAKE : T.A. Morrison 1000 SIZE : 58 X 30	
(J)	FILTERS : LIFT-OUT UPSTREAM VELOCITY : 375 FPM TYPE : 2" (MERV 8) Farr 30/30 SIZES : 12 @ 24 X 24	
(K)	OA HOOD TYPICAL OF 2	
(L)	OA DAMPER : OPPOSED BLADES MAKE : T.A. Morrison 1000 SIZE : 78 X 48	
(M)	EA LV DAMPER : PARALLEL BLADES MAKE : T.A. Morrison 1000 SIZE : 80 X 50	
(N)	LOUVRE Std Louvre	SIZE : 80 X 50
UNIT MOUNTING The unit is designed to be mounted on a roof curb.		

SDG VER: Jun 20 2014


0 24 48 72 96

PROJECT

MBG - TORONTO TRANSIT CENTER

OPENINGS AND DIMENSIONS MAY VARY
FROM CONTRACT DOCUMENTS. RETURN
OF APPROVED DRAWINGS CONSTITUTES
ACCEPTANCE OF THESE VARIANCES.

JOB NO.	49446	DRAWN BY	TN	DWG NO.	49446U32SD01	ACCESS SIDE	RIGHT	DWG UNITS	IN	SALES OFFICE	TRAN. VANCOUVER
TAG	AHU-8,12,16	DATE	JUN 26/14	TYPE	OUTDOOR	10:00		SCALE	N.T.S.	SALES ENGINEER	IVAN HOLD




PROJECT

MBG - TORONTO TRANSIT CENTER

OPENINGS AND DIMENSIONS MAY VARY
FROM CONTRACT DOCUMENTS. RETURN
OF APPROVED DRAWINGS CONSTITUTES
ACCEPTANCE OF THESE VARIANCES.

JOB NO.	49446	DRAWN BY	TN	DWG NO.	49446U33SD01	ACCESS SIDE	RIGHT	DWG UNITS	IN	SALES OFFICE	TRAN. VANCOUVER
TAG	AHU-17-20	DATE	JUN 26/14	TYPE	OUTDOOR	10:00		SCALE	N.T.S.	SALES ENGINEER	IVAN HOLD



Note : Calculated unit weights are shipping weights and do not reflect operating conditions, items which are field installed or ship loose.

(A)	LOUVRE Std Louvre	SIZE : 22 X 22
(B)	LOUVRE Std Louvre	SIZE : 14 X 14
(C)	GAS FIRED FURNACE, 20:1 TURNDOWN MAKE : HC MODEL : HE 1500 FUEL PRESSURE: 0.500 psi INPUT : 1875 MBH OUTPUT : 1500 MBH	
(D)	FILTERS : LIFT-OUT UPSTREAM VELOCITY : 436 FPM TYPE : 2" (MERV 8) Farr 30/30 SIZES : 3 @ 24 X 12 9 @ 24 X 24	
(E)	FAN : (RF) 30" EPQ SW, Arrangement-3 AIR FLOW : 18300 CFM RPM : 1506 T.S.P. : 3.5 in wc CLASS : II MOTOR : 20 HP, ODP Prem-Eff, 460/3/60 RPM : 1750 (GROUNDED SHAFT) ISOLATORS : OS DEF : 2 in FEG75 η_{pt} : 73% η_t / η_{pt} : 90%	
(F)	FAN : (SF) 27" BAE DW, Arrangement-3 AIR FLOW : 18300 CFM RPM : 1379 T.S.P. : 3.75 in wc CLASS : II MOTOR : 20 HP, ODP Prem-Eff, 460/3/60 RPM : 1750 (GROUNDED SHAFT) ISOLATORS : OS DEF : 2 in FEG90 η_{pt} : 85% η_t / η_{pt} : 97%	
(G)	DRAIN PAN	
(H)	HEAT PIPE TYPE : Heat Pipe Technology, 6 ROW SIZES : 2 @ 33.75 X 160	
(I)	OA BYPASS DAMPER : OPPOSED BLADES MAKE : T.A. Morrison 1000 SIZE : 66 X 27	
(J)	FILTERS : LIFT-OUT UPSTREAM VELOCITY : 436 FPM TYPE : 2" (MERV 8) Farr 30/30 SIZES : 9 @ 24 X 24 3 @ 24 X 12	
(K)	OA HOOD TYPICAL OF 2	
(L)	OA DAMPER : OPPOSED BLADES MAKE : T.A. Morrison 1000 SIZE : 74 X 51	
(M)	EA LV DAMPER : PARALLEL BLADES MAKE : T.A. Morrison 1000 SIZE : 80 X 50	
(N)	LOUVRE Std Louvre SIZE : 80 X 50	
	UNIT MOUNTING The unit is designed to be mounted on a roof curb.	


SDG VER: Jun 20 2014

PROJECT

MBG - TORONTO TRANSIT CENTER

OPENINGS AND DIMENSIONS MAY VARY
FROM CONTRACT DOCUMENTS. RETURN
OF APPROVED DRAWINGS CONSTITUTES
ACCEPTANCE OF THESE VARIANCES.

JOB NO.	49446	DRAWN BY	TN	DWG NO.	49446U34SD01	ACCESS SIDE	RIGHT	DWG UNITS	IN	SALES OFFICE	TRANSPORT VANCOUVER
TAG	AHU-21,22	DATE	JUN 26/14	TYPE	OUTDOOR	10:00		SCALE	N.T.S.	SALES ENGINEER	IVAN HOLDY



Note : Calculated unit weights are shipping weights and do not reflect operating conditions, items which are field installed or ship loose.

(A)	LOUVRE Std Louvre	SIZE : 22 X 22
(B)	LOUVRE Std Louvre	SIZE : 14 X 14
(C)	GAS FIRED FURNACE, 20:1 TURNDOWN MAKE : HC MODEL : HE 3000 FUEL PRESSURE: 0.500 psi INPUT : 3750 MBH OUTPUT : 3000 MBH	
(D)	FILTERS : LIFT-OUT UPSTREAM VELOCITY : 446 FPM TYPE : 2" (MERV 8) Farr 30/30 SIZES : 16 @ 24 X 24 4 @ 24 X 12	
(E)	FAN : (RF) 40" EPF SW, Arrangement-3 AIR FLOW : 32100 CFM RPM : 1070 T.S.P. : 3.5 in wc CLASS : II MOTOR : 40 HP, ODP Prem-Eff, 460/3/60 RPM : 1750 (GROUNDED SHAFT) ISOLATORS : OS DEF : 2 in FEG80 η_{pt} : 76% η_t / η_{pt} : 96%	
(F)	FAN : (SF) 36" BAE DW, Arrangement-3 AIR FLOW : 32100 CFM RPM : 982 T.S.P. : 3.75 in wc CLASS : II MOTOR : 30 HP, ODP Prem-Eff, 460/3/60 RPM : 1750 (GROUNDED SHAFT) ISOLATORS : OS DEF : 2 in FEG90 η_{pt} : 85% η_t / η_{pt} : 99%	
(G)	DRAIN PAN	
(H)	HEAT PIPE TYPE : Heat Pipe Technology, 6 ROW SIZES : 2 @ 50 X 186	
(I)	OA BYPASS DAMPER : OPPOSED BLADES MAKE : T.A. Morrison 1000 SIZE : 94 X 30	
(J)	FILTERS : LIFT-OUT UPSTREAM VELOCITY : 401 FPM TYPE : 2" (MERV 8) Farr 30/30 SIZES : 16 @ 24 X 24 8 @ 24 X 12	
(K)	OA HOOD TYPICAL OF 2	
(L)	OA DAMPER : OPPOSED BLADES MAKE : T.A. Morrison 1000 SIZE : 90 X 74	
(M)	EA LV DAMPER : PARALLEL BLADES MAKE : T.A. Morrison 1000 SIZE : 2 @ 48 X 70	
(N)	LOUVRE Std Louvre SIZE : 100 X 70	
UNIT MOUNTING The unit is designed to be mounted on a roof curb.		

SDG VER: Jun 20 2014

0 24 48 72 96


PROJECT

MBG - TORONTO TRANSIT CENTER

OPENINGS AND DIMENSIONS MAY VARY
FROM CONTRACT DOCUMENTS. RETURN
OF APPROVED DRAWINGS CONSTITUTES
ACCEPTANCE OF THESE VARIANCES.

JOB NO.	49446	DRAWN BY	TN	DWG NO.	49446U35SD01	ACCESS SIDE	RIGHT	DWG UNITS	IN	SALES OFFICE	TRAN. VANCOUVER
TAG	AHU-23	DATE	JUN 26/14	TYPE	OUTDOOR	10:00		SCALE	N.T.S.	SALES ENGINEER	IVAN HOLD

(A)	LOUVRE	SIZE : 22 X 22
	Std Louvre	
(B)	LOUVRE	SIZE : 14 X 14
	Std Louvre	
(C)	GAS FIRED FURNACE, 20:1 TURNDOWN MAKE : HC MODEL : HE 4000 FUEL PRESSURE: 0.500 psi INPUT : 5000 MBH OUTPUT : 4000 MBH	
(D)	FAN : (SF) 2 @ 30° BAE DW, Arrangement-3 AIR FLOW : 21000 CFM RPM : 1178 T.S.P. : 3.5 in wc CLASS : II MOTOR : 20 HP, ODP Prem-Eff, 460/3/60 RPM : 1750 (GROUNDED SHAFT) ISOLATORS : OS DEF : 2 in FEG90 η_{pt} : 85% η_t / η_{pt} : 98%	
(E)	FILTERS : LIFT-OUT UPSTREAM VELOCITY : 500 FPM TYPE : 2" (MERV 8) Farr 30/30 SIZES : 21 @ 24 X 24	
(F)	OA HOOD TYPICAL OF 2	
(G)	OA DAMPER : OPPOSED BLADES MAKE : T.A. Morrison 1000 SIZE : 149 X 58	
UNIT MOUNTING		
The unit is designed to be mounted on a roof curb.		
Note : Calculated unit weights are shipping weights and do not reflect operating conditions, items which are field installed or ship loose.		




PROJECT

MBG - TORONTO TRANSIT CENTER

OPENINGS AND DIMENSIONS MAY VARY
FROM CONTRACT DOCUMENTS. RETURN
OF APPROVED DRAWINGS CONSTITUTES
ACCEPTANCE OF THESE VARIANCES.

JOB NO.	49446	DRAWN BY	TN	DWG NO.	49446U36SD01	ACCESS SIDE	RIGHT	DWG UNITS	IN	SALES OFFICE	TRANE VANCOUVER
TAG	AHU-24	DATE	JUN 26/14	TYPE	OUTDOOR	10:00		SCALE	N.T.S.	SALES ENGINEER	IVAN HOLDI



Note : Calculated unit weights are shipping weights and do not reflect operating conditions, items which are field installed or ship loose.

(A)	LOUVRE Std Louvre	SIZE : 22 X 22
(B)	LOUVRE Std Louvre	SIZE : 14 X 14
(C)	GAS FIRED FURNACE, 20:1 TURNDOWN MAKE : HC MODEL : HE 1500 FUEL PRESSURE: 0.500 psi INPUT : 1875 MBH OUTPUT : 1500 MBH	
(D)	FILTERS : LIFT-OUT UPSTREAM VELOCITY : 470 FPM TYPE : 2" (MERV 8) Farr 30/30 SIZES : 6 @ 24 X 24 3 @ 24 X 12	
(E)	FAN : (RF) 27" EPF SW, Arrangement-3 AIR FLOW : 14100 CFM RPM : 1616 T.S.P. : 3.5 in wc CLASS : II MOTOR : 15 HP, ODP Prem-Eff, 460/3/60 RPM : 1750 (GROUNDED SHAFT) ISOLATORS : OS DEF : 2 in FEG75 η_{pt} : 73% η_t / η_{pt} : 95%	
(F)	FAN : (SF) 24" BAE DW, Arrangement-3 AIR FLOW : 14100 CFM RPM : 1461 T.S.P. : 3.75 in wc CLASS : II MOTOR : 15 HP, ODP Prem-Eff, 460/3/60 RPM : 1750 (GROUNDED SHAFT) ISOLATORS : OS DEF : 2 in FEG85 η_{pt} : 82% η_t / η_{pt} : 99%	
(G)	DRAIN PAN	
(H)	HEAT PIPE TYPE : Heat Pipe Technology, 6 ROW SIZES : 2 @ 27.75 X 152	
(I)	OA BYPASS DAMPER : OPPOSED BLADES MAKE : T.A. Morrison 1000 SIZE : 46 X 30	
(J)	FILTERS : LIFT-OUT UPSTREAM VELOCITY : 470 FPM TYPE : 2" (MERV 8) Farr 30/30 SIZES : 6 @ 24 X 24 3 @ 24 X 12	
(K)	OA HOOD TYPICAL OF 2	
(L)	OA DAMPER : OPPOSED BLADES MAKE : T.A. Morrison 1000 SIZE : 71 X 41	
(M)	EA LV DAMPER : PARALLEL BLADES MAKE : T.A. Morrison 1000 SIZE : 80 X 38	
(N)	LOUVRE Std Louvre SIZE : 80 X 38	
	UNIT MOUNTING The unit is designed to be mounted on a roof curb.	


SDG VER: Jun 20 2014

PROJECT

MBG - TORONTO TRANSIT CENTER

OPENINGS AND DIMENSIONS MAY VARY
FROM CONTRACT DOCUMENTS. RETURN
OF APPROVED DRAWINGS CONSTITUTES
ACCEPTANCE OF THESE VARIANCES.

JOB NO.	49446	DRAWN BY	TN	DWG NO.	49446U37SD01	ACCESS SIDE	RIGHT	DWG UNITS	IN	SALES OFFICE	TRANE VANCOUVER
TAG	AHU-25	DATE	JUN 26/14	TYPE	OUTDOOR	10:00		SCALE	N.T.S.	SALES ENGINEER	IVAN HOLD



Note : Calculated unit weights are shipping weights and do not reflect operating conditions, items which are field installed or ship loose.

(A)	LOUVRE Std Louvre	SIZE : 22 X 22
(B)	LOUVRE Std Louvre	SIZE : 14 X 14
(C)	GAS FIRED FURNACE, 20:1 TURNDOWN MAKE : HC MODEL : HE 2500 FUEL PRESSURE: 0.500 psi INPUT : 3000 MBH OUTPUT : 2400 MBH	
(D)	FILTERS : LIFT-OUT UPSTREAM VELOCITY : 471 FPM TYPE : 2" (MERV 8) Farr 30/30 SIZES : 3 @ 24 X 12 9 @ 24 X 24	
(E)	FAN : (RF) 30" EPF SW, Arrangement-3 AIR FLOW : 19800 CFM RPM : 1567 T.S.P. : 3.5 in wc CLASS : II MOTOR : 25 HP, ODP Prem-Eff, 460/3/60 RPM : 1750 (GROUNDED SHAFT) ISOLATORS : OS DEF : 2 in FEG80 η_{pt} : 74% η_t / η_{pt} : 93%	
(F)	FAN : (SF) 30" BAE DW, Arrangement-3 AIR FLOW : 19800 CFM RPM : 1174 T.S.P. : 3.75 in wc CLASS : II MOTOR : 20 HP, ODP Prem-Eff, 460/3/60 RPM : 1750 (GROUNDED SHAFT) ISOLATORS : OS DEF : 2 in FEG90 η_{pt} : 85% η_t / η_{pt} : 99%	
(G)	DRAIN PAN	
(H)	HEAT PIPE TYPE : Heat Pipe Technology, 6 ROW SIZES : 2 @ 33.75 X 174	
(I)	OA BYPASS DAMPER : OPPOSED BLADES MAKE : T.A. Morrison 1000 SIZE : 64 X 30	
(J)	FILTERS : LIFT-OUT UPSTREAM VELOCITY : 367 FPM TYPE : 2" (MERV 8) Farr 30/30 SIZES : 12 @ 24 X 24 3 @ 24 X 12	
(K)	OA HOOD TYPICAL OF 2	
(L)	OA DAMPER : OPPOSED BLADES MAKE : T.A. Morrison 1000 SIZE : 82 X 50	
(M)	EA LV DAMPER : PARALLEL BLADES MAKE : T.A. Morrison 1000 SIZE : 80 X 54	
(N)	LOUVRE Std Louvre SIZE : 80 X 54	
UNIT MOUNTING The unit is designed to be mounted on a roof curb.		

SDG VER: Jun 20 2014


0 24 48 72 96

PROJECT

MBG - TORONTO TRANSIT CENTER

OPENINGS AND DIMENSIONS MAY VARY
FROM CONTRACT DOCUMENTS. RETURN
OF APPROVED DRAWINGS CONSTITUTES
ACCEPTANCE OF THESE VARIANCES.

JOB NO.	49446	DRAWN BY	TN	DWG NO.	49446U38SD01	ACCESS SIDE	RIGHT	DWG UNITS	IN	SALES OFFICE	TRANSPORT VANCOUVER
TAG	AHU-26	DATE	JUN 26/14	TYPE	OUTDOOR	10:00		SCALE	N.T.S.	SALES ENGINEER	IVAN HOLDY



Note : Calculated unit weights are shipping weights and do not reflect operating conditions, items which are field installed or ship loose.

(A)	LOUVRE Std Louvre	SIZE : 22 X 22
(B)	LOUVRE Std Louvre	SIZE : 14 X 14
(C)	GAS FIRED FURNACE, 20:1 TURNDOWN MAKE : HC MODEL : HE 1750 FUEL PRESSURE: 0.500 psi INPUT : 2250 MBH OUTPUT : 1800 MBH	
(D)	FILTERS : LIFT-OUT UPSTREAM VELOCITY : 476 FPM TYPE : 2" (MERV 8) Farr 30/30 SIZES : 5 @ 24 X 12 6 @ 24 X 24	
(E)	FAN : (RF) 27" EPQ SW, Arrangement-3 AIR FLOW : 16200 CFM RPM : 1779 T.S.P. : 3.5 in wc CLASS : II MOTOR : 20 HP, ODP Prem-Eff, 460/3/60 RPM : 1750 (GROUNDED SHAFT) ISOLATORS : OS DEF : 2 in FEG75 η_{pt} : 72% η_t / η_{pt} : 89%	
(F)	FAN : (SF) 27" BAE DW, Arrangement-3 AIR FLOW : 16200 CFM RPM : 1309 T.S.P. : 3.75 in wc CLASS : II MOTOR : 15 HP, ODP Prem-Eff, 460/3/60 RPM : 1750 (GROUNDED SHAFT) ISOLATORS : OS DEF : 2 in FEG90 η_{pt} : 85% η_t / η_{pt} : 99%	
(G)	DRAIN PAN	
(H)	HEAT PIPE TYPE : Heat Pipe Technology, 6 ROW SIZES : 2 @ 30 X 156	
(I)	OA BYPASS DAMPER : OPPOSED BLADES MAKE : T.A. Morrison 1000 SIZE : 52 X 30	
(J)	FILTERS : LIFT-OUT UPSTREAM VELOCITY : 476 FPM TYPE : 2" (MERV 8) Farr 30/30 SIZES : 6 @ 24 X 24 5 @ 24 X 12	
(K)	OA HOOD TYPICAL OF 2	
(L)	OA DAMPER : OPPOSED BLADES MAKE : T.A. Morrison 1000 SIZE : 75 X 45	
(M)	EA LV DAMPER : PARALLEL BLADES MAKE : T.A. Morrison 1000 SIZE : 80 X 42	
(N)	LOUVRE Std Louvre SIZE : 80 X 42	
UNIT MOUNTING The unit is designed to be mounted on a roof curb.		

SDG VER: Jun 20 2014


0 24 48 72 96

PROJECT

MBG - TORONTO TRANSIT CENTER

OPENINGS AND DIMENSIONS MAY VARY
FROM CONTRACT DOCUMENTS. RETURN
OF APPROVED DRAWINGS CONSTITUTES
ACCEPTANCE OF THESE VARIANCES.

JOB NO.	49446	DRAWN BY	TN	DWG NO.	49446U39SD01	ACCESS SIDE	RIGHT	DWG UNITS	IN	SALES OFFICE	TRAN. VANCOUVER
TAG	AHU-27	DATE	JUN 26/14	TYPE	OUTDOOR	10:00		SCALE	N.T.S.	SALES ENGINEER	IVAN HOLD



Note : Calculated unit weights are shipping weights and do not reflect operating conditions, items which are field installed or ship loose.

(A)	LOUVRE Std Louvre	SIZE : 22 X 22
(B)	LOUVRE Std Louvre	SIZE : 14 X 14
(C)	GAS FIRED FURNACE, 20:1 TURNDOWN MAKE : HC MODEL : HE 1750 FUEL PRESSURE: 0.500 psi INPUT : 2250 MBH OUTPUT : 1800 MBH	
(D)	FILTERS : LIFT-OUT UPSTREAM VELOCITY : 447 FPM TYPE : 2" (MERV 8) Farr 30/30 SIZES : 5 @ 24 X 12 6 @ 24 X 24	
(E)	FAN : (RF) 27" EPF SW, Arrangement-3 AIR FLOW : 15200 CFM RPM : 1691 T.S.P. : 3.5 in wc CLASS : II MOTOR : 20 HP, ODP Prem-Eff, 460/3/60 RPM : 1750 (GROUNDED SHAFT) ISOLATORS : OS DEF : 2 in FEG75 η_{pt} : 73% η_t / η_{pt} : 93%	
(F)	FAN : (SF) 24" BAE DW, Arrangement-3 AIR FLOW : 15200 CFM RPM : 1508 T.S.P. : 3.75 in wc CLASS : II MOTOR : 15 HP, ODP Prem-Eff, 460/3/60 RPM : 1750 (GROUNDED SHAFT) ISOLATORS : OS DEF : 2 in FEG85 η_{pt} : 82% η_t / η_{pt} : 98%	
(G)	DRAIN PAN	
(H)	HEAT PIPE TYPE : Heat Pipe Technology, 6 ROW SIZES : 2 @ 30 X 146	
(I)	OA BYPASS DAMPER : OPPOSED BLADES MAKE : T.A. Morrison 1000 SIZE : 49 X 30	
(J)	FILTERS : LIFT-OUT UPSTREAM VELOCITY : 475 FPM TYPE : 2" (MERV 8) Farr 30/30 SIZES : 8 @ 24 X 24	
(K)	OA HOOD TYPICAL OF 2	
(L)	OA DAMPER : OPPOSED BLADES MAKE : T.A. Morrison 1000 SIZE : 72 X 44	
(M)	EA LV DAMPER : PARALLEL BLADES MAKE : T.A. Morrison 1000 SIZE : 80 X 42	
(N)	LOUVRE Std Louvre SIZE : 80 X 42	
	UNIT MOUNTING The unit is designed to be mounted on a roof curb.	

SDG VER: Jun 20 2014


0 24 48 72 96

PROJECT

MBG - TORONTO TRANSIT CENTER

OPENINGS AND DIMENSIONS MAY VARY
FROM CONTRACT DOCUMENTS. RETURN
OF APPROVED DRAWINGS CONSTITUTES
ACCEPTANCE OF THESE VARIANCES.

JOB NO.	49446	DRAWN BY	TN	DWG NO.	49446U40SD01	ACCESS SIDE	RIGHT	DWG UNITS	IN	SALES OFFICE	TRANSPORT VANCOUVER
TAG	AHU-28	DATE	JUN 26/14	TYPE	OUTDOOR	10:00		SCALE	N.T.S.	SALES ENGINEER	IVAN HOLDY




PROJECT

MBG - TORONTO TRANSIT CENTER

OPENINGS AND DIMENSIONS MAY VARY
FROM CONTRACT DOCUMENTS. RETURN
OF APPROVED DRAWINGS CONSTITUTES
ACCEPTANCE OF THESE VARIANCES.

JOB NO.	49446	DRAWN BY	TN	DWG NO.	49446U41SD01	ACCESS SIDE	RIGHT	DWG UNITS	IN	SALES OFFICE	TRAN. VANCOUVER
TAG	AHU-29,30	DATE	JUN 26/14	TYPE	OUTDOOR	10:00		SCALE	N.T.S.	SALES ENGINEER	IVAN HOLD



Note : Calculated unit weights are shipping weights and do not reflect operating conditions, items which are field installed or ship loose.

(A)	LOUVRE Std Louvre	SIZE : 22 X 22
(B)	LOUVRE Std Louvre	SIZE : 14 X 14
(C)	GAS FIRED FURNACE, 20:1 TURNDOWN MAKE : HC MODEL : HE 1750 FUEL PRESSURE: 0.500 psi INPUT : 2250 MBH OUTPUT : 1800 MBH	
(D)	FILTERS : LIFT-OUT UPSTREAM VELOCITY : 478 FPM TYPE : 2" (MERV 8) Farr 30/30 SIZES : 9 @ 24 X 24	
(E)	FAN : (RF) 30" EPF SW, Arrangement-3 AIR FLOW : 17200 CFM RPM : 1442 T.S.P. : 3.5 in wc CLASS : II MOTOR : 20 HP, ODP Prem-Eff, 460/3/60 RPM : 1750 (GROUNDED SHAFT) ISOLATORS : OS DEF : 2 in FEG80 η_{pt} : 74% η_t / η_{pt} : 96%	
(F)	FAN : (SF) 27" BAE DW, Arrangement-3 AIR FLOW : 17200 CFM RPM : 1342 T.S.P. : 3.75 in wc CLASS : II MOTOR : 15 HP, ODP Prem-Eff, 460/3/60 RPM : 1750 (GROUNDED SHAFT) ISOLATORS : OS DEF : 2 in FEG90 η_{pt} : 85% η_t / η_{pt} : 98%	
(G)	DRAIN PAN	
(H)	HEAT PIPE TYPE : Heat Pipe Technology, 6 ROW SIZES : 2 @ 33.75 X 152	
(I)	OA BYPASS DAMPER : OPPOSED BLADES MAKE : T.A. Morrison 1000 SIZE : 56 X 30	
(J)	FILTERS : LIFT-OUT UPSTREAM VELOCITY : 358 FPM TYPE : 2" (MERV 8) Farr 30/30 SIZES : 12 @ 24 X 24	
(K)	OA HOOD TYPICAL OF 2	
(L)	OA DAMPER : OPPOSED BLADES MAKE : T.A. Morrison 1000 SIZE : 73 X 49	
(M)	EA LV DAMPER : PARALLEL BLADES MAKE : T.A. Morrison 1000 SIZE : 80 X 46	
(N)	LOUVRE Std Louvre SIZE : 80 X 46	
UNIT MOUNTING The unit is designed to be mounted on a roof curb.		

SDG VER: Jun 20 2014


0 24 48 72 96

PROJECT

MBG - TORONTO TRANSIT CENTER

OPENINGS AND DIMENSIONS MAY VARY
FROM CONTRACT DOCUMENTS. RETURN
OF APPROVED DRAWINGS CONSTITUTES
ACCEPTANCE OF THESE VARIANCES.

JOB NO.	49446	DRAWN BY	TN	DWG NO.	49446U42SD01	ACCESS SIDE	RIGHT	DWG UNITS	IN	SALES OFFICE	TRANSPORT VANCOUVER
TAG	AHU-31	DATE	JUN 26/14	TYPE	OUTDOOR	10:00		SCALE	N.T.S.	SALES ENGINEER	IVAN HOLDY



Note : Calculated unit weights are shipping weights and do not reflect operating conditions, items which are field installed or ship loose.

(A)	LOUVRE Std Louvre	SIZE : 22 X 22
(B)	LOUVRE Std Louvre	SIZE : 14 X 14
(C)	GAS FIRED FURNACE, 20:1 TURNDOWN MAKE : HC MODEL : HE 1000 FUEL PRESSURE: 0.500 psi INPUT : 1250 MBH OUTPUT : 1000 MBH	
(D)	FILTERS : LIFT-OUT UPSTREAM VELOCITY : 410 FPM TYPE : 2" (MERV 8) Farr 30/30 SIZES : 2 @ 24 X 12 4 @ 24 X 24	
(E)	FAN : (RF) 20" EPF SW, Arrangement-3 AIR FLOW : 8200 CFM RPM : 2282 T.S.P. : 3.5 in wc CLASS : II MOTOR : 10 HP, ODP Prem-Eff, 460/3/60 RPM : 1750 (GROUNDED SHAFT) ISOLATORS : OS DEF : 2 in FEG75 η_{pt} : 70% η_t / η_{pt} : 93%	
(F)	FAN : (SF) 18" BAE DW, Arrangement-3 AIR FLOW : 8200 CFM RPM : 2007 T.S.P. : 3.75 in wc CLASS : II MOTOR : 10 HP, ODP Prem-Eff, 460/3/60 RPM : 1750 (GROUNDED SHAFT) ISOLATORS : OS DEF : 2 in FEG90 η_{pt} : 80% η_t / η_{pt} : 97%	
(G)	DRAIN PAN	
(H)	HEAT PIPE TYPE : Heat Pipe Technology, 6 ROW SIZES : 1 @ 50 X 96	
(I)	OA BYPASS DAMPER : OPPOSED BLADES MAKE : T.A. Morrison 1000 SIZE : 40 X 20	
(J)	FILTERS : LIFT-OUT UPSTREAM VELOCITY : 410 FPM TYPE : 2" (MERV 8) Farr 30/30 SIZES : 4 @ 24 X 24 2 @ 24 X 12	
(K)	OA HOOD	
(L)	OA DAMPER : OPPOSED BLADES MAKE : T.A. Morrison 1000 SIZE : 50 X 34	
(M)	EA LV DAMPER : PARALLEL BLADES MAKE : T.A. Morrison 1000 SIZE : 80 X 22	
(N)	LOUVRE Std Louvre	SIZE : 80 X 22
UNIT MOUNTING The unit is designed to be mounted on a roof curb.		



SDG VER: Jun 20 2014

PROJECT

MBG - TORONTO TRANSIT CENTER

OPENINGS AND DIMENSIONS MAY VARY
FROM CONTRACT DOCUMENTS. RETURN
OF APPROVED DRAWINGS CONSTITUTES
ACCEPTANCE OF THESE VARIANCES.

JOB NO.	49446	DRAWN BY	TN	DWG NO.	49446U43SD01	ACCESS SIDE	RIGHT	DWG UNITS	IN	SALES OFFICE	TRANE VANCOUVER
TAG	AHU-32	DATE	JUN 26/14	TYPE	OUTDOOR	10:00		SCALE	N.T.S.	SALES ENGINEER	IVAN HOLD



0 24 48 72 96


PROJECT

MBG - TORONTO TRANSIT CENTER

JOB NO.	49446	DRAWN BY	TN	DWG NO.	49446U44SD01	ACCESS SIDE	RIGHT	DWG UNITS	IN	SALES OFFICE	TRANE VANCOUVER
TAG	AHU-33	DATE	JUN 26/14	TYPE	OUTDOOR	10:00		SCALE	N.T.S.	SALES ENGINEER	IVAN HOLD

OPENINGS AND DIMENSIONS MAY VARY
FROM CONTRACT DOCUMENTS. RETURN
OF APPROVED DRAWINGS CONSTITUTES
ACCEPTANCE OF THESE VARIANCES.

SDG VER: Jun 20 2014



- A** GAS FIRED FURNACE, 5:1 TURNDOWN
MAKE : Heatco HM MODEL : HMA 500
FUEL PRESSURE: 0.500 psi
INPUT : 500 MBH OUTPUT : 400 MBH
- B** FILTERS : LIFT-OUT UPSTREAM
VELOCITY : 469 FPM
TYPE : 2" (MERV 8) Farr 30/30
SIZES : 4 @ 24 X 24
- C** FAN : (RF) 22" EPF SW,
Arrangement-3
AIR FLOW : 7500 CFM RPM : 1709
T.S.P. : 3.5 in wc CLASS : II
MOTOR : 7.5 HP, ODP Prem-Eff, 460/3/60
RPM : 1750 (GROUNDED SHAFT)
ISOLATORS : OS DEF : 2 in
FEG75 η_{pt} : 73% η_t / η_{pt} : 99%
- D** FAN : (SF) 18" BAE DW,
Arrangement-3
AIR FLOW : 7500 CFM RPM : 1935
T.S.P. : 3.75 in wc CLASS : II
MOTOR : 7.5 HP, ODP Prem-Eff, 460/3/60
RPM : 1750 (GROUNDED SHAFT)
ISOLATORS : OS DEF : 2 in
FEG90 η_{pt} : 80% η_t / η_{pt} : 99%
- E** DRAIN PAN
- F** HEAT PIPE
TYPE : Heat Pipe Technology, 6 ROW
SIZES : 1 @ 45 X 96
- G** OA BYPASS DAMPER : OPPOSED BLADES
MAKE : T.A. Morrison 1000
SIZE : 45 X 16
- H** FILTERS : LIFT-OUT UPSTREAM
VELOCITY : 469 FPM
TYPE : 2" (MERV 8) Farr 30/30
SIZES : 4 @ 24 X 24
- I** OA HOOD
- J** OA DAMPER : OPPOSED BLADES
MAKE : T.A. Morrison 1000
SIZE : 45 X 35
- K** EA LV DAMPER : PARALLEL BLADES
MAKE : T.A. Morrison 1000
SIZE : 80 X 22
- L** LOUVRE SIZE : 80 X 22
Std Louvre
- UNIT MOUNTING**
The unit is designed to be mounted on a roof curb.
- Note : Calculated unit weights are shipping weights and do not reflect operating conditions, items which are field installed or ship loose.

0 24 48 72 96


SDG VER: Jun 20 2014


PROJECT

MBG - TORONTO TRANSIT CENTER

OPENINGS AND DIMENSIONS MAY VARY
FROM CONTRACT DOCUMENTS. RETURN
OF APPROVED DRAWINGS CONSTITUTES
ACCEPTANCE OF THESE VARIANCES.

JOB NO.	49446	DRAWN BY	TN	DWG NO.	49446U45SD01	ACCESS SIDE	RIGHT	DWG UNITS	IN	SALES OFFICE	TRANE VANCOUVER
TAG	AHU-34	DATE	JUN 26/14	TYPE	OUTDOOR	10:00		SCALE	N.T.S.	SALES ENGINEER	IVAN HOLD





REVISIONS	REVISIONS

SCOPE REVIEW
DRAWING
NOT FOR CONSTRUCTION

SCALE(S)


0 2 4 6 8 10
15m



DESIGNED V. JOHN 20140515
DRAWN S. CHENG 20140515
CHECKED P. MARSH 20140515
APPROVED _____

McNICOLL BUS GARAGE
H.V.A.C
GROUND FLOOR PLAN
OVERALL

Print Date: 08-24-2014
Doc. No.: GBS-314-M500
Sheet No.: 1



FOR CONTINUATION SEE DIVISION
MATCHLINE
M504



MATCHLINE
M501

This detailed HVAC system plan for the Ground Floor South East area includes the following key components and labels:

- Ductwork:** Various duct sizes and types are shown, including 350mm SIA ducts, 400mm SIA ducts, 600x600x500 vehicle exhaust plenums, and 1000x800 exhaust air ducts.
- Equipment:** Components like AC-D-4, BB-8, BB-10, BB-26, BB-28, BB-30, and BB-32 are labeled.
- Structural Labels:** Levels E, F, G, H, and columns 1 through 18 are indicated.
- Annotations:** Numerous callouts provide specific details for certain sections, such as "350MMØ S/A DUCT DN THEN TRANSITION TO 350x150MM DN TO 300MM AFF (TYP.)" and "600x600 EXHAUST AIR UP (TYP., OF 2)".
- Legend:** A legend on the right side defines symbols for various duct types and sizes.

1 HVAC - GROUND FLOOR PLAN - SOUTH EAST


M503 1:200

REVISIONS	REVISIONS
GRB-314-M-1	
DRAWING No.	
1	
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	
25	
26	
27	
28	
29	
30	
31	
32	
33	
34	
35	
36	
37	
38	
39	
40	
41	
42	
43	
44	
45	
46	
47	
48	
49	
50	
51	
52	
53	
54	
55	
56	
57	
58	
59	
60	
61	
62	
63	
64	
65	
66	
67	
68	
69	
70	
71	
72	
73	
74	
75	
76	
77	
78	
79	
80	
81	
82	
83	
84	
85	
86	
87	
88	
89	
90	
91	
92	
93	
94	
95	
96	
97	
98	
99	
100	
101	
102	
103	
104	
105	
106	
107	
108	
109	
110	
111	
112	
113	
114	
115	
116	
117	
118	
119	
120	
121	
122	
123	
124	
125	
126	
127	
128	
129	
130	
131	
132	
133	
134	
135	
136	
137	
138	
139	
140	
141	
142	
143	
144	
145	
146	
147	
148	
149	
150	
151	
152	
153	
154	
155	
156	
157	
158	
159	
160	
161	
162	
163	
164	
165	
166	
167	
168	
169	
170	
171	
172	
173	
174	
175	
176	
177	
178	
179	
180	
181	
182	
183	
184	
185	
186	
187	
188	
189	
190	
191	
192	
193	
194	
195	
196	
197	
198	
199	
200	

**SCOPE REVIEW
DRAWING**



McNICOLL BUS GARAGE
H.V.A.C
GROUND FLOOR PLAN
SOUTH EAST



1
M504 1200
HVAC - GROUND FLOOR PLAN - SOUTH WEST

DRAWING No. GBS-314-M504

BLDG. REF. No.

FILE: STN_811\wph_01.dwg

SHEET No.

SCOPE REVIEW
DRAWING
NOT FOR CONSTRUCTION


Stantec HDR


SCALE(S) 0 1 2 3 4 5 6m

DESIGNED V. JOHN 20140515
DRAWN S. CHENG 20140515
CHECKED P. MARSH 20140515
APPROVED _____

McNICOLL BUS GARAGE
H.V.A.C
GROUND FLOOR PLAN
SOUTH WEST

Print Date: 08-24-2014
Doc. No.: GBS-314-M504
Sheet No.: 1





1 HVAC - GROUND FLOOR PLAN - ENLARGE OFFICE
M505 1:150

FILE: STN-811\w-dwg-01.dwg.dgn

SHEET No.

DRAWING No.: G65-314-M505

BLDG. REF. No.

REVISIONS	REVISIONS

SCOPE REVIEW
DRAWING
NOT FOR CONSTRUCTION

Stantec HDR


SCALE(S) 0 1 2 3 4 5 6ft

DESIGNED V. JOHN 20140615
DRAWN S. CHENG 20140615
CHECKED P. MARSH 20140615
APPROVED _____

McNICOLL BUS GARAGE
H.V.A.C
GROUND FLOOR PLAN
OFFICE ENLARGE

Print Date: 08-24-2014

Doc. No. G65-314-M505 Sheet No. _____



DRAWING No.	REVIEWS	REVIEWS
G85-314-M506		

SCOPE REVIEW
DRAWING
NOT FOR CONSTRUCTION



SCALE(S)

0 2 4 6 8 10 15m

McNICOLL BUS GARAGE
H.V.A.C.
SECOND FLOOR PLAN
OVERALL

DESIGNED

V. JOSH

20140615

DRAWN

S. CHENG

20140615

CHECKED


P. MARSH

20140615

APPROVED


Print Date: 08-25-2014
Doc. No. G85-314-M506
Sheet No. 1

FOR CONTINUATION SEE DW
MATCHLINE
M508



The diagram shows a rectangular room with several internal divisions. At the top left, a small room is labeled 'OFFICE'. To its right is a larger room labeled 'STORAGE'. Below the 'STORAGE' room is a smaller room labeled 'SERVICE'. A large, irregularly shaped area to the right of the 'STORAGE' room is filled with diagonal hatching. The entire diagram is enclosed within a dashed rectangular border.

DRAWING No. GBS-314-M507 | Page No. 1 of 1 | Sheet No. G85-314-M507




REVISIONS	REVISIONS
SCOPE REVIEW DRAWING NOT FOR CONSTRUCTION	

Stantec HDR

SCALE(S) 0 1 2 3 4 5 6"


McNICOLL BUS GARAGE
H.V.A.C.
SECOND FLOOR PLAN
NORTH WEST

Drawn: 08-24-2014
Approved: _____
Sheet No.: G65-314-M508

HVAC - SECOND FLOOR PLAN - SOUTH EAST
M509 1:200

DRAWING No. G85-314-M509

REVISIONS	REVISIONS	SCOPE REVIEW DRAWING NOT FOR CONSTRUCTION	Stantec HDR	McNICOLL BUS GARAGE H.V.A.C. SECOND FLOOR PLAN SOUTH EAST	File Date: 08-24-2014 Doc. No. G85-314-M509
		SCALE(S) 0 1 2 3 4 5 6 7 8 9m		DESIGNED V. JOHN 28140815 DRAWN S. CHENG 28140815 CHECKED P. MARSH 28140815 APPROVED _____	

HVAC - SECOND FLOOR PLAN - SOUTH WEST
M510 1:200

DRAWING No. G65-314-M510

BLDG. REF. No.

FILE: STN-811\mgh-02.dwg.dgn

SHEET No.

REVISIONS

REVISIONS

SCOPE REVIEW
DRAWING
NOT FOR CONSTRUCTION

Stantec HDR


SCALE(S) 0 1 2 3 4 5 6m

DESIGNED V. JOHN 2014/05/15
DRAWN S. CHENG 2014/05/15
CHECKED P. MARSH 2014/05/15
APPROVED _____McNICOLL BUS GARAGE
H.V.A.C.
SECOND FLOOR PLAN
SOUTH WESTRev Date: 08-25-2014
DWG No.: G65-314-M510
Sheet No.: 1

FILE: STN_811\mwh_02_Ind.dwg
SHEET No. 1
BLDG. REF. No.
DRAWING No. G85-314-M511

HVAC - SECOND FLOOR PLAN - OFFICE ENLARGE

12150



**SCOPE REVIEW
DRAWING**
NOT FOR CONSTRUCTION


Stantec **HDR**

SCALE(S) 0 1 2 3 4 5 6m

DESIGNED V. JOSH 20140515
DRAWN S. CHENG 20140515
CHECKED P. MARSH 20140515
APPROVED _____

McNICOLL BUS GARAGE
H.V.A.C
SECOND FLOOR PLAN
OFFICE ENLARGE

Rev Date: 08-24-2014
JFC
Doc. No. G85-314-M511 Sheet No.



DRAWING No.: G85-314-M512

REVISIONS	REVISIONS

SCOPE REVIEW
DRAWING
NOT FOR CONSTRUCTION


SCALE(S)


0 2 4 6 10
15m

Stantec HDR


McNICOLL BUS GARAGE
H.V.A.C.
ROOF PLAN
OVERALL

Rev Date: 08-27-2014
Doc. No.: G85-314-M512
Sheet No.: 1





1 HVAC - ROOF PLAN - NORTH WEST
M514 1200



DRAWING No. G85-314-M514

FILE: STLN_811\w\g\h\05\w.dwg

SHEET No.

BLDG. REF. No.

REVISIONS	REVISIONS

SCOPE REVIEW
DRAWING
NOT FOR CONSTRUCTION

Stantec HDR

SCALE(S)
0 1 2 3 4 5 6"

DESIGNED V. JOHN 20140615
DRAWN S. CHENG 20140615
CHECKED P. MARSH 20140615
APPROVED _____

McNICOLL BUS GARAGE
H.V.A.C.
ROOF PLAN
NORTH WEST

Print Date: 08-27-2014
Doc. No.: G85-314-M514
Sheet No.: 1

E


F

BLOG. REF. NO.

FILE: STN_818_hv_ph_03_se.dgn

SHEET N.

DRAWING No. G85-314-M515



1 HVAC - ROOF PLAN - SOUTH EAST
M615 1:200



REVISIONS	REVISIONS	
<input type="checkbox"/>	<input type="checkbox"/>	
<input type="checkbox"/>	<input type="checkbox"/>	
<input type="checkbox"/>	<input type="checkbox"/>	SCA


**SCOPE REVIEW
DRAWING**

SCALE(S) 0 1 2 3 4 5 6

DESIGNED V. JOSEPH
DRAWN S. CHUNG
CHECKED P. MARSH
APPROVED

McNICOLL BUS GARAGE

**H.V.A.C
ROOF PLAN
SOUTH EAST**



1 HVAC - ROOF PLAN - SOUTH WEST
M516 1200

DRAWING No. GBS-314-M516

REVISIONS	REVISIONS

SCOPE REVIEW
DRAWING
NOT FOR CONSTRUCTION




SCALE(S) 0 1 2 3 4 5 6m


DESIGNED V. JOHN 20140515
DRAWN S. CHENG 20140515
CHECKED P. MARSH 20140515
APPROVED _____


McNICOLL BUS GARAGE
H.V.A.C.
ROOF PLAN
SOUTH WEST

Rev Date: 08-24-2014

Doc. No. GBS-314-M516 Sheet No. _____







BLDG. Ref. No.

FILE: STN-811-114-02-02.dwg

SHEET No.

DRAWING No.: G85-314-M521

REVISIONS	REVISIONS

SCOPE REVIEW DRAWING
NOT FOR CONSTRUCTION

 DESIGNED V. JOHN 20140615
 DRAWN S. CHENG 20140615
 CHECKED P. MARSH 20140615
 APPROVED _____

 McNICOLL BUS GARAGE
H.V.A.C DETAILS
 Sheet 2 of 6

 Rev Date: 08-24-2014

 Doc. No.: G85-314-M521
 Sheet No.

17 RETURN/EXHAUST GRILLE WITH PLENUM

18 ACCESS TO FIRE DAMPER (ROUND DUCT TO 300MM [12"] ONLY)

19 BOILER VENT THROUGH ROOF

20 FAN/DUCT FLEXIBLE CONNECTION

21 GRILLE MOUNTED ON EXPOSED RECTANGULAR DUCT

22 SCOPE REVIEW DRAWING
NOT FOR CONSTRUCTION

23 DUCT PENETRATING ROOF DETAIL

24 DUCT PENETRATING ROOF DETAIL

REVISIONS **REVISIONS**

SCOPE REVIEW DRAWING
NOT FOR CONSTRUCTION

Stantec HDR

McNICOLL BUS GARAGE
H.V.A.C DETAILS

Sheet 3 of 6









File: STN_811\wdec\03.dwg
Sheet No.: G65-314-M522
Drawing No.: G65-314-M522
Bldg. Ref. No.:
FILE: STN_811\wdec\03.dwg
SHEET NO.: G65-314-M522
DRAWING NO.: G65-314-M522
REV: 08-24-2014
DESIGNED BY: V. JOHN DATE: 2014/08/15
DRAWN BY: S. CHENG DATE: 2014/08/15
CHECKED BY: P. MARSH DATE: 2014/08/15
APPROVED BY: _____

DRAWING No. G85-314-M523 SHEET No. 818 Inv. del. Dugign FILE: STN_818Inv_dugign BLDG. REF. No.

FILE: STN_818_hv_dcl_04.dgn

SHEET No.

DRAWING No. G85-314-M523








REVISIONS	REVISIONS

**SCOPE REVIEW
DRAWING**



McNICOLL BUS GARAGE H.V.A.C DETAILS	Plot Date 08-24-2014 
Sheet 4 of 6	Doc No. G85-314-M523 Sheet No.

DRAWING No. G85-314-M524 SHEET No. FILE: STN 87s Inv. 05-dgn BLDG. REF. No.



REVISIONS	REVISIONS

**SCOPE REVIEW
DRAWING**




DESIGNED V. JOHN
DRAWN S. CHUNG
CHECKED P. MARSH

McNICOLL BUS GARAGE

**H.V.A.C
DETAILS**

Plot Date: 08-24-2014

Dwg. No. G85-314-M524 Sheet No.



BLDG. REF. No.

FILE: STN-811-HVAC-DESIGN

SHEET No.

DRAWING No.: G65-314-NS2

REVISIONS	REVISIONS

SCOPE REVIEW
DRAWING
NOT FOR CONSTRUCTION

Stantec HDR


DESIGNED BY: V. JOHN 2014/05/15
DRAWN BY: S. CHENG 2014/05/15
CHECKED BY: P. MARSH 2014/05/15
APPROVED BY:
File Date: 08-24-2014

McNICOLL BUS GARAGE


H.V.A.C
DETAILS

Sheet 6 of 6


Doc. No.: G65-314-M525
Sheet No.:



SECTION
M530 1:200



SECTION
M530 1:200



SECTION
M530 1:200

BLDG. REF. No.

FILE: STNL_811\sec_01.dwg

SHEET No.

DRAWING No.: GBS-314-M530

REVISIONS	REVISIONS

SCOPE REVIEW
DRAWING
NOT FOR CONSTRUCTION





DESIGNED V. JOSH 20140515
DRAWN S. CHUNG 20140515
CHECKED P. MARSH 20140515
APPROVED _____

McNICOLL BUS GARAGE
H.V.A.C
SECTIONS
Sheet 1 of 2

Print Date: 08-24-2014

Doc. No. GBS-314-M530 Sheet No.






BLDG. REF. No.

FILE: STN-811-114-0500-C1.dwg

SHEET No.

DRAWING No.: G65-314-M550



REVISIONS	REVISIONS

**SCOPE REVIEW
DRAWING**
NOT FOR CONSTRUCTION




DESIGNED V. JOHN 2014/06/15
DRAWN S. CHENG 2014/06/15
CHECKED P. MARSH 2014/06/15
APPROVED _____


McNICOLL BUS GARAGE
**H.V.A.C
AIR SCHEMATICS**

Rev Date: 08-24-2014

Doc. No.: G65-314-M550
Sheet No.: _____



1 AIR SCHEMATIC
M551


REVISIONS G85-314-M551	REVISIONS	SCOPE REVIEW DRAWING NOT FOR CONSTRUCTION					DESIGNED <u>V. JOHN</u> 25/14/05/15 DRAWN <u>S. CHUNG</u> 25/14/05/15 CHECKED <u>P. MARSH</u> 25/14/06/13 APPROVED _____	McNICOLL BUS GARAGE H.V.A.C AIR SCHEMATICS	Plot Date 08-24-2014  Drawn By G85-314-M551 Sheet N
DRAWING NO.	SCALE(S)								

BLDG. REF. No.

FILE: STNL_811\17\450\03.dwg

SHEET No.

DRAWING No.: GBS-314-M552



1
M552
AIR SCHEMATIC

McNICOLL BUS GARAGE
H.V.A.C
AIR SCHEMATICS

Rev Date: 08-24-2014
Doc. No.: GBS-314-M552
Sheet No.:




SCOPE REVIEW
DRAWING
NOT FOR CONSTRUCTION

DESIGNED V. JOHN 2014/06/15
DRAWN S. CHENG 2014/06/15
CHECKED P. MARSH 2014/06/15
APPROVED _____

SCALE(S)

REVISIONS

REVISIONS



OFFICE AREA HYDRONIC HEATING SCHEMATIC
M553

REVISIONS	REVISIONS	SCOPE REVIEW DRAWING NOT FOR CONSTRUCTION	Stantec HDR			McNICOLL BUS GARAGE H.V.A.C HYDRONIC HEATING SCHEMATICS	Date: 08-24-2014 Doc. No. G85-314-M553 Sheet No.
DRAWING No. G85-314-M553	SCALE(S)						

This page intentionally left blank
for 2-sided printing purposes

Appendix C

This page intentionally left blank
for 2-sided printing purposes

Table C.1: Detailed Noise Source Data

TTC McNicoll Bus Garage, Toronto, Ontario

Source ID	Source Description	Recommended Noise Control Measures	Source Sound Power Level Data 1/1 Octave Bands (dB)								PWL (dBA)	Source Location Information				Modelled Source Operations Minutes per Hour		
			63 Hz	125 Hz	250 Hz	500 Hz	1000 Hz	2000 Hz	4000 Hz	8000 Hz		X (m)	Y (m)	Z (m)	Source Height H (m) + Notes	Day	3am	6am
AHU1_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	84	81	89	87	83	75	71	68	88	17636802.7	4852572.0	15.0	4.0 m Above Roof	15	60	15
AHU1_OA	Air-Handling Unit - Outdoor Air Inlet	Relocate, remove, or silence north/west solar collector intakes	76	83	85	88	78	75	70	65	87	17636811.2	4852559.9	10.0	10.0 m Relative to Ground	15	60	15
AHU2_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	84	81	89	87	83	75	71	68	88	17636824.6	4852579.7	15.0	4.0 m Above Roof	15	60	15
AHU2_OA	Air-Handling Unit - Outdoor Air Inlet	Relocate, remove, or silence north/west solar collector intakes	76	83	85	88	78	75	70	65	87	17636833.2	4852567.7	10.0	10.0 m Relative to Ground	15	60	15
AHU3_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	84	81	89	87	83	75	71	68	88	17636846.7	4852587.5	15.0	4.0 m Above Roof	15	60	15
AHU3_OA	Air-Handling Unit - Outdoor Air Inlet	Relocate, remove, or silence north/west solar collector intakes	76	83	85	88	78	75	70	65	87	17636855.2	4852575.4	10.0	10.0 m Relative to Ground	15	60	15
AHU4_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	85	79	92	92	84	80	73	64	91	17636868.9	4852595.4	15.0	4.0 m Above Roof	15	60	15
AHU4_OA	Air-Handling Unit - Outdoor Air Inlet	Relocate, remove, or silence north/west solar collector intakes	72	86	85	86	75	71	66	63	85	17636886.3	4852591.6	10.0	10.0 m Relative to Ground	15	60	15
AHU5_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	84	81	89	87	83	75	71	68	88	17636793.1	4852599.5	15.0	4.0 m Above Roof	15	60	15
AHU5_OA	Air-Handling Unit - Outdoor Air Inlet	Relocate, remove, or silence north/west solar collector intakes	67	78	80	87	78	75	70	65	86	17636783.9	4852589.5	10.0	10.0 m Relative to Ground	15	60	15
AHU6_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	93	88	94	91	81	78	73	67	91	17636815.1	4852607.0	15.0	4.0 m Above Roof	15	60	15
AHU6_OA	Air-Handling Unit - Outdoor Air Inlet	Rotate such that louvres are north and/or east	93	88	94	91	81	78	73	67	91	17636818.7	4852607.1	12.0	12.0 m Relative to Ground	15	60	15
AHU7_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	84	81	89	87	83	75	71	68	88	17636837.1	4852615.1	15.0	4.0 m Above Roof	15	60	15
AHU7_OA	Air-Handling Unit - Outdoor Air Inlet	Rotate such that louvres are north and/or east	93	88	94	91	81	78	73	67	91	17636840.7	4852615.0	12.0	12.0 m Relative to Ground	15	60	15
AHU8_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	85	79	92	92	84	80	73	64	91	17636859.0	4852623.5	15.0	4.0 m Above Roof	15	60	15
AHU8_OA	Air-Handling Unit - Outdoor Air Inlet	Rotate such that louvres are north and/or east	89	91	94	89	78	74	69	65	89	17636862.2	4852623.4	12.0	12.0 m Relative to Ground	15	60	15
AHU9_OA	Air-Handling Unit - Outdoor Air Inlet	Relocate, remove, or silence north/west solar collector intakes	67	78	80	87	78	75	70	65	86	17636773.6	4852618.5	10.0	10.0 m Relative to Ground	15	60	15
AHU10_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	84	81	89	87	83	75	71	68	88	17636804.7	4852636.3	15.0	4.0 m Above Roof	15	60	15
AHU10_OA	Air-Handling Unit - Outdoor Air Inlet	Rotate such that louvres are north and/or east	93	88	94	91	81	78	73	67	91	17636808.0	4852636.2	12.0	12.0 m Relative to Ground	15	60	15
AHU11_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	84	81	89	87	83	75	71	68	88	17636826.8	4852644.1	15.0	4.0 m Above Roof	15	60	15
AHU11_OA	Air-Handling Unit - Outdoor Air Inlet	Rotate such that louvres are north and/or east	93	88	94	91	81	78	73	67	91	17636830.1	4852644.1	12.0	12.0 m Relative to Ground	15	60	15
AHU12_EA	Air-Handling Unit - Outdoor Air Inlet	Rotate such that louvres are north and/or east	85	79	92	92	84	80	73	64	91	17636852.3	4852652.7	12.0	12.0 m Relative to Ground	15	60	15
AHU12_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	85	79	92	92	84	80	73	64	91	17636848.6	4852652.9	15.0	4.0 m Above Roof	15	60	15
AHU13_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	84	81	89	87	83	75	71	68	88	17636772.5	4852657.8	15.0	4.0 m Above Roof	15	60	15
AHU13_OA	Air-Handling Unit - Outdoor Air Inlet	Relocate, remove, or silence north/west solar collector intakes	67	78	80	87	78	75	70	65	86	17636763.2	4852647.9	10.0	10.0 m Relative to Ground	15	60	15
AHU14_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	84	81	89	87	83	75	71	68	88	17636794.4	4852665.5	15.0	4.0 m Above Roof	15	60	15
AHU14_OA	Air-Handling Unit - Outdoor Air Inlet	Rotate such that louvres are north and/or east	93	88	94	91	81	78	73	67	91	17636797.4	4852665.3	12.0	12.0 m Relative to Ground	15	60	15
AHU15_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	84	81	89	87	83	75	71	68	88	17636816.5	4852673.3	15.0	4.0 m Above Roof	15	60	15
AHU15_OA	Air-Handling Unit - Outdoor Air Inlet	Rotate such that louvres are north and/or east	93	88	94	91	81	78	73	67	91	17636819.6	4852673.2	12.0	12.0 m Relative to Ground	15	60	15
AHU16_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	85	79	92	92	84	80	73	64	91	17636838.2	4852682.0	15.0	4.0 m Above Roof	15	60	15
AHU16_OA	Air-Handling Unit - Outdoor Air Inlet	Rotate such that louvres are north and/or east	89	91	94	89	78	74	69	65	89	17636841.8	4852681.9	12.0	12.0 m Relative to Ground	15	60	15
AHU17_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	85	80	92	95	86	81	75	66	94	17636760.5	4852695.9	15.0	4.0 m Above Roof	15	60	15
AHU17_OA	Air-Handling Unit - Outdoor Air Inlet	Relocate, remove, or silence north/west solar collector intakes	73	88	84	81	75	71	66	62	82	17636749.2	4852687.4	10.0	10.0 m Relative to Ground	15	60	15
AHU18_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	85	80	92	95	86	81	75	66	94	17636784.1	4852704.2	15.0	4.0 m Above Roof	15	60	15
AHU18_OA	Air-Handling Unit - Outdoor Air Inlet	Rotate such that louvres are north and/or east	90	93	93	84	78	74	69	64	87	17636784.4	4852699.9	12.0	12.0 m Relative to Ground	15	60	15
AHU19_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	85	80	92	95	86	81	75	66	94	17636811.5	4852713.9	15.0	4.0 m Above Roof	15	60	15
AHU19_OA	Air-Handling Unit - Outdoor Air Inlet	Rotate such that louvres are north and/or east	90	93	93	84	78	74	69	64	87	17636811.6	4852709.4	12.0	12.0 m Relative to Ground	15	60	15
AHU20_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	85	80	92	95	86	81	75	66	94	17636840.7	4852724.3	15.0	4.0 m Above Roof	15	60	15
AHU20_OA	Air-Handling Unit - Outdoor Air Inlet	Rotate such that louvres are north and/or east	90	93	93	84	78	74	69	64	87	17636840.9	4852719.7	12.0	12.0 m Relative to Ground	15	60	15
AHU21_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	85	75	88	88	84	80	74	67	89	17636871.2	4852654.8	15.0	4.0 m Above Roof	15	60	15
AHU21_OA	Air-Handling Unit - Outdoor Air Inlet	Rotate such that louvres are north and/or east	90	91	95	90	79	74	70	65	90	17636872.7	4852654.7	12.0	12.0 m Relative to Ground	15	60	15
AHU22_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	85	75	88	88	84	80	74	67	89	17636875.8	4852656.5	15.0	4.0 m Above Roof	15	60	15
AHU22_OA	Air-Handling Unit - Outdoor Air Inlet	Rotate such that louvres are north and/or east	90	91	95	90	79	74	70	65	90	17636879.1	4852658.9	12.0	12.0 m Relative to Ground	15	60	15
AHU23_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	89	87	88	85	83	77	70	64	87	17636856.0	4852696.5	15.0	4.0 m Above Roof	15	60	15
AHU23_OA	Air-Handling Unit - Outdoor Air Inlet	Rotate such that louvres are north and/or east	100	97	93	86	82	79	74	68	90	17636860.1	4852699.1	12.0	12.0 m Relative to Ground	15	60	15
AHU24_EA	Air-Handling Unit - Outdoor Air Inlet	Rotate such that louvres are north and/or east	92	97	97	88	82	78	73	67	91	17636825.8	4852806.1	12.0	12.0 m Relative to Ground	15	60	15
AHU25_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	83	81	89	86	81	73	69	66	87	17636809.1	4852791.2	15.0	4.0 m Above Roof	15	60	15
AHU25_OA	Air-Handling Unit - Outdoor Air Inlet	Rotate such that louvres are north and/or east	93	86	93	90	80	76	71	65	90	17636806.7	4852794.5	12.0	12.0 m Relative to Ground	15	60	15
AHU26_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	85	80	92	94	85	81	74	65	93	17636785.8	4852787.5	15.0	4.0 m Above Roof	15	60	15
AHU26_OA	Air-Handling Unit - Outdoor Air Inlet	Rotate such that louvres are north and/or east	90	92	92	83	77	74	68	63	87	17636788.4	4852784.1	12.0	12.0 m Relative to Ground	15	60	15
AHU27_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	86	80	87	87	86	78	73	68	89	17636785.5	4852777.8	15.0	4.0 m Above Roof	15	60	15
AHU27_OA	Air-Handling Unit - Outdoor Air Inlet	Rotate such that louvres are north and/or east	88	90	92	86	76	72	67	63	87	17636760.9	4852774.5	12.0	12.0 m Relative to Ground	15	60	15
AHU28_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	84	81	89	87	82	74	70	67	87	17636725.2	4852769.1	15.0	4.0 m Above Roof	15	60	15
AHU28_OA	Air-Handling Unit - Outdoor Air Inlet	Rotate such that louvres are north and/or east	93	88	94	91	81	78	73	67	91	17636721.3	4852769.6	12.0	12.0 m Relative to Ground	15	60	15
AHU29_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	84	79	93	92	84	80	73	64	92	17636760.3	4852750.8	15.0	4.0 m Above Roof	15	60	15
AHU29_OA	Air-Handling Unit - Outdoor Air Inlet	Rotate such that louvres are north and/or east	89	91	94	89	78	74	69	64	89	17636757.9	4852754.3	12.0	12.0 m Relative to Ground	15	60	15
AHU30_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	84	79	93	92	84	80	73	64	92	17636784.7	4852759.5	15.0	4.0 m Above Roof	15	60	15
AHU30_OA	Air-Handling Unit - Outdoor Air Inlet	Rotate such that louvres are north and/or east	89	91	94	89	78	74	69	64	89	17636782.4	4852762.9	12.0	12.0 m Relative to Ground	15	60	15
AHU31_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	84	79	93	92	84	79	72	63								

Source ID	Source Description	Recommended Noise Control Measures	Source Sound Power Level Data 1/1 Octave Bands (dB)								PWL (dBA)	Source Location Information				Modelled Source Operations Minutes per Hour		
			63 Hz	125 Hz	250 Hz	500 Hz	1000 Hz	2000 Hz	4000 Hz	8000 Hz		X (m)	Y (m)	Z (m)	Source Height H (m) + Notes	Day	3am	6am
			Hz	Hz	Hz	Hz	Hz	Hz	Hz	Hz								
AHU33_OA	Air-Handling Unit - Outdoor Air Inlet	Rotate such that louvres are north and/or east	86	78	87	85	83	81	75	69	88	17636811.0	4852741.1	12.0	12.0 m Relative to Ground	15	60	15
AHU34_EA	Air-Handling Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	77	71	80	80	75	71	67	63	81	17636814.9	4852746.9	15.0	4.0 m Above Roof	15	60	15
AHU34_OA	Air-Handling Unit - Outdoor Air Inlet	Rotate such that louvres are north and/or east	92	86	88	87	80	76	72	68	87	17636815.1	4852749.9	12.0	12.0 m Relative to Ground	15	60	15
AHU35_OA	Air-Handling Unit - Outdoor Air Inlet	Rotate such that louvres are north and/or east	71	66	74	74	70	66	62	60	75	17636773.4	4852742.0	12.0	12.0 m Relative to Ground	15	60	15
BD_repair_1	Bay Door - Repair Bay	Keep closed at night	90	88	86	87	90	90	86	86	95	17636727.4	4852744.7	2.0	2.0 m Relative to Ground	15	60	15
BD_repair_2	Bay Door - Repair Bay	Keep closed at night	90	88	86	87	90	90	86	86	95	17636727.3	4852747.3	2.0	2.0 m Relative to Ground	15	60	15
BD_repair_3	Bay Door - Repair Bay	Keep closed at night	90	88	86	87	90	90	86	86	95	17636718.4	4852756.1	2.0	2.0 m Relative to Ground	15	60	15
BD_repair_4	Bay Door - Repair Bay	Keep closed at night	90	88	86	87	90	90	86	86	95	17636715.4	4852765.8	2.0	2.0 m Relative to Ground	15	60	15
BD_repair_5	Bay Door - Repair Bay	Keep closed at night	104	98	97	96	95	93	90	86	100	17636847.2	4852788.8	2.0	2.0 m Relative to Ground	15	60	15
BD_storage_1	Bay Door - Storage Bay		101	95	94	93	92	90	87	83	97	17636808.5	4852558.9	2.0	2.0 m Relative to Ground	15	60	15
BD_storage_2	Bay Door - Storage Bay		101	95	94	93	92	90	87	83	97	17636829.8	4852566.5	2.0	2.0 m Relative to Ground	15	60	15
BD_storage_3	Bay Door - Storage Bay		101	95	94	93	92	90	87	83	97	17636851.5	4852574.1	2.0	2.0 m Relative to Ground	15	60	15
BD_storage_4	Bay Door - Storage Bay		101	95	94	93	92	90	87	83	97	17636875.8	4852582.7	2.0	2.0 m Relative to Ground	15	60	15
BD_wash	Bay Door - Wash Bay		95	92	88	87	86	89	85	85	94	17636883.3	4852628.3	2.0	2.0 m Relative to Ground	15	60	15
DX_AHU_1	Cooling Unit		99	95	91	89	88	85	82	79	93	17636767.1	4852719.2	12.0	1.0 m Above Roof	60	30	30
DX_AHU_2	Cooling Unit		98	94	90	88	86	83	81	77	91	17636763.3	4852726.0	12.0	1.0 m Above Roof	60	30	30
DX_AHU_3	Cooling Unit		98	94	90	88	86	83	81	77	91	17636747.0	4852719.9	12.0	1.0 m Above Roof	60	30	30
DX_AHU_4	Cooling Unit		99	95	91	89	88	85	82	79	93	17636774.4	4852734.7	12.0	1.0 m Above Roof	60	30	30
DX_AHU_5	Cooling Unit		99	95	91	89	88	85	82	79	93	17636747.9	4852728.0	12.0	1.0 m Above Roof	60	30	30
DX_AHU_6	Cooling Unit		100	96	92	90	89	86	83	80	94	17636777.0	4852721.6	12.0	1.0 m Above Roof	60	30	30
DX_AHU_7	Cooling Unit		98	94	90	88	86	83	81	77	91	17636882.3	4852668.1	7.6	1.0 m Above Roof	60	30	30
EFO1	Exhaust Fan - Outlet		101	97	92	89	82	79	77	74	90	17636770.4	4852783.5	14.5	3.5 m Above Roof	15	60	15
EFO1_cas	Exhaust Fan - Casing		101	97	87	79	67	59	55	49	84	17636770.0	4852784.4	12.0	1.0 m Above Roof	15	60	15
EFO2	Exhaust Fan - Outlet		101	97	92	89	82	79	77	74	90	17636797.5	4852793.3	14.5	3.5 m Above Roof	15	60	15
EFO2_cas	Exhaust Fan - Casing		101	97	87	79	67	59	55	49	84	17636797.2	4852794.1	12.0	1.0 m Above Roof	15	60	15
EFO4	Exhaust Fan - Outlet		101	97	92	89	82	79	77	74	90	17636806.7	4852760.8	14.5	3.5 m Above Roof	15	60	15
EFO4_cas	Exhaust Fan - Casing		101	97	87	79	67	59	55	49	84	17636807.4	4852761.1	12.0	1.0 m Above Roof	15	60	15
EFO5	Exhaust Fan - Outlet		99	95	90	87	80	77	75	72	88	17636779.2	4852751.2	14.5	3.5 m Above Roof	15	60	15
EFO5_cas	Exhaust Fan - Casing		99	95	85	77	65	57	53	47	82	17636780.0	4852751.4	12.0	1.0 m Above Roof	15	60	15
EFO6	Exhaust Fan - Outlet		104	100	95	92	85	82	80	77	93	17636833.8	4852784.9	18.5	7.5 m Above Roof	15	60	15
EFO6_cas	Exhaust Fan - Casing		104	100	90	82	70	62	58	52	87	17636835.9	4852785.7	12.0	1.0 m Above Roof	15	60	15
EF18	Exhaust Fan - Outlet		85	81	76	73	66	63	61	58	74	17636869.4	4852709.6	10.1	3.5 m Above Roof	15	60	15
SF6	Exhaust Fan - Outlet		85	81	76	73	66	63	61	58	74	17636871.0	4852704.9	10.1	3.5 m Above Roof	15	60	15
HRU1_EA	Heat Recovery Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	78	69	80	81	78	75	68	61	83	17636763.5	4852713.2	13.7	2.7 m Above Roof	60	30	30
HRU1_OA	Heat Recovery Unit - Outdoor Air Louvre	Rotate such that louvres are north and/or east	84	79	88	90	80	78	77	72	89	17636762.5	4852714.0	11.6	0.6 m Above Roof	60	30	30
HRU3_EA	Heat Recovery Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	74	64	74	80	76	74	70	66	81	17636743.3	4852714.7	13.5	2.5 m Above Roof	60	30	30
HRU3_OA	Heat Recovery Unit - Outdoor Air Louvre	Rotate such that louvres are north and/or east	69	64	72	75	66	64	63	60	74	17636742.3	4852715.5	11.6	0.6 m Above Roof	60	30	30
HRU4_EA	Heat Recovery Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	77	70	84	80	78	74	68	61	83	17636770.3	4852728.8	13.9	2.9 m Above Roof	60	30	30
HRU4_OA	Heat Recovery Unit - Outdoor Air Louvre	Rotate such that louvres are north and/or east	81	77	90	84	79	76	72	66	86	17636769.3	4852729.6	11.6	0.6 m Above Roof	60	30	30
HRU5_EA	Heat Recovery Unit - Exhaust Air Louvre		73	68	78	74	73	68	62	60	77	17636748.6	4852733.9	14.0	3.0 m Above Roof	60	30	30
HRU5_OA	Heat Recovery Unit - Outdoor Air Louvre		80	74	91	87	78	76	73	68	87	17636749.8	4852734.0	11.7	0.7 m Above Roof	60	30	30
HRU6_EA	Heat Recovery Unit - Exhaust Air Louvre	Rotate such that louvres are north and/or east	80	71	89	84	81	78	72	90	17636773.2	4852716.6	14.2	3.2 m Above Roof	60	30	30	
HRU6_OA	Heat Recovery Unit - Outdoor Air Louvre	Rotate such that louvres are north and/or east	81	83	87	79	74	72	67	62	82	17636772.0	4852717.5	11.8	0.8 m Above Roof	60	30	30
refuel	Refuelling		103	98	95	95	97	94	88	81	101	1763685.7	4852680.9	3.0	3.0 m Relative to Ground		60	
generator	Standby Generator		118	116	110	105	101	100	99	96	109	17636836.0	4852856.3	2.0	2.0 m Relative to Ground		60	

SOUND POWER LEVELS

Sound calculations are based on ASHRAE equations for attenuation of sound from lined plenums. To match actual test data, adjustments are made in the lower bands to account for sound reflection by the plenums.

Haakon casing sound absorption coefficients and transmission loss values used in the calculations have been obtained by an independent sound testing laboratory. The fan sound data is based on AMCA 300 testing.

UNIT	OPEN	SOUND POWER LEVELS (db)									
		BAND	1	2	3	4	5	6	7	8	
		FREQ	63	125	250	500	1000	2000	4000	8000	
5-7,9-11,13-15	SA		95	90	91	86	82	77	72	66	
5-7,9-11,13-15	RA		87	91	101	88	83	78	74	70	
5-7,9-11,13-15	EA LV		84	81	89	87	83	75	71	68	
5-7,9-11,13-15	OA		93	88	94	91	81	78	73	67	
AHU-1-3	SA		95	90	91	86	81	77	72	66	
AHU-1-3	RA		87	91	101	88	83	78	74	70	
AHU-1-3	EA LV		84	81	89	87	83	75	71	68	
AHU-1-3	OA		93	88	94	91	81	78	73	67	
AHU-17-20	SA		94	91	90	82	79	76	71	64	
AHU-17-20	RA		89	93	100	101	87	83	78	72	
AHU-17-20	EA LV		85	80	92	95	86	81	75	66	
AHU-17-20	OA		90	93	93	84	78	74	69	64	
AHU-21,22	SA		95	90	92	85	80	76	72	66	
AHU-21,22	RA		90	89	94	95	84	82	76	70	
AHU-21,22	EA LV		85	75	88	88	84	80	74	67	
AHU-21,22	OA		90	91	95	90	79	74	70	65	
AHU-23	SA		101	98	92	87	83	78	73	67	
AHU-23	RA		94	102	97	87	86	81	73	69	
AHU-23	EA LV		89	87	88	85	83	77	70	64	
AHU-23	OA		100	97	93	86	82	79	74	68	
AHU-24	SA		94	91	91	83	81	78	73	66	
AHU-24	OA		92	97	97	88	82	78	73	67	
AHU-25	SA		94	89	90	85	80	75	70	64	
AHU-25	RA		87	92	100	86	82	77	73	70	
AHU-25	EA LV		83	81	89	86	81	73	69	66	
AHU-25	OA		93	86	93	90	80	76	71	65	
AHU-26	SA		93	90	89	81	78	75	70	64	
AHU-26	RA		89	93	100	101	86	83	77	71	
AHU-26	EA LV		85	80	92	94	85	81	74	65	
AHU-26	OA		90	92	92	83	77	74	68	63	
AHU-27	SA		92	88	89	81	78	75	70	64	
AHU-27	RA		90	89	95	89	85	80	76	72	
AHU-27	EA LV		86	80	87	87	86	78	73	68	
AHU-27	OA		88	90	92	86	76	72	67	63	
AHU-28	SA		95	90	91	86	81	77	72	66	
AHU-28	RA		87	91	101	88	83	78	74	71	
AHU-28	EA LV		84	81	89	87	82	74	70	67	
AHU-28	OA		93	88	94	91	81	78	73	67	
AHU-29,30	SA		94	89	92	84	80	76	72	65	
AHU-29,30	RA		89	92	99	98	85	82	76	70	
AHU-29,30	EA LV		84	79	93	92	84	80	73	64	

PROJECT:

MBG - TORONTO TRANSIT CENTER

DRAWN BY TN

DATE 2014-10-03

JOB NO. 49446

UNITS IMPERIAL

DWG NO. 49446DT01

REVISION



SOUND POWER LEVELS

Sound calculations are based on ASHRAE equations for attenuation of sound from lined plenums. To match actual test data, adjustments are made in the lower bands to account for sound reflection by the plenums.

Haakon casing sound absorption coefficients and transmission loss values used in the calculations have been obtained by an independent sound testing laboratory. The fan sound data is based on AMCA 300 testing.

UNIT	OPEN	SOUND POWER LEVELS (db)									
		BAND	1	2	3	4	5	6	7	8	
		FREQ	63	125	250	500	1000	2000	4000	8000	
AHU-29,30	OA		89	91	94	89	78	74	69	64	
AHU-31	SA		93	89	90	83	79	76	71	65	
AHU-31	RA		89	92	99	98	85	81	76	69	
AHU-31	EA LV		84	79	93	92	84	79	72	63	
AHU-31	OA		89	91	93	88	77	73	68	64	
AHU-32	SA		93	86	87	84	79	76	72	68	
AHU-32	RA		85	80	93	91	83	80	78	71	
AHU-32	EA LV		77	68	85	83	80	77	74	67	
AHU-32	OA		91	85	89	87	81	76	73	69	
AHU-33	SA		90	81	86	85	82	80	73	67	
AHU-33	RA		82	81	93	86	79	77	73	67	
AHU-33	EA LV		76	68	82	79	77	73	68	61	
AHU-33	OA		86	78	87	85	83	81	75	69	
AHU-34	SA		94	87	86	82	78	74	70	66	
AHU-34	RA		84	83	91	86	77	74	70	65	
AHU-34	EA LV		77	71	80	80	75	71	67	63	
AHU-34	OA		92	86	88	87	80	76	72	68	
AHU-35	SA		74	66	69	69	65	62	60	60	
AHU-35	OA		71	66	74	74	70	66	62	60	
AHU-4	SA		93	89	91	84	80	76	72	66	
AHU-4	RA		89	93	99	98	85	82	76	70	
AHU-4	EA LV		85	79	92	92	84	80	73	64	
AHU-4	OA		89	91	94	89	78	74	69	65	
AHU-8,12,16	SA		93	89	91	83	80	76	72	66	
AHU-8,12,16	RA		89	93	99	98	85	82	76	70	
AHU-8,12,16	EA LV		85	79	92	92	84	80	73	64	
AHU-8,12,16	OA		89	91	94	89	78	74	69	65	
HRU-1	SA		85	80	87	88	83	81	78	74	
HRU-1	RA		81	79	88	87	81	78	72	65	
HRU-1	EA LV		78	69	80	81	78	75	68	61	
HRU-1	OA		84	79	88	90	80	78	77	72	
HRU-3	SA		75	69	74	78	71	69	66	61	
HRU-3	RA		79	76	82	86	77	75	73	69	
HRU-3	EA LV		74	64	74	80	76	74	70	66	
HRU-3	OA		69	64	72	75	66	64	63	60	
HRU-4	SA		82	77	88	84	80	77	72	65	
HRU-4	RA		82	81	92	86	80	78	73	66	
HRU-4	EA LV		77	70	84	80	78	74	68	61	
HRU-4	OA		81	77	90	84	79	76	72	66	
HRU-5	SA		76	68	83	80	76	73	68	62	

PROJECT: MBG - TORONTO TRANSIT CENTER

DRAWN BY	TN	JOB NO.	49446	DWG NO.	49446DT02
DATE	2014-10-03	UNITS	IMPERIAL	REVISION	



SOUND POWER LEVELS

Sound calculations are based on ASHRAE equations for attenuation of sound from lined plenums. To match actual test data, adjustments are made in the lower bands to account for sound reflection by the plenums.

Haakon casing sound absorption coefficients and transmission loss values used in the calculations have been obtained by an independent sound testing laboratory. The fan sound data is based on AMCA 300 testing.

UNIT	OPEN	SOUND POWER LEVELS (db)									
		BAND	1	2	3	4	5	6	7	8	
		FREQ	63	125	250	500	1000	2000	4000	8000	
HRU-5	RA		79	79	90	80	75	74	69	63	
HRU-5	EA LV		73	68	78	74	73	68	62	60	
HRU-5	OA		80	74	91	87	78	76	73	68	
HRU-6	RA		87	83	96	95	87	84	82	76	
HRU-6	SA		83	83	86	80	78	75	70	62	
HRU-6	EA LV		80	71	89	89	84	81	78	72	
HRU-6	OA		81	83	87	79	74	72	67	62	

PROJECT:

MBG - TORONTO TRANSIT CENTER

DRAWN BY TN

JOB NO. 49446

DWG NO. 49446DT03

DATE 2014-10-03

UNITS IMPERIAL

REVISION



ASHRAE 1991 Fan PWL Estimation - SF-6, EF-18

Select Fan Type From List:

Fan type **3** Centrifugal Forward Curved Blade, All Sizes

1	Centrifugal Airfoil, Backward Curved or Inclined Blade, Over 30 in dia. (0.76 m)
2	Centrifugal Airfoil, Backward Curved or Inclined Blade, Under 30 in dia. (0.76 m)
3	Centrifugal Forward Curved Blade, All Sizes
4	Centrifugal Radial, Forward Curved, Over 40 in dia. (1.01 m)
5	Centrifugal Radial, Forward Curved, Under 40 in dia. (1.01 m)
6	Centrifugal Radial, Straight Blade, Over 40 in dia. (1.01 m)
7	Centrifugal Radial, Straight Blade, Between 20 and 40 in dia. (0.51 to 1.01 m)
8	Centrifugal Radial, Straight Blade, Under 20 in dia. (0.51 m)
9	Tubeaxial (No Straighting Vanes), Over 40 in dia. (1.01 m)
10	Tubeaxial (No Straighting Vanes), Under 40 in dia. (1.01 m)
11	Vaneaxial, Over 40 in dia. (1.01 m)
12	Vaneaxial, Under 40 in dia. (1.01 m)
13	Propeller, All Sizes

UNITS **Imperial**

Fan Diameter	8495	in	Peak Fan Efficiency (PE)	
Flow Rate	8495	cfm	Peak Static Efficiency (SE)	
Static Pressure	0.5	in w.g.	SE / PE Ratio	N/A
RPM			Correction for Off-Peak	5.0 dB
No of Blades				
Blade Pass Freq (BPF)	500	Hz		
Blade Freq Incr (BFI)	2	dB		

	3	4	5	6	7	8	9	10
	Octave Band Centre Frequency (Hz)							
K _w	50	46	41	36	31	28	26	23
10 log Q	39.3	39.3	39.3	39.3	39.3	39.3	39.3	39.3
20 log P	-5.9	-5.9	-5.9	-5.9	-5.9	-5.9	-5.9	-5.9
BFI	-	-	-	2	-	-	-	-
PE / SE	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0
TOTAL PWL	88	84	79	76	69	66	64	61
Inlet PWL	85	81	76	73	66	63	61	58
Outlet PWL	85	81	76	73	66	63	61	58
Casing Loss	0	0	5	10	15	20	22	25

ASHRAE 1991 Fan PWL Estimation - EF-1,2,4

Select Fan Type From List:

Fan type **3** Centrifugal Forward Curved Blade, All Sizes

1	Centrifugal Airfoil, Backward Curved or Inclined Blade, Over 30 in dia. (0.76 m)
2	Centrifugal Airfoil, Backward Curved or Inclined Blade, Under 30 in dia. (0.76 m)
3	Centrifugal Forward Curved Blade, All Sizes
4	Centrifugal Radial, Forward Curved, Over 40 in dia. (1.01 m)
5	Centrifugal Radial, Forward Curved, Under 40 in dia. (1.01 m)
6	Centrifugal Radial, Straight Blade, Over 40 in dia. (1.01 m)
7	Centrifugal Radial, Straight Blade, Between 20 and 40 in dia. (0.51 to 1.01 m)
8	Centrifugal Radial, Straight Blade, Under 20 in dia. (0.51 m)
9	Tubeaxial (No Straighting Vanes), Over 40 in dia. (1.01 m)
10	Tubeaxial (No Straighting Vanes), Under 40 in dia. (1.01 m)
11	Vaneaxial, Over 40 in dia. (1.01 m)
12	Vaneaxial, Under 40 in dia. (1.01 m)
13	Propeller, All Sizes

UNITS **Imperial**

Fan Diameter	3197	in	Peak Fan Efficiency (PE)	
Flow Rate	3197	cfm	Peak Static Efficiency (SE)	
Static Pressure	4.8	in w.g.	SE / PE Ratio	N/A
RPM			Correction for Off-Peak	5.0 dB
No of Blades				
Blade Pass Freq (BPF)	500	Hz		
Blade Freq Incr (BFI)	2	dB		

	3	4	5	6	7	8	9	10
	Octave Band Centre Frequency (Hz)							
	63	125	250	500	1000	2000	4000	8000
K _w	50	46	41	36	31	28	26	23
10 log Q	35.0	35.0	35.0	35.0	35.0	35.0	35.0	35.0
20 log P	13.6	13.6	13.6	13.6	13.6	13.6	13.6	13.6
BFI	-	-	-	2	-	-	-	-
PE / SE	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0
TOTAL PWL	104	100	95	92	85	82	80	77
Inlet PWL	101	97	92	89	82	79	77	74
Outlet PWL	101	97	92	89	82	79	77	74
Casing Loss	0	0	5	10	15	20	22	25

ASHRAE 1991 Fan PWL Estimation - EF-5

Select Fan Type From List:

Fan type **3** Centrifugal Forward Curved Blade, All Sizes

1	Centrifugal Airfoil, Backward Curved or Inclined Blade, Over 30 in dia. (0.76 m)
2	Centrifugal Airfoil, Backward Curved or Inclined Blade, Under 30 in dia. (0.76 m)
3	Centrifugal Forward Curved Blade, All Sizes
4	Centrifugal Radial, Forward Curved, Over 40 in dia. (1.01 m)
5	Centrifugal Radial, Forward Curved, Under 40 in dia. (1.01 m)
6	Centrifugal Radial, Straight Blade, Over 40 in dia. (1.01 m)
7	Centrifugal Radial, Straight Blade, Between 20 and 40 in dia. (0.51 to 1.01 m)
8	Centrifugal Radial, Straight Blade, Under 20 in dia. (0.51 m)
9	Tubeaxial (No Straighting Vanes), Over 40 in dia. (1.01 m)
10	Tubeaxial (No Straighting Vanes), Under 40 in dia. (1.01 m)
11	Vaneaxial, Over 40 in dia. (1.01 m)
12	Vaneaxial, Under 40 in dia. (1.01 m)
13	Propeller, All Sizes

UNITS Imperial

Fan Diameter	in	Peak Fan Efficiency (PE)	
Flow Rate	cfm	Peak Static Efficiency (SE)	
Static Pressure	in w.g.	SE / PE Ratio	N/A
RPM		Correction for Off-Peak	5.0 dB
No of Blades			
Blade Pass Freq (BPF)	500 Hz		
Blade Freq Incr (BFI)	2 dB		

	3	4	5	6	7	8	9	10
	Octave Band Centre Frequency (Hz)							
K _w	50	46	41	36	31	28	26	23
10 log Q	33.8	33.8	33.8	33.8	33.8	33.8	33.8	33.8
20 log P	13.6	13.6	13.6	13.6	13.6	13.6	13.6	13.6
BFI	-	-	-	2	-	-	-	-
PE / SE	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0
TOTAL PWL	102	98	93	90	83	80	78	75
Inlet PWL	99	95	90	87	80	77	75	72
Outlet PWL	99	95	90	87	80	77	75	72
Casing Loss	0	0	5	10	15	20	22	25

ASHRAE 1991 Fan PWL Estimation - EF-6

Select Fan Type From List:

Fan type **3** Centrifugal Forward Curved Blade, All Sizes

1	Centrifugal Airfoil, Backward Curved or Inclined Blade, Over 30 in dia. (0.76 m)
2	Centrifugal Airfoil, Backward Curved or Inclined Blade, Under 30 in dia. (0.76 m)
3	Centrifugal Forward Curved Blade, All Sizes
4	Centrifugal Radial, Forward Curved, Over 40 in dia. (1.01 m)
5	Centrifugal Radial, Forward Curved, Under 40 in dia. (1.01 m)
6	Centrifugal Radial, Straight Blade, Over 40 in dia. (1.01 m)
7	Centrifugal Radial, Straight Blade, Between 20 and 40 in dia. (0.51 to 1.01 m)
8	Centrifugal Radial, Straight Blade, Under 20 in dia. (0.51 m)
9	Tubeaxial (No Straighting Vanes), Over 40 in dia. (1.01 m)
10	Tubeaxial (No Straighting Vanes), Under 40 in dia. (1.01 m)
11	Vaneaxial, Over 40 in dia. (1.01 m)
12	Vaneaxial, Under 40 in dia. (1.01 m)
13	Propeller, All Sizes

UNITS **Imperial**

Fan Diameter	in	Peak Fan Efficiency (PE)	
Flow Rate	cfm	Peak Static Efficiency (SE)	
Static Pressure	in w.g.	SE / PE Ratio	N/A
RPM		Correction for Off-Peak	5.0 dB
No of Blades			
Blade Pass Freq (BPF)	500 Hz		
Blade Freq Incr (BFI)	2 dB		

	3	4	5	6	7	8	9	10
	Octave Band Centre Frequency (Hz)							
	63	125	250	500	1000	2000	4000	8000
K _w	50	46	41	36	31	28	26	23
10 log Q	46.2	46.2	46.2	46.2	46.2	46.2	46.2	46.2
20 log P	6.2	6.2	6.2	6.2	6.2	6.2	6.2	6.2
BFI	-	-	-	2	-	-	-	-
PE / SE	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0
TOTAL PWL	107	103	98	95	88	85	83	80
Inlet PWL	104	100	95	92	85	82	80	77
Outlet PWL	104	100	95	92	85	82	80	77
Casing Loss	0	0	5	10	15	20	22	25

Table C.2: Bus Route Measurements and Calculations

Source ID	Source Description	Measurement Type	Partition Coefficient	Distance (m)	Spectrum Weighting	Measured Sound Pressure Levels (1/1 Octave Band Levels)								Total SPL (dBA)	Calculated Sound Power Levels (1/1 Octave Band Levels)								Total PWL (dBA)		
						32	63	125	250	500	1000	2000	4000	8000	32	63	125	250	500	1000	2000	4000	8000		
M_28	bus passby, acceleration from stop	Spherical	50%	2.0	Flat	82.5	101.1	98.7	87.7	82.3	79.6	77.6	73.2	65.2	87.6	115.1	112.7	101.7	96.3	93.6	91.6	87.2	79.2	101.6	
M_29	low speed bus passby	Spherical	50%	5.0	Flat	79.0	96.0	87.4	76.8	74.1	73.7	70.1	65.4	57.7	79.2	101.0	118.0	109.4	98.8	96.1	95.7	92.1	87.4	79.7	101.2
	average of low speed and accelerating															101.0	116.8	111.3	100.5	96.2	94.8	91.8	87.3	79.4	101.4
	per bus, per m																								
km/m	0.001																								
km/hr	20																								
total buses (bus / hr m)	0.00005																								
dB correction	-43.0																								
PWL / m / bus	average of low speed and accelerating, per bus, per metre															58.0	73.8	68.3	57.5	53.2	51.7	48.8	44.3	36.4	58.4

Bus Movement Summary

Bus Route	Bus Movements Per Hour		
	Daytime	3am Period	6am Period
Entrance	60	14	5
Exit	2	0	98

Table 4 Sound level data on general site activities

Ref No.	Equipment	Power rating kW	Equipment size, weight (mass), capacity	Octave Band Sound Pressure Levels (Hz)								A-weighted Sound Pressure Level, L_{Aeq} dB
				63	125	250	500	1k	2k	4k	8k	
Distribution of Materials												
1	Articulated Dump Truck $\times K$	194	25 t	90	87	77	79	75	73	67	63	81 $\times K$
2	Articulated Dump Truck $\times K$	187	23 t	85	80	77	72	74	70	65	58	78 $\times K$
3	Dumper $\times K$	81	7 t	84	81	74	73	72	68	61	53	76 $\times K$
4	Dumper $\times K$	75	9 t	82	76	75	74	68	68	64	55	76 $\times K$
5	Dumper (Idling)	75	9 t	73	64	55	55	60	56	50	43	63
6	Dumper $\times K$	60	6 t	89	86	77	74	72	72	66	62	79 $\times K$
7	Dumper $\times K$	56	5 t	90	86	72	71	71	71	66	59	78 $\times K$
8	Dumper (Idling)	56	5 t	68	56	47	49	52	50	41	32	56
9	Dumper $\times K$	32	3 t	82	82	78	77	69	67	61	53	77 $\times K$
10	Wheeled Excavator	90	18 t	64	60	63	64	62	57	51	45	66
11	Wheeled Excavator (Idling)	90	18 t	61	59	57	57	58	52	42	34	61
12	Wheeled Excavator $\times K$	63	14 t	84	82	77	75	72	68	60	52	77 $\times K$
13	Wheeled Loader $\times K$	75	37 t	83	72	70	69	65	64	57	49	71 $\times K$
14	Wheeled Backhoe loader	62	9 t	68	67	63	62	62	61	54	47	67
15	Fuel Tanker Lorry $\times K$	-	11 t	79	73	71	75	72	67	59	50	76 $\times K$
16	Fuel Tanker Pumping	-	25,000 litre	75	70	67	67	69	66	60	53	72
17	Tracked Excavator	41	8 t	81	72	68	68	66	64	60	55	71
Mixing Concrete												
18	Cement Mixer Truck (Discharging)	-	-	80	69	66	70	71	69	64	58	75
19	Cement Mixer Truck (Idling)	-	-	77	71	65	65	66	66	60	51	71
20	Concrete Mixer Truck	-	-	83	74	66	69	70	78	60	55	80
21	Large Lorry Concrete Mixer	216	-	80	71	65	72	71	72	68	56	77
22	Large Concrete Mixer	167	26 t	72	73	79	72	69	67	63	60	76
23	Small Cement Mixer	2	-	61	65	58	58	57	53	51	49	61
Pumping Concrete												
24	Concrete Pump + Cement Mixer Truck (Discharging)	223	8 t / 350 bar	69	64	64	66	63	59	53	47	67
25	Concrete Pump + Concrete Mixer Truck (Pumping to 5th Floor)	171	6 t / 350 bar / 150 mm diameter	83	81	78	79	77	74	71	66	82

$\times K$ Drive-by maximum sound pressure level in L_{max} (Octave Bands) and L_{Amax} (Overall Level)

UNIT TAG	SERVICE	LOCATION	AIR HANDLING UNIT SCHEDULE												SUPPLY FAN												HEATING NG @ 35 Kpa				ELECTRIC			PHYSICAL DIMENSIONS			
			U/s	U/s	U/s	Pa	Pa	RPM	BHP	HP	RPM	TYPE	VPHHZ	U/s	Pa	Pa	RPM	BHP	HP	RPM	TYPE	VPHHZ	KW	KW	°C	°C	VPHHZ	MCA	VPHHZ	mm	mm	mm	kg				
AHU-1	STORAGE BAY 1	ROOF	7,075	7,075	100%	7015	VFD	318	953	1499	15.0	1750	575/3/60	7075	VFD	318	889	1677	20	1750	575/3/60	586.1	468.9	575/3/60	8,192	4,975	4,490	11,762	13,567.8								
AHU-2	STORAGE BAY 2	ROOF	7,075	7,075	100%	7015	VFD	318	953	1499	15.0	1750	575/3/60	7075	VFD	318	889	1677	20	1750	575/3/60	586.1	468.9	575/3/60	8,192	4,975	4,490	11,762	13,567.8								
AHU-3	STORAGE BAY 3	ROOF	7,075	7,075	100%	7015	VFD	318	953	1499	15.0	1750	575/3/60	7075	VFD	318	889	1677	20	1750	575/3/60	586.1	468.9	575/3/60	8,192	4,975	4,490	11,762	13,567.8								
AHU-4	STORAGE BAY 4	ROOF	8,491	8,491	100%	8461	VFD	318	953	1369	20.0	1750	575/3/60	8491	VFD	318	889	1480	20	1750	575/3/60	677.8	542.2	575/3/60	8,496	5,461	4,683	13,467	13,567.8								
AHU-5	STORAGE BAY 5	ROOF	7,075	7,075	100%	7015	VFD	318	953	1499	15.0	1750	575/3/60	7075	VFD	318	889	1677	20	1750	575/3/60	494.6	395.7	575/3/60	8,039	4,975	4,490	11,463	13,567.8								
AHU-6	STORAGE BAY 6	ROOF	7,075	7,075	100%	7015	VFD	318	953	1499	15.0	1750	575/3/60	7075	VFD	318	889	1677	20	1750	575/3/60	494.6	395.7	575/3/60	8,039	4,975	4,490	11,463	13,567.8								
AHU-7	STORAGE BAY 7	ROOF	7,075	7,075	100%	7015	VFD	318	953	1499	15.0	1750	575/3/60	7075	VFD	318	889	1677	20	1750	575/3/60	494.6	395.7	575/3/60	8,039	4,975	4,490	11,463	13,567.8								
AHU-8	STORAGE BAY 8	ROOF	8,491	8,491	100%	8461	VFD	318	953	1369	20.0	1750	575/3/60	8491	VFD	318	889	1480	20	1750	575/3/60	586.1	468.9	575/3/60	8,293	5,461	4,683	13,064	13,567.8								
AHU-9	STORAGE BAY 9	ROOF	7,075	7,075	100%	7015	VFD	318	953	1499	15.0	1750	575/3/60	7075	VFD	318	889	1677	20	1750	575/3/60	494.6	395.7	575/3/60	8,039	4,975	4,490	11,463	13,567.8								
AHU-10	STORAGE BAY 10	ROOF	7,075	7,075	100%	7015	VFD	318	953	1499	15.0	1750	575/3/60	7075	VFD	318	889	1677	20	1750	575/3/60	494.6	395.7	575/3/60	8,039	4,975	4,490	11,463	13,567.8								
AHU-11	STORAGE BAY 11	ROOF	7,075	7,075	100%	7015	VFD	318	953	1499	15.0	1750	575/3/60	7075	VFD	318	889	1677	20	1750	575/3/60	494.6	395.7	575/3/60	8,039	4,975	4,490	11,463	13,567.8								
AHU-12	STORAGE BAY 12	ROOF	8,491	8,491	100%	8461	VFD	318	953	1369	20.0	1750	575/3/60	8491	VFD	318	889	1480	20	1750	575/3/60	586.1	468.9	575/3/60	8,293	5,461	4,683	13,064	13,567.8								
AHU-13	STORAGE BAY 13	ROOF	7,075	7,075	100%	7015	VFD	318	953	1499	15.0	1750	575/3/60	7075	VFD	318	889	1677	20	1750	575/3/60	494.6	395.7	575/3/60	8,039	4,975	4,490	11,463	13,567.8								
AHU-14	STORAGE BAY 14	ROOF	7,075	7,075	100%	7015	VFD	318	953	1499	15.0	1750	575/3/60	7075	VFD	318	889	1677	20	1750	575/3/60	494.6	395.7	575/3/60	8,039	4,975	4,490	11,463	13,567.8								
AHU-15	STORAGE BAY 15	ROOF	7,075	7,075	100%	7015	VFD	318	953	1499	15.0	1750	575/3/60	7075	VFD	318	889	1677	20	1750	575/3/60	494.6	395.7	575/3/60	8,039	4,975	4,490	11,463	13,567.8								
AHU-16	STORAGE BAY 16	ROOF	8,491	8,491	100%	8461	VFD	318	953	1369	20.0	1750	575/3/60	8491	VFD	318	889	1480	20	1750	575/3/60	586.1	468.9	575/3/60	8,293	5,461	4,683	13,064	13,567.8								
AHU-17	MNU/VERNING ASLE 1	ROOF	9,670	9,670	100%	9670	VFD	318	953	1190	20.0	1750	575/3/60	9670	VFD	318	889	1602	25	1750	575/3/60	732.8	596.2	575/3/60	8,649	5,537	4,810	14,432	13,567.8								
AHU-18	MNU/VERNING ASLE 2	ROOF	9,670	9,670	100%	9670	VFD	318	953	1190	20.0	1750	575/3/60	9670	VFD	318	889	1602	25	1750	575/3/60	604.4	527.5	575/3/60	8,649	5,537	4,810	14,432	13,567.8								
AHU-19	MNU/VERNING ASLE 3	ROOF	9,670	9,670	100%	9670	VFD	318	953	1190	20.0	1750	575/3/60	9670	VFD	318	889	1602	25	1750	575/3/60	659.4	575.5	575/3/60	8,649	5,537	4,810	14,432	13,567.8								
AHU-20	MNU/VERNING ASLE 4	ROOF	9,670	9,670	100%	9670	VFD	318	953	1190	20.0	1750	575/3/60	9670	VFD	318	889	1602	25	1750	575/3/60	732.8	596.2	575/3/60	8,649	5,537	4,810	14,432	13,567.8								
AHU-21	FUEL BAY @ 15% +	ROOF	8,632	8,632	100%	8632	VFD	318	953	1379	20.0	1750	575/3/60	8632	VFD	318	889	1609	20	1750	575/3/60	512.0	410.3	575/3/60	8,141	5,220	4,682	12,661	13,567.8								
AHU-22	FUEL BAY @ 15% - 2, MILLWEIGHT SHC	ROOF	8,632	8,632	100%	8632	VFD	318	953	1379	20.0	1750	575/3/60	8632	VFD	318	889	1506	20	1750	575/3/60	512.0	410.3	575/3/60	8,141	5,220	4,682	12,661	13,567.8								
AHU-23	WASHBAY	ROOF	15,142	15,142	100%	15142	VFD	318	953	992	30.0	1750	575/3/60	15142	VFD	318	889	1070	40	1750	575/3/60	1025.8	920.6	575/3/60	9,938	6,213	5,817	20,141	13,567.8								
AHU-24	TOUCH UP BAY	ROOF	19,811	19,811	100%	19811	VFD	318	889	1179	20.0	1750	575/3/60	19811	VFD	318	889	1179	20	1750	575/3/60	1319.9	1055.1	575/3/60	9,938	6,213	5,817	20,141	13,567.8								
AHU-25	BODY BAY	ROOF	6,651	6,651	100%	6651	VFD	318	953	146	15.0	1750	575/3/60	6651	VFD	318	889	1616	15	1750	575/3/60	531.3	425	575/3/60	8,039	5,077	4,388	11,277	13,567.8								
AHU-26	ARTICULATED MAINT BAY 1	ROOF	9,340	9,340	100%	9040	VFD	318	953	1174	20.0	1750	575/3/60	9340	VFD	318	889	1567	25	1750	575/3/60	806.0	644.8	575/3/60	8,649	5,661	4,703	14,399	13,567.8								
AHU-27	ARTICULATED PAINT BAY 2	ROOF	7,642	7,642	100%	7642	VFD	318	953	1309	15.0	1750	575/3/60	7642	VFD	318	889	1779	20	1750	575/3/60	622.8	498.2	575/3/60	8,192	5,191	4,491	22,029	13,567.8								
AHU-28	ARTICULATED PAINT BAY 3	ROOF	7,170	7,170	100%	7170	VFD	318	953	1508	15.0	1750	575/3/60	7170	VFD	318	889	1691	20	1750	575/3/60	586.1	468.9	575/3/60	8,192	5,191	4,461	11,974	13,567.8								
AHU-29	STANDARD MINT BAY 1	ROOF	8,398	8,398	100%	8398	VFD	318	953	1362	20.0	1750	575/3/60	8398	VFD	318	889	1470	20	1750	575/3/60	622.8	498.2	575/3/60	8,293	5,182	4,681	12,841	13,567.8								
AHU-30	STANDARD MINT BAY 2	ROOF	8,398	8,398	100%	8398	VFD	318	953	1362	20.0	1750	575/3/60	8398	VFD	318	889	1470	20	1750	575/3/60	622.8	498.2	575/3/60	8,293	5,181	4,681	12,841	13,567.8								
AHU-31	STANDARD MINT BAY 3	ROOF	8,113	8,113	100%	8113	VFD	318	953	1342	15.0	1750	575/3/60	8113	VFD	318	889	1442	20	1750	575/3/60	630.1	504.1	575/3/60	8,788	3,823	3,793	8,292	13,567.8								
AHU-32	DE GREASING BAY	ROOF	3,868	3,868	100%	3868	VFD	318	953	2007	10.0	1750	575/3/60	3868	VFD	318	889	2282	10	1750	575/3/60	300.4	240.3	575/3/60	6,797	3,454	3,744	5,764	13,567.8								
AHU-33	PART STORAGE	ROOF	2,925	2,925	100%	2925	VFD	318	953	2346	7.5	1750	575/3/60	2925	VFD	318	889	1962	7.5	1750	575/3/60	113.6	90.9	575/3/60	6,797	3,454	3,815	6,276	13,567.8								
AHU-34	TOOL STORAGE	ROOF	3,538	3,538	100%	3538	VFD	318	953	1935	7.5	1750	575/3/60	3538	VFD	318	889	1709	7.5	1750	575/3/60	131.9	105.5	575/3/60	6,867	3,496	3,815	6,276	13,567.8								
AHU-35	BATTERY STORAGE	ROOF	613	613	100%	613	VFD	254	320	1896	0.48	15	1750	575/3/60	613	VFD	254	320	1896	6	1750	575/3/60	40.3	32.2	575/3/60	4,435	3,114	1,086	1,395	13,567.8							
AHU-36	SOUTH BUS STORAGE ENTRANCE	ROOF	5,197	0	0%	5197</td																															

VAV BOX SCHEDULE

TAG	Location	Qty	Unit Size	Max (Primary L/s)	Mn (Primary L/s)	Reheat(L/s)	EAT °C	LAT °C	Capacity (MBH)	Capacity (Kw)	Rows	Fluid Type	Fluid Flow(L/s)	Max Air PD (Pa)	EWT °C	LWT °C	Fluid PD (kPa)	Max Discharge NC	Max Radiated NC	Min Discharge NC	Mn Radiated NC	Controller	Weight (Kg)			
VAV-1-1	F1	1	8	368	110	110	12.8	23.9	5.22	1.53	1 HC	WTR	0.02	86.4	60.0	44.6	0.42	--	24	--	--	DDC By Div 25	26.1			
VAV-1-2	F1	1	10	547	164	164	12.8	23.9	7.77	2.28	1 HC	WTR	0.03	88.9	60.0	42.3	0.84	--	24	--	--	DDC By Div 25	31.1			
VAV-1-3	F1	1	7	287	86	86	12.8	23.9	4.09	1.20	1	WTR	0.02	48.3	60.0	45.0	0.30	21	21	--	--	--	DDC By Div 25	24.7		
VAV-1-4	F1	1	8	327	268	268	12.8	23.9	12.70	3.72	2	WTR	0.04	129.5	60.0	39.7	0.45	--	21	--	--	--	--	DDC By Div 25	27.2	
VAV-1-5	F1	1	10	517	406	406	12.8	23.9	19.23	5.64	2	WTR	0.06	152.4	60.0	36.9	0.90	--	21	--	--	--	--	DDC By Div 25	32.2	
VAV-1-6	F1	2	10	576	494	494	12.8	23.9	23.40	6.86	2	WTR	0.08	182.9	60.0	39.4	1.49	--	21	--	--	--	--	DDC By Div 25	32.2	
VAV-1-7	F1	1	4	71	71	71	12.8	23.9	3.37	0.99	1	WTR	0.02	7.6	60.0	47.6	0.24	--	--	--	--	--	--	DDC By Div 25	23.6	
VAV-1-8	F1	1	4	39	24	24	12.8	32.8	2.00	0.59	1	WTR	0.02	2.5	60.0	52.8	0.24	--	--	--	--	--	--	DDC By Div 25	23.6	
VAV-1-9	F1	1	5	132	100	100	12.8	23.9	4.70	1.08	1 HC	WTR	0.03	22.9	60.0	48.4	0.42	--	--	--	--	--	--	DDC By Div 25	23.6	
VAV-3-1	F1	1	4	71	71	71	12.8	23.9	3.35	0.98	1	WTR	0.02	7.6	60.0	47.7	0.21	--	--	--	--	--	--	DDC By Div 25	23.6	
VAV-3-2	F1	1	4	75	71	71	12.8	23.9	3.35	0.98	1	WTR	0.02	7.6	60.0	47.7	0.21	--	20	20	--	--	--	--	DDC By Div 25	23.6
VAV-3-3	F1	1	6	106	105	106	12.8	23.9	5.02	1.47	1 HC	WTR	0.03	15.2	60.0	49.0	0.48	--	--	--	--	--	--	DDC By Div 25	24.1	
VAV-3-4	F1	1	4	71	71	71	12.8	23.9	3.35	0.98	1	WTR	0.02	7.6	60.0	47.7	0.21	--	--	--	--	--	--	DDC By Div 25	23.6	
VAV-3-5	F1	1	6	191	72	72	12.8	23.9	3.42	1.00	1	WTR	0.02	40.6	60.0	47.9	0.24	--	23	--	--	--	--	--	DDC By Div 25	24.1
VAV-3-6	F1	1	8	331	151	151	12.8	23.9	7.14	2.09	1 HC	WTR	0.04	71.1	60.0	48.0	0.99	--	23	--	--	--	--	--	DDC By Div 25	26.1
VAV-3-7	F1	1	6	140	71	71	12.8	23.9	3.35	0.98	1	WTR	0.02	22.9	60.0	47.7	0.21	--	--	--	--	--	--	DDC By Div 25	24.1	
VAV-0-1	F2	1	0	197	173	173	12.8	20.0	8.70	2.04	2 HC	WTR	0.04	101.0	60.0	42.2	0.27	--	20	--	--	--	--	--	DDC By Div 25	24.7
VAV-6-2	F2	1	10	533	492	492	12.8	24.0	23.50	6.89	2	WTR	0.08	160.0	60.0	39.5	1.52	--	21	--	20	--	--	--	DDC By Div 25	32.2
VAV-6-3	F2	1	6	117	74	74	12.8	24.9	3.80	1.11	1 HC	WTR	0.02	20.3	60.0	47.4	0.27	--	--	--	--	--	--	--	DDC By Div 25	24.1
VAV-6-4	F2	4	12	726	289	289	12.8	23.9	13.66	4.00	1 HC	WTR	0.06	83.8	60.0	43.5	2.93	--	25	--	--	--	--	--	DDC By Div 25	43.1
VAV-6-5	F2	2	9	439	328	328	12.8	24.7	16.60	4.87	2	WTR	0.05	111.8	60.0	36.2	0.69	20	21	--	--	--	--	--	DDC By Div 25	30.4
VAV-6-6	F2	1	8	319	288	288	12.8	26.1	4.78	2 HC	WTR	0.06	142.2	60.0	42.2	0.81	--	20	--	--	--	--	--	DDC By Div 25	27.2	
VAV-6-7	F2	2	9	403	333	333	12.8	23.9	15.78	4.62	2	WTR	0.04	96.5	60.0	34.8	0.57	--	20	--	--	--	--	--	DDC By Div 25	30.4
EAV-1	F1	1	14	812	812	812																		DDC By Div 25		
EAV-2	F2	1	12	624	624	624																			DDC By Div 25	
FPB	F1	1	206																							

CABINET FORCE FLOW HEATER

TAG	UNIT CONFIGURATION	SERVICE	LOCATION	DESIGN CAPACITY		AIR	LIQUID				ROWS	FAN MOTOR	ELECTRIC	REMARKS
				OUTPUT	Kw		FLOW U/S	TEMP °C	FLOW L/S	TEMP °C				
FCU-1	HORIZONTAL CONCEALED, FRONT DUCT COLLAR, BACK RADUCT COLLAR	CORRIDOR 312	CORRIDOR 312	2.10	32	15.6	WATER	0.051	82.2	71.1	8	100W	115/1/60	1
FCU-2	HORIZONTAL CONCEALED, FRONT DUCT COLLAR, BACK RADUCT COLLAR	VESTIBULE 127	VESTIBULE 127	2.10	32	15.6	WATER	0.051	82.2	71.1	8	100W	115/1/60	1
FCU-3	VERTICAL CABINET, FRONT TOE INLET, FRONT STAMPED LOUVER OUTLET	STARWELL-118	STARWELL-118	2.10	32	15.6	WATER	0.051	82.2	71.1	8	100W	115/1/60	1
FCU-4	VERTICAL CABINET, FRONT TOE INLET, FRONT STAMPED LOUVER OUTLET	STARWELL-118	STARWELL-118	2.10	32	15.6	WATER	0.051	82.2	71.1	8	100W	115/1/60	1
FCU-5	VERTICAL CABINET, FRONT TOE INLET, FRONT STAMPED LOUVER OUTLET	STARWELL-316	STARWELL-316	2.10	32	15.6	WATER	0.051	82.2	71.1	8	100W	115/1/60	1
FCU-6	VERTICAL CABINET, FRONT TOE INLET, FRONT STAMPED LOUVER OUTLET	STARWELL-316	STARWELL-316	2.10	32	15.6	WATER	0.051	82.2	71.1	8	100W	115/1/60	1
FCU-7	VERTICAL CABINET, FRONT TOE INLET, FRONT STAMPED LOUVER OUTLET	STARWELL-121	STARWELL-121	2.10	32	15.6	WATER	0.051	82.2	71.1	8	100W	115/1/60	1
FCU-8	VERTICAL CABINET, FRONT TOE INLET, FRONT STAMPED LOUVER OUTLET	STARWELL-121	STARWELL-121	2.10	32	15.6	WATER	0.051	82.2	71.1	8	100W	115/1/60	1
FCU-9	VERTICAL CABINET, FRONT TOE INLET, FRONT STAMPED LOUVER OUTLET	STARWELL-121	STARWELL-121	2.10	32	15.6	WATER	0.051	82.2	71.1	8	100W	115/1/60	1
FCU-10	HORIZONTAL CONCEALED, FRONT DUCT COLLAR, BACK RADUCT COLLAR	VESTIBULE 125	VESTIBULE 125	2.10	32	15.6	WATER	0.051	82.2	71.1	8	100W	115/1/60	1
FCU-11	HORIZONTAL CONCEALED, FRONT DUCT COLLAR, BACK RADUCT COLLAR	VESTIBULE 101	VESTIBULE 101	2.10	32	15.6	WATER	0.051	82.2	71.1	8	100W	115/1/60	1
FCU-12	HORIZONTAL CONCEALED, FRONT DUCT COLLAR, BACK RADUCT COLLAR	VESTIBULE	VESTIBULE	2.10	32	15.6	WATER	0.051	82.2	71.1	8	100W	115/1/60	1
FCU-13	HORIZONTAL CONCEALED, FRONT DUCT COLLAR, BACK RADUCT COLLAR	VESTIBULE	VESTIBULE	2.10	32	15.6	WATER	0.051	82.2	71.1	8	100W	115/1/60	1

ELECTRIC BASE BOARD HEATER SCHEDULE

TAG	SERVICE	LOCATION	FLUID	FLOW RATE	PIPE SIZE	PIPE LENGTH (MM)	WIDTH (MM)	HEIGHT (MM)	NOTES
AS-1	HEATING WATER LOOP	BOILER RM	WATER	2.0			457	585	1,2,3

NOTES:

1. ASME RATED DIAPHRAGM TYPE
2. SUITABLE FOR 125PSI MAXIMUM WORKING PRESSURE
3. C/W SEISMIC RESTRAINTS

REVISIONS		REVISIONS		SCOPE REVIEW DRAWING NOT FOR CONSTRUCTION				SCALE(S)	
									

DRAWING No. G85-314-M561	Sheet No.	McNICOLL BUS GARAGE	H.V.A.C SCHEDULES	Print Date 08-27-2014
				
				Doc No. G85-314-M561
				Sheet No.

HEAT RECOVERY UNIT SCHEDULE

TAG	SERVICE	DESIGN CONDITION	SUPPLY								EXHAUST								REMARK
			AIR FLOW	EDB	EWB	LDB	LWB	APD	ENERGY RECOVERY	AIR FLOW	EDB	RH	LDB	LWB	APD				
L/S	°C	°C	°C	Pa	Kw	L/S	°C	°C	%	Pa									
HRU-AHU-1	AHU-1	WNTER	7.075	-20	-20	-3.7	-7.2	122	140	7075	22	15	-7.4	-9.1	127	1			
HRU-AHU-2	AHU-2	WNTER	7.075	-20	-20	-3.7	-7.2	122	140	7075	22	15	-7.4	-9.1	127	1			
HRU-AHU-3	AHU-3	WNTER	7.075	-20	-20	-3.7	-7.2	122	140	7075	22	15	-7.4	-9.1	127	1			
HRU-AHU-4	AHU-4	WNTER	8.491	-20	-20	-4.0	-7.4	140	165	8491	22	15	-7.4	-8.9	149	1			
HRU-AHU-5	AHU-5	WNTER	7.075	-20	-20	-3.7	-7.2	122	140	7075	22	15	-7.4	-9.1	127	1			
HRU-AHU-6	AHU-6	WNTER	7.075	-20	-20	-3.7	-7.2	122	140	7075	22	15	-7.4	-9.1	127	1			
HRU-AHU-7	AHU-7	WNTER	7.075	-20	-20	-3.7	-7.2	122	140	7075	22	15	-7.4	-9.1	127	1			
HRU-AHU-8	AHU-8	WNTER	8.491	-20	-20	-4.0	-7.4	140	165	8491	22	15	-6.7	8.0	145	1			
HRU-AHU-9	AHU-9	WNTER	7.075	-20	-20	-3.7	-7.2	122	140	7075	22	15	-7.4	-9.1	127	1			
HRU-AHU-10	AHU-10	WNTER	7.075	-20	-20	-3.7	-7.2	122	140	7075	22	15	-7.4	-9.1	127	1			
HRU-AHU-11	AHU-11	WNTER	7.075	-20	-20	-3.7	-7.2	122	140	7075	22	15	-7.4	-9.1	127	1			
HRU-AHU-12	AHU-12	WNTER	8.491	-20	-20	-4.0	-7.4	140	165	8491	22	15	-6.7	-8.9	145	1			
HRU-AHU-13	AHU-13	WNTER	7.075	-20	-20	-3.7	-7.2	122	140	7075	22	15	-7.4	-9.1	127	1			
HRU-AHU-14	AHU-14	WNTER	7.075	-20	-20	-3.7	-7.2	122	140	7075	22	15	-7.4	-9.1	127	1			
HRU-AHU-15	AHU-15	WNTER	7.075	-20	-20	-3.7	-7.2	122	140	7075	22	15	-7.4	-9.1	127	1			
HRU-AHU-16	AHU-16	WNTER	8.491	-20	-20	-4.0	-7.4	140	165	8491	22	15	-6.7	8.0	145	1			
HRU-AHU-17	AHU-17	WNTER	9.670	-20	-20	-3.3	-3.3	137	182	9670	22	15	-2.3	-3.7	147	1			
HRU-AHU-18	AHU-18	WNTER	9.670	-20	-20	-2.3	-3.3	137	182	9670	22	15	-2.3	-3.7	147	1			
HRU-AHU-19	AHU-19	WNTER	9.670	-20	-20	-2.3	-3.3	137	182	9670	22	15	-2.3	-3.7	147	1			
HRU-AHU-20	AHU-20	WNTER	9.670	-20	-20	-2.3	-3.3	137	182	9670	22	15	-2.3	-3.7	147	1			
HRU-AHU-21	AHU-21	WNTER	8.832	-20	-20	-2.2	-3.4	142	133	8832	22	15	-2.1	-3.7	152	1			
HRU-AHU-22	AHU-22	WNTER	8.832	-20	-20	-2.2	-3.4	142	133	8832	22	15	-2.1	-3.7	152	1			
HRU-AHU-23	AHU-23	WNTER	15.142	-20	-20	-2.3	-3.3	137	410	15142	22	15	-2.2	-3.7	147	1			
HRU-AHU-25	AHU-25	WNTER	6.651	-20	-20	-2.4	-3.2	132	183	6651	22	15	-2.4	-3.8	140	1			
HRU-AHU-26	AHU-26	WNTER	9.340	-20	-20	-2.2	-3.3	140	252	9340	22	15	-2.1	-3.7	150	1			
HRU-AHU-27	AHU-27	WNTER	7.642	-20	-20	-2.3	-3.3	137	207	7642	22	15	-2.2	-3.7	147	1			
HRU-AHU-28	AHU-28	WNTER	7.170	-20	-20	-2.3	-3.3	137	194	7170	22	15	-2.2	-3.7	147	1			
HRU-AHU-29	AHU-29	WNTER	8.396	-20	-20	-2.2	-3.4	140	226	8396	22	15	-2.1	-3.7	150	1			
HRU-AHU-30	AHU-30	WNTER	8.396	-20	-20	-2.2	-3.4	140	226	8396	22	15	-2.1	-3.7	150	1			
HRU-AHU-31	AHU-31	WNTER	8.113	-20	-20	-2.3	-3.3	140	220	8113	22	15	-2.2	-3.7	147	1			
HRU-AHU-32	AHU-32	WNTER	3.868	-20	-20	-2.3	-3.3	135	105	3868	22	15	-2.3	-3.8	145	1			
HRU-AHU-33	AHU-33	WNTER	2.925	-20	-20	-2.3	-3.3	140	79	2925	22	15	-2.2	-3.7	147	1			
HRU-AHU-34	AHU-34	WNTER	3.538	-20	-20	2.3	-3.3	137.0	95.7	3538	22	15	-2.2	-3.7	147	1			

NOTES:

1. PACKAGED WITH AHU

SILENCER SCHEDULE

TAG	FAN SYSTEM	FACE DIM				FLOW	VELOCITY	PRESSURE DROP W/ SYSTEM EFFECTS	DYNAMIC INSERTION LOSS								NOTES
		W (M)	H (M)	MM	L/S				Pa	Pa	63	125	250	500	1000	2000	4000
SL-S-1	AC-AHU-1 SUPPLY AIR	600	600	2400	2,912	8.1	42	70	5	-2	21	36	35	24	15	11	
SL-S-1R	AC-AHU-1 RETURN AIR	750	500	3000	2702	-7.2	28	61	4	-3	23	31	26	17	14	13	
SL-S-2	AC-AHU-2 SUPPLY AIR	250	350	2100	378	4.3	49	78	8	-7	27	38	43	39	34	29	
SL-S-2R	AC-AHU-2 RETURN AIR	250	350	3600	143	-1.6	31	74	8	-24	30	47	50	47	37	26	
SL-S-3	AC-AHU-3 SUPPLY AIR	500	350	3000	1055	-6.0	28	56	9	-20	31	32	30	19	14	13	
SL-S-3R	AC-AHU-3 RETURN AIR	500	350	3000	2,912	7.3	26	58	10	-18	30	41	35	24	23		
SL-S-4	AC-AHU-4 SUPPLY AIR	700	900	3600	2,015	-4.2	15	59	10	-22	23	33	52	36	26	20	
SL-S-5	AC-AHU-5 SUPPLY AIR	350	650	2700	2,460	-10.6	28	89	7	-5	25	28	36	37	35	25	
SL-S-5R	AC-AHU-5 RETURN AIR	450	650	3600	2,460	-8.4	34	92	9	-24	36	50	46	45	37	27	
SL-S-6	AC-AHU-6 SUPPLY AIR	600	900	2700	4,632	8.6	15	54	10	-17	16	28	37	32	22	22	
SL-S-6R	AC-AHU-6 RETURN AIR	600	900	3600	4,231	7.8	33	72	13	-23	30	36	48	36	24	28	

NOTES:

1. SELECTION OF SILENCERS BASED ON MAINTAINING SPACE SOUND LEVEL AT NC-35 WITH SPECIFIED SOUND POWER LEVEL FROM AHUs.

GAS-FIRED CONDENSING BOILER SCHEDULE

TAG	TYPE	SERVICE	LOCATION	INPUT		OUTPUT (SEE NOTE 6)		EFFICIENCY (SEE NOTE 6)	TEMPERATURE OPERATING HI-LIMIT		FUEL	NATURAL GAS SUPPLY/PRESSURE		NATURAL GAS CONSUMPTION		MAX. OPERATING WEIGHT		NOTES
				Kw	Kw	Kw	Kw		°C	°C		MPa	kG	kg	kg	kg		
B-1	HIGH EFF.	CONDENSING	HEATING	BOILER ROOM	219	95	93	97.4	20-90	110	NATURAL GAS	.25	9.2	115	1,2,3,4,5,6			
B-2	HIGH EFF.	CONDENSING	HEATING	BOILER ROOM	219	95	93	97.4	20-90	110	NATURAL GAS	.25	9.2	115	1,2,3,4,5,6			

NOTES:

1. DUAL HEATING WATER RETURN INLETS TO BOILER FOR HIGH AND LOW TEMPERATURE RETURN WATER.

2. MODULATING BURNER

3. STAINLESS STEEL BURNER; CAST ALUMINUM / SILICUM SECTIONAL HEAT EXCHANGER

4. NEUTRALIZING TANK

5. BACNet® COMPATIBLE ELECTRONIC CONTROL PANEL

6. INDICATED BOILER OUTPUT IS AT 70°C BOILER SUPPLY WATER TEMPERATURE AND 50°C RETURN WATER TEMPERATURE TO BOILER.

7. DIRECT VENTING AIR INTAKE AND FLUE DISCHARGE PIPE PACKAGE

DUST COLLECTOR SCHEDULE

TAG	SERVICE	LOCATION	TYPE	AIR SUCTION CAPACITY		MAX. STATIC PRESSURE	MIN. INLET SIZE	MOTOR RPM	ELECTRIC WEIGHT	
				L/S	%	KPa	mm Dia.	HP	VPHz	Kg
DC-1	BODY SHOP	BODY SHOP	WALL MOUNT	253	18	100	100	3450	1	115/160
DC-2	BODY SHOP	BODY SHOP	WALL MOUNT	253	18	100	100	3450	1	115/160

NOTES:

1. COORDINATE WITH ARCHITECT THE CABINET ARRANGEMENT AND THE ASSOCIATED ACCESSORIES PRIOR TO ORDERING.

2. CW NECESSARY ACCESSORIES INCLUDING END PIECE, WALL TRIM, ACCESS PANELS, ETC.

3. PROTECTIVE MAGNESIUM ANODE RODS

4. COMPLETE WITH FRAMING SUITABLE FOR LAY-IN TYPE ACOUSTIC CEILING

5.

CONTROL VALVE SCHEDULE

TAG	TYPE	SERVICE	LOCATION	FLOW	MEDIUM	DESIGN P	PIPE LINE SIZE	CONTROL VALVE SIZE	NOTES		
										kPa	DIA. MM
CV-B-1	2-WAY, ON/OFF	B-1 HIGH TEMP HEATING RETURN	219 - BOILER ROOM		HOT WATER					15	15
CV-B-12	2-WAY, ON/OFF	B-1 LOW TEMP HEATING RETURN	219 - BOILER ROOM		HOT WATER					15	15
CV-B-2	2-WAY, ON/OFF	B-2 HIGH TEMP HEATING RETURN	219 - BOILER ROOM		HOT WATER					15	15
CV-B-22	2-WAY, ON/OFF	B-2 LOW TEMP HEATING RETURN	219 - BOILER ROOM		HOT WATER					15	15
FCU-1	PICCV	HEATING COIL	312 - CORRIDOR	0.0103	PROPYLENE GLYCOL 50%	15	15	2			
FCU-2	PICCV	HEATING COIL	127 - VESTIBULE	0.051	PROPYLENE GLYCOL 50%	15	15	2			
FCU-3	PICCV	HEATING COIL	118 - STARYWELL	0.051	PROPYLENE GLYCOL 50%	15	15	2			
FCU-4	PICCV	HEATING COIL	118 - STARYWELL	0.051	PROPYLENE GLYCOL 50%	15	15	2			
FCU-5	PICCV	HEATING COIL	316 - STARYWELL	0.051	PROPYLENE GLYCOL 50%	15	15	2			
FCU-6	PICCV	HEATING COIL	121 - STARYWELL	0.000	PROPYLENE GLYCOL 50%	15	15	2			
FCU-7	PICCV	HEATING COIL	121 - STARYWELL	0.051	PROPYLENE GLYCOL 50%	15	15	2			
FCU-8	PICCV	HEATING COIL	121 - STARYWELL	0.051	PROPYLENE GLYCOL 50%	15	15	2			
FCU-9	PICCV	HEATING COIL	125 - STARYWELL	0.051	PROPYLENE GLYCOL 50%	15	15	2			
FCU-10	PICCV	HEATING COIL	125 - VESTIBULE	0.051	PROPYLENE GLYCOL 50%	15	15	2			
FCU-11	PICCV	HEATING COIL	101 - VESTIBULE	0.051	PROPYLENE GLYCOL 50%	15	15	2			
FCU-12	PICCV	HEATING COIL	101 - VESTIBULE	0.051	PROPYLENE GLYCOL 50%	15	15	2			
FCU-13	PICCV	HEATING COIL	101 - VESTIBULE	0.051	PROPYLENE GLYCOL 50%	15	15	2			
CV-VAV-1	3-WAY, MOD. MIXING	VAV REHEATING SUPPLY MAIN	219 - BOILER ROOM	0.86	HOT WATER	22.5	32/32/40	25	1.2		
CV-VAV-1-1	PICV	REHEAT COIL	102 - LUNCH ROOM	0.02	HOT WATER			15	15	1.2	
CV-VAV-1-2	PICV	REHEAT COIL	103 - DIVISION MANAGER	0.03	HOT WATER			15	15	1.2	
CV-VAV-1-3	PICV	REHEAT COIL	103 - DIVISION MANAGER	0.02	HOT WATER			15	15	1.2	
CV-VAV-1-4	PICV	REHEAT COIL	106 - OPEN OFFICE	0.04	HOT WATER			15	15	1.2	
CV-VAV-1-5	PICV	REHEAT COIL	119 - WICKET	0.06	HOT WATER			15	15	1.2	
CV-VAV-1-6	PICV	REHEAT COIL	123 - WICKET	0.06	HOT WATER			15	15	1.2	
CV-VAV-1-7	PICV	REHEAT COIL	116 - OFFICE FORAGE	0.02	HOT WATER			15	15	1.2	
CV-VAV-1-8	PICV	REHEAT COIL	324 - FIRST AID	0.03	HOT WATER			15	15	1.2	
CV-VAV-1-9	PICV	REHEAT COIL	115 - LOCKER	0.03	HOT WATER			15	15	1.2	
CV-VAV-1-10	PICV	REHEAT COIL	305 - CORRIDOR	0.02	HOT WATER			15	15	1.2	
CV-VAV-1-11	PICV	REHEAT COIL	305 - CORRIDOR	0.02	HOT WATER			15	15	1.2	
CV-VAV-1-12	PICV	REHEAT COIL	306 - KITCHEN	0.03	HOT WATER			15	15	1.2	
CV-VAV-1-13	PICV	REHEAT COIL	303 - MAINTENANCE OFFICE STORAGE	0.02	HOT WATER			15	15	1.2	
CV-VAV-1-14	PICV	REHEAT COIL	303 - MAINTENANCE OFFICE STORAGE	0.02	HOT WATER			15	15	1.2	
CV-VAV-1-15	PICV	REHEAT COIL	307 - LIBRARY OPEN OFFICE	0.04	HOT WATER			15	15	1.2	
CV-VAV-1-16	PICV	REHEAT COIL	307 - LIBRARY OPEN OFFICE	0.02	HOT WATER			15	15	1.2	
CV-VAV-1-17	PICV	REHEAT COIL	214 - MEETING ROOM	0.04	HOT WATER			15	15	1.2	
CV-VAV-1-18	PICV	REHEAT COIL	202 - RECREATION ROOM	0.08	HOT WATER			15	15	1.2	
CV-VAV-1-19	PICV	REHEAT COIL	227 - SIGN UP ROOM	0.02	HOT WATER			15	15	1.2	
CV-VAV-1-20	PICV	REHEAT COIL	201 - OPERATORS LOUNGE	0.06	HOT WATER			15	15	1.2	
CV-VAV-1-21	PICV	REHEAT COIL	215 - CORRIDOR	0.05	HOT WATER			15	15	1.2	
CV-VAV-1-22	PICV	REHEAT COIL	216 - CONFERENCE ROOM	0.06	HOT WATER			15	15	1.2	
CV-VAV-1-23	PICV	REHEAT COIL	230 - BOARD/CLASS ROOM	0.04	HOT WATER			15	15	1.2	
CV-RP-1-1	PICV	RADIANT PANEL	102 - LUNCH ROOM	0.03	HOT WATER			20	15	1.2	
CV-RP-1-1	PICV	RADIANT PANEL	104, 105 - ASSISTANT DIVISION MANAGER	0.05	HOT WATER			20	15	1.2	
CV-RP-1-1	PICV	RADIANT PANEL	103 - DIVISION MANAGER	0.02	HOT WATER			20	15	1.2	
CV-RP-1-1	PICV	RADIANT PANEL	304 - SENIOR FOREPERSON	0.05	HOT WATER			20	15	1.2	
CV-RP-1-1	PICV	RADIANT PANEL	301, 302 - OPERATIONS MANAGER, ASSISTANT	0.05	HOT WATER			20	15	1.2	
CV-RP-1-1	PICV	RADIANT PANEL	307, 308, 309 - OFFICE	0.09	HOT WATER			20	15	1.2	
CV-RP-1-1	PICV	RADIANT PANEL	310 - FIREMAN IN OFFICE	0.06	HOT WATER			20	15	1.2	
CV-RP-1-1	PICV	RADIANT PANEL	231 - MINT LUNCH ROOM	0.13	HOT WATER			20	15	1.2	
CV-RP-1-1	PICV	RADIANT PANEL	201 - OPERATORS LOUNGE	0.21	HOT WATER			20	15	1.2	
CV-WF-1	PICV	WALL FIN	319 - MEN'S WASHROOM	0.02	HOT WATER			15	15	1.2	
CV-WF-2	PICV	WALL FIN	322 - WOMENS WASHROOM	0.01	HOT WATER			15	15	1.2	
CV-WF-3	PICV	WALL FIN	206 - VESTIBULE	0.01	HOT WATER			15	15	1.2	
CV-WF-4	PICV	WALL FIN	210 - MEN'S WASHROOM	0.03	HOT WATER			15	15	1.2	
CV-WF-5	PICV	WALL FIN	204 - VESTIBULE	0.01	HOT WATER			15	15	1.2	

NOTES:

1. PICV SHALL BE SIZED FOR LINE SIZE.
2. CONTRACTOR TO VERIFY CONTROL VALVE SCHEDULE WITH REFERENCE TO FLOOR PLANS AND HYDRONIC SCHEMATICS BEFORE ORDERING.

CEILING FAN SCHEDULE

TAG	LOCATION	SERVICE	SIZE DIA (mm)	MAX. RPM	POWER HP	DBA	ELECTRIC VPHHZ	PHASE	WEIGHT kg		
										L/s	M
CF-1	Maintenance Bay	SUPPLY AIR DE-STRATIFICATION	7315	55	2	55	575/3/60	3	185	1.23	
CF-2	Maintenance Bay	SUPPLY AIR DE-STRATIFICATION	7315	55	2	55	576/3/60	3	185	1.23	
CF-3	Maintenance Bay	SUPPLY AIR DE-STRATIFICATION	7315	55	2	55	575/3/60	3	185	1.23	
CF-4	Maintenance Bay	SUPPLY AIR DE-STRATIFICATION	7315	55	2	55	575/3/60	3	185	1.23	

NOTES:

1. DIGITAL WALL KEYPAD
2. C/W VARIABLE SPEED DRIVE
3. INTERFACE W/ BAS SYSTEM

TAG	TYPE	SERVICE	LOCATION	FLOW	MEDIUM	DESIGN P	PIPE LINE SIZE	CONTROL VALVE SIZE	NOTES		
										kPa	DIA. MM
CV-B-1	2-WAY, ON/OFF	B-1 HIGH TEMP HEATING RETURN	219 - BOILER ROOM		HOT WATER					15	15
CV-B-12	2-WAY, ON/OFF	B-1 LOW TEMP HEATING RETURN	219 - BOILER ROOM		HOT WATER					15	15
CV-B-2	2-WAY, ON/OFF	B-2 HIGH TEMP HEATING RETURN	219 - BOILER ROOM		HOT WATER					15	15
CV-B-22	2-WAY, ON/OFF	B-2 LOW TEMP HEATING RETURN	219 - BOILER ROOM		HOT WATER					15	15
FCU-1	PICCV	HEATING COIL	312 - CORRIDOR	0.0103	PROPYLENE GLYCOL 50%	15	15	2			
FCU-2	PICCV	HEATING COIL	127 - VESTIBULE	0.051	PROPYLENE GLYCOL 50%	15	15	2			
FCU-3	PICCV	HEATING COIL	118 - STARYWELL	0.051	PROPYLENE GLYCOL 50%	15	15	2			
FCU-4	PICCV	HEATING COIL	118 - STARYWELL	0.051	PROPYLENE GLYCOL 50%	15	15	2			
FCU-5	PICCV	HEATING COIL	316 - STARYWELL	0.051	PROPYLENE GLYCOL 50%	15	15	2			
FCU-6	PICCV	HEATING COIL	121 - STARYWELL	0.000	PROPYLENE GLYCOL 50%	15	15	2			
FCU-7	PICCV	HEATING COIL	121 - STARYWELL	0.051	PROPYLENE GLYCOL 50%	15	15	2			
FCU-8	PICCV	HEATING COIL	121 - STARYWELL	0.051	PROPYLENE GLYCOL 50%	15	15	2			
FCU-9	PICCV	HEATING COIL	125 - STARYWELL	0.051	PROPYLENE GLYCOL 50%	15	15	2			
FCU-10	PICCV	HEATING COIL	125 - VESTIBULE	0.051	PROPYLENE GLYCOL 50%	15	15	2			
FCU-11	PICCV	HEATING COIL	101 - VESTIBULE	0.051	PROPYLENE GLYCOL 50%	15	15	2			
FCU-12	PICCV	HEATING COIL	101 - VESTIBULE	0.051	PROPYLENE GLYCOL 50%	15	15	2			
FCU-13	PICCV	HEATING COIL	101 - VESTIBULE	0.051	PROPYLENE GLYCOL 50%	15	15	2			
CV-VAV-1	3-WAY, MOD. MIXING	VAV REHEATING SUPPLY MAIN	219 - BOILER ROOM	0.86	HOT WATER	22.5	32/32/40	25	1.2		
CV-VAV-1-1	PICV	REHEAT COIL	102 - LUNCH ROOM	0.02	HOT WATER			15	15	1.2	
CV-VAV-1-2	PICV	REHEAT COIL	103 - DIVISION MANAGER	0.03	HOT WATER			15	15	1.2	
CV-VAV-1-3	PICV	REHEAT COIL	103 - DIVISION MANAGER	0.02	HOT WATER			15	15	1.2	
CV-VAV-1-4	PICV	REHEAT COIL	106 - OPEN OFFICE	0.04	HOT WATER			15	15	1.2	
CV-VAV-1-5	PICV	REHEAT COIL	119 - WICKET	0.06	HOT WATER			15	15	1.2	
CV-VAV-1-6	PICV	REHEAT COIL	123 - WICKET	0.06	HOT WATER			15	15	1.2	
CV-VAV-1-7	PICV	REHEAT COIL	116 - OFFICE FORAGE	0.02	HOT WATER			15	15	1.2	
CV-VAV-1-8	PICV	REHEAT COIL	324 - FIRST AID	0.03	HOT WATER			15	15	1.2	
CV-VAV-1-9	PICV	REHEAT COIL	115 - LOCKER	0.03	HOT WATER			15	15	1.2	
CV-VAV-1-10	PICV	REHEAT COIL	305 - CORRIDOR	0.02	HOT WATER			15	15	1.2	
CV-VAV-1-11	PICV	REHEAT COIL	305 - CORRIDOR	0.02	HOT WATER			15	15	1.2	
CV-VAV-1-12	PICV	REHEAT COIL	306 - KITCHEN	0.03	HOT WATER			15	15	1.2	
CV-VAV-1-13	PICV	REHEAT COIL	303 - MAINTENANCE OFFICE STORAGE	0.02	HOT WATER			15	15	1.2	
CV-VAV-1-14	PICV	REHEAT COIL	303 - MAINTENANCE OFFICE STORAGE	0.02	HOT WATER			15	15	1.2	
CV-VAV-1-15	PICV	REHEAT COIL	307 - LIBRARY OPEN OFFICE	0.04	HOT WATER						

UNIT HEATER SCHEDULE												UNIT HEATER SCHEDULE																				
TAG	SERVICE	LOCATION	TYPE	HEATING CAPACITY			GAS SUPPLY PRESSURE			UNIT CONFIGURATION			MOUNTING HEIGHT	ELECTRIC INFORMATION	CONTROL VOLTS	WEIGHT	NOTE	TAG	SERVICE	LOCATION	TYPE	HEATING CAPACITY			GAS SUPPLY PRESSURE			MOUNTING HEIGHT	ELECTRIC INFORMATION	CONTROL VOLTS	WEIGHT	NOTE
				INPUT KW	OUTPUT T Kpa	KW	V	PH	NZ	INPUT KW	OUTPUT T Kpa	KW	V	PH	NZ																	
UH-1	STORAGE BAY	STORAGE BAY	GAS FIRED	87.9	73	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	11	20860/1	24	122	12	UH-71	DE-GREASE BAY	DE-GREASE BAY	GAS FIRED	73.3	60.8	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	7.5	20860/1	24	98	1.2			
UH-2	STORAGE BAY	STORAGE BAY	GAS FIRED	87.9	73	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	11	20860/1	24	122	12	UH-72	MANEUVERING BAY	MANEUVERING BAY	GAS FIRED	73.3	60.8	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	7.5	20860/1	24	98	1.2			
UH-3	STORAGE BAY	STORAGE BAY	GAS FIRED	87.9	73	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	11	20860/1	24	122	12	UH-73	MANEUVERING BAY	MANEUVERING BAY	GAS FIRED	73.3	60.8	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	7.5	20860/1	24	98	1.2			
UH-4	STORAGE BAY	STORAGE BAY	GAS FIRED	87.9	73	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	11	20860/1	24	122	12	UH-74	MAINTENANCE BAYS	MAINTENANCE BAYS	GAS FIRED	44	36.5	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	3.8	20860/1	24	78	1.2			
UH-5	STORAGE BAY	STORAGE BAY	GAS FIRED	87.9	73	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	11	20860/1	24	122	12	UH-75	MAINTENANCE BAYS	MAINTENANCE BAYS	GAS FIRED	44	36.5	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	3.8	20860/1	24	78	1.2			
UH-6	STORAGE BAY	STORAGE BAY	GAS FIRED	87.9	73	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	11	20860/1	24	122	12	UH-76	MAINTENANCE BAYS	MAINTENANCE BAYS	GAS FIRED	44	36.5	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	3.8	20860/1	24	78	1.2			
UH-7	STORAGE BAY	STORAGE BAY	GAS FIRED	87.9	73	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	11	20860/1	24	122	12	UH-77	MAINTENANCE BAYS	MAINTENANCE BAYS	GAS FIRED	44	36.5	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	3.8	20860/1	24	78	1.2			
UH-8	STORAGE BAY	STORAGE BAY	GAS FIRED	87.9	73	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	11	20860/1	24	122	12	UH-78	MAINTENANCE BAYS	MAINTENANCE BAYS	GAS FIRED	44	36.5	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	3.8	20860/1	24	78	1.2			
UH-9	STORAGE BAY	STORAGE BAY	GAS FIRED	87.9	73	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	11	20860/1	24	122	12	UH-79	MAINTENANCE BAYS	MAINTENANCE BAYS	GAS FIRED	44	36.5	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	3.8	20860/1	24	78	1.2			
UH-10	STORAGE BAY	STORAGE BAY	GAS FIRED	87.9	73	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	11	20860/1	24	122	12	UH-80	STORAGE BAY	STORAGE BAY	GAS FIRED	44	36.5	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	3.8	20860/1	24	78	1.2			
UH-11	STORAGE BAY	STORAGE BAY	GAS FIRED	87.9	73	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	11	20860/1	24	122	12	UH-81	STORAGE BAY	STORAGE BAY	GAS FIRED	44	36.5	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	3.8	20860/1	24	78	1.2			
UH-12	STORAGE BAY	STORAGE BAY	GAS FIRED	87.9	73	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	11	20860/1	24	122	12	UH-82	TOUCH UP BAY	TOUCH UP BAY	FORCED AIR ELEC	25	25	-	-	CEILING MOUNTED	5	-	57560/3	24	142	3.4			
UH-13	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6	48.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	4.6	20860/1	24	85	12	UH-83	TOUCH UP BAY	TOUCH UP BAY	FORCED AIR ELEC	25	25	-	-	CEILING MOUNTED	5	-	57560/3	24	142	3.4			
UH-14	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6	48.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	4.6	20860/1	24	85	12	UH-84	BODY SHOP	BODY SHOP	GAS FIRED	65.9	54.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	7.5	20860/1	24	93	1.2			
UH-15	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6	48.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	4.6	20860/1	24	85	12	UH-85	BODY SHOP	BODY SHOP	GAS FIRED	65.9	54.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	7.5	20860/1	24	93	1.2			
UH-16	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6	48.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	4.6	20860/1	24	85	12	UH-86	STOCKROOM524	STOCKROOM524	GAS FIRED	17.6	14.6	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	2.4	20860/1	24	31	1.2			
UH-17	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6	48.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	4.6	20860/1	24	85	12	UH-87	VESTIBULE 525	VESTIBULE 525	GAS FIRED	17.6	14.6	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	2.4	20860/1	24	31	1.2			
UH-18	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6	48.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	4.6	20860/1	24	85	12	UH-88	VESTIBULE 525	VESTIBULE 525	GAS FIRED	17.6	14.6	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	2.4	20860/1	24	31	1.2			
UH-19	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6	48.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	4.6	20860/1	24	85	12	UH-89	PUMP STORAGE	PUMP STORAGE	FORCED AIR ELEC	5	5	-	-	CEILING MOUNTED	5	-	20860/3	24	142	4			
UH-20	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6	48.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	4.6	20860/1	24	85	12	UH-90	HOT WATER ROOM	HOT WATER ROOM	FORCED AIR ELEC	5	5	-	-	CEILING MOUNTED	5	-	20860/3	24	142	4			
UH-21	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6	48.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	4.6	20860/1	24	85	12	UH-91	RECYCLE AREA	RECYCLE AREA	FORCED AIR ELEC	5	5	-	-	CEILING MOUNTED	5	-	20860/3	24	142	4			
UH-22	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6	48.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	4.6	20860/1	24	85	12	UH-92	RECYCLE AREA	RECYCLE AREA	FORCED AIR ELEC	5	5	-	-	CEILING MOUNTED	5	-	20860/3	24	142	4			
UH-23	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6	48.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	4.6	20860/1	24	85	12	UH-93	SPRINKLER ROOM	SPRINKLER ROOM	FORCED AIR ELEC	5	5	-	-	CEILING MOUNTED	5	-	20860/3	24	142	4			
UH-24	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6	48.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	4.6	20860/1	24	85	12	UH-94	SPRINKLER ROOM	SPRINKLER ROOM	FORCED AIR ELEC	5	5	-	-	CEILING MOUNTED	5	-	20860/3	24	142	4			
UH-25	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6	48.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	4.6	20860/1	24	85	12	UH-95	MECH RM 518	MECH RM 518	FORCED AIR ELEC	5	5	-	-	CEILING MOUNTED	5	-	20860/3	24	142	4			
UH-26	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6	48.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	4.6	20860/1	24	85	12	UH-96	PLANT MILLRIGHTS	PLANT MILLRIGHTS	FORCED AIR ELEC	5	5	-	-	CEILING MOUNTED	5	-	20860/3	24	142	4			
UH-27	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6	48.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	4.6	20860/1	24	85	12	UH-97	HAZMAT 1	HAZMAT 1	FORCED AIR ELEC	5	5	-	-	CEILING MOUNTED	5	-	20860/3	24	142	3.4			
UH-28	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6	48.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	4.6	20860/1	24	85	12	UH-98	HAZMAT 2	HAZMAT 2	FORCED AIR ELEC	5	5	-	-	CEILING MOUNTED	5	-	20860/3	24	142	3.4			
UH-29	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6	48.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	4.6	20860/1	24	85	12	UH-99	BOILER ROOM219	BOILER ROOM	FORCED AIR ELEC	5	5	-	-	CEILING MOUNTED	5	-	20860/3	24	142	4			
UH-30	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6	48.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	4.6	20860/1	24	85	12	UH-100	SPLINKER ROOM 218	SPLINKER ROOM	FORCED AIR ELEC	5	5	-	-	CEILING MOUNTED	5	-	20860/3	24	142	4			
UH-31	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6	48.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	4.6	20860/1	24	85	12	NOTES:																	
UH-32	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6	48.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	4.6	20860/1	24	85	12	1. C/W DOWNTURN NOZZLE AT 41° ANGLE																	
UH-33	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6	48.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	4.6	20860/1	24	85	12	2. C/W VERTICAL/COMBINATION AIR KIT																	
UH-34	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6	48.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	4.6	20860/1	24	85	12	3. EXPLOSION PROOF																	
UH-35	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6	48.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	4.6	20860/1	24	85	12	4. HORIZONTAL DISCHARGE																	
UH-36	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6	48.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	4.6	20860/1	24	85	12																		
UH-37	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6	48.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	4.6	20860/1	24	85	12																		
UH-38	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6	48.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	4.6	20860/1	24	85	12																		
UH-39	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6	48.7	174	-3.48	SEPARATED COMBUSTION AIR / VENT	5	4.6	20860/1	24	85	12																		
UH-40	STORAGE BAY	STORAGE BAY	GAS FIRED	58.6																												

FAN SCHEDULE

TAG	SERVICE	LOCATION	TYPE	FLOW	ESP	FAN RPM	OPERATING POWER	MOTOR			SOUND DATA	WEIGHT	NOTES	
				L/S	Ps	HP	HP	DRIVE TYPE	VPH/HZ	dBA	KG			
TB-1	SMALL SERVING BAY	SMALL SERVING BAY	TUBE AXIAL	9496	0	1725	2.76	3	1725	DIRECT	575/3/60	91	110	1.3
TB-2	SMALL SERVING BAY	SMALL SERVING BAY	TUBE AXIAL	9496	0	1725	2.76	3	1725	DIRECT	575/3/60	91	110	1.3
TB-3	SMALL SERVING BAY	SMALL SERVING BAY	TUBE AXIAL	9496	0	1725	2.76	3	1725	DIRECT	575/3/60	91	110	1.3
TB-4	SMALL SERVING BAY	SMALL SERVING BAY	TUBE AXIAL	9496	0	1725	2.76	3	1725	DIRECT	575/3/60	91	110	1.3
SF-5	BOILER ROOM	CENTRIFUGAL INLINE	118	64	1550	0.03	1/30	1550	DIRECT	115/160	48.0	13.0	1	
SF-6	COMPRESSOR ROOM	ROOF	LOUVERED ROOF SUPPLY	4009	127	2405	4.97	5	1725	3ELT	575/3/60	82.0	313.0	1.6
EF-1	VEHICLE EXHAUST	ROOF (articulated bay)	CENTRIFUGAL UTILITY	1509	1194	2277	3.85	5	1725	3ELT	575/3/60	74	126	1.35
EF-2	VEHICLE EXHAUST	ROOF (articulated bay)	CENTRIFUGAL UTILITY	1509	1194	2277	3.85	5	1725	3ELT	575/3/60	74	126	1.35
EF-3	VEHICLE EXHAUST	ROOF (articulated bay)	CENTRIFUGAL UTILITY	755	1194	3349	2.04	2	1725	3ELT	575/3/60	73	78	1.35
EF-4	VEHICLE EXHAUST	ROOF (stand. Maint. bay)	CENTRIFUGAL UTILITY	1509	1194	2277	3.85	5	1725	3ELT	575/3/60	74	126	1.35
EF-5	VEHICLE EXHAUST	ROOF (stand. Maint. bay)	CENTRIFUGAL UTILITY	1132	1194	2839	2.82	3	1725	3ELT	575/3/60	75	105	1.35
EF-6	PAINT BOOTH	ROOF	CENTRIFUGAL UTILITY	19811	508	701	28.08	30	1725	3ELT	575/3/60	82	994	1.3
EF-7	BATTERY STORAGE	ROOF	CENTRIFUGAL UTILITY	613	191	1975	0.44	1/2	1725	3ELT	115/160	68	68	1.2
EF-8	HAZARD 1	ROOF	CENTRIFUGAL UTILITY	47	127	1273	0.06	1/4	1725	3ELT	115/160	53	64	1.24
EF-9	HAZARD 2	ROOF	CENTRIFUGAL UTILITY	47	127	1273	0.06	1/4	1725	3ELT	115/160	53	64	1.24
EF-10	MECH ROOM 518	ROOF	CENTRIFUGAL ROOF	142	127	1155	0.08	1/6	1725	3ELT	115/160	50	26	1
EF-11	MILLRIGHTS SHOP	ROOF	CENTRIFUGAL ROOF	118	127	1562	0.12	1/6	1725	3ELT	115/160	57	26	1
EF-12	RECYCLE WASH	ROOF	CENTRIFUGAL ROOF	436	127	1563	0.22	1/4	1725	3ELT	115/160	61	26	1
EF-13	WATER TANK	ROOF	CENTRIFUGAL ROOF	101	127	1444	0.1	1/6	1725	3ELT	115/160	54	26	1
EF-14	PUMP RM	ROOF	CENTRIFUGAL ROOF	101	127	1444	0.1	1/6	1725	3ELT	115/160	54	26	1
EF-16	SPRINKLER ROOM	ROOF	CENTRIFUGAL ROOF	290	127	1556	0.17	1/6	1725	3ELT	115/160	59	26	1
EF-17	WASH FLUR COLLECTION	ROOF	CENTRIFUGAL ROOF	137	165	1273	0.09	1/6	1725	3ELT	115/160	52	26	1
EF-18	COMPRESSOR ROOM	ROOF	CENTRIFUGAL ROOF	4009	127	746	2.22	3	1725	3ELT	575/3/60	68	80	1
EF-19	PAINT PREP AREA 400	ROOF	CENTRIFUGAL UTILITY	377	191	2162	0.33	1/3	1725	3ELT	115/160	66	65.4	1.3
EF-20	PAINT MX RM518	ROOF	CENTRIFUGAL UTILITY	129	191	1498	0.15	1/4	1725	3ELT	115/160	58	44	1,2,7,8,9
EF-21	CIS CONTRAL AREA EXHAUST	ROOF	CENTRIFUGAL INLINE	129	191	1542	0.17	1/4	1725	3ELT	115/160	60	37.2	1,2,7,8,9
EF-22	L1 OFFICE WIR EXHAUST	ROOF	CENTRIFUGAL ROOF	152	191	1542	0.17	1/4	1725	3ELT	115/160	51	25.9	1
EF-23	SE OFFICE WASHROOM	ROOF	CENTRIFUGAL UTILITY	377	1067	3350	1.1	1 1/2	1725	3ELT	575/3/60	72	74.5	1,3,5
EF-24	TELECOM ROOM 714	ROOF	CENTRIFUGAL ROOF	110	127	1502	0.12	1/6	1725	3CLT	112/160	57	25.9	1
EF-25	TELECOM ROOM 809	ROOF	CENTRIFUGAL ROOF	118	127	1562	0.12	1/6	1725	3ELT	115/160	57	25.9	1
EF-26	SPRINKLER ROOM 218	SPRINKLER ROOM	CENTRIFUGAL INLINE	118	64	1550	0.03	1/30	1550	DIRECT	115/160	48.0	13.0	1
WEF-1	BODY SHOP	BODY SHOP	CENTRIFUGAL FAN	222	1300	-	1.2	1.5	3460	DIRECT	480/3/60	-	17	1,4,10
WEF-2	BODY SHOP	BODY SHOP	CENTRIFUGAL FAN	222	1300	-	1.2	1.5	3460	DIRECT	480/3/60	-	17	1,4,10

NOTES:

1. MOTOR W/ CSA APPROVAL
2. ALUMINUM WHEEL MATERIAL
3. CORROSION RESISTANT GALVANIZED STEEL HOUSING
4. SPARK PROOF CONSTRUCTION AND MOTOR OUT OF AIR STREAM
5. OPERATION ON VFD
6. 50MM WASHABLE ALUMINUM FILTER
7. CW BACKDRAFT DAMPER
8. CW MOTOR COVER
9. SPRING HANGING ISOLATORS & BRACKETS

GAS-FIRED INFRA RAD HEATERS SCHEDULE

TAG	SERVICE	TYPE	HEATING TUBE				REFLECTOR	TYP. MOUNTING HEIGHT	TYP. MOUNTING ANGLE	SURFACE TEMPERATURE	SELECTION CRITERIA			TSTAT	ELECTRIC INFORMATION			CONTROL		WEIGHT	NOTE				
			MATERIAL	RADIANT Emitter	NO. OF BAFFLES	LENGTH					INPUT KW	GAS PRESSURE kPa	HEATING COMBUSTION AIR INTAKE DIA.	FLUE VENT TYPE	BURNER LOCATION DIA.	TYPE	MOTOR SIZE	MOTOR SPEED	FLA TOTAL	VOLTAGE	INTERLOCK TYPE	PHYSICAL BACS	CONTROL VOLTS		
IRH-1	REPAIR BAY	HIGH-INTENSITY INFRARED	-	-	-	15.8	ALUMINUM	NO	5.3	20	904	13	1.74 - 348	-	-	-	YES	-	-	0.48	24/160	NO	YES	24	1,2,3,4,5,6
IRH-2	REPAIR BAY	HIGH-INTENSITY INFRARED	-	-	-	15.8	ALUMINUM	NO	5.3	20	904	13	1.74 - 348	-	-	-	YES	-	-	0.48	24/160	NO	YES	24	1,2,3,4,5,6
IRH-3	REPAIR BAY	HIGH-INTENSITY INFRARED	-	-	-	15.8	ALUMINUM	NO	6.3	20	904	13	1.74 - 348	-	-	-	YES	-	-	0.48	24/160	NO	YES	24	1,2,3,4,5,6
IRH-4	REPAIR BAY	HIGH-INTENSITY INFRARED	-	-	-	15.8	ALUMINUM	NO	5.3	20	904	13	1.74 - 348	-	-	-	YES	-	-	0.48	24/160	NO	YES	24	1,2,3,4,5,6
IRH-5	REPAIR BAY	HIGH-INTENSITY INFRARED	-	-	-	15.8	ALUMINUM	NO	5.3	20	904	13	1.74 - 348	-	-	-	YES	-	-	0.48	24/160	NO	YES	24	1,2,3,4,5,6
IRH-6	REPAIR BAY	HIGH-INTENSITY INFRARED	-	-	-	15.8	ALUMINUM	NO	5.3	20	904	13	1.74 - 348	-	-	-	YES	-	-	0.48	24/160	NO	YES	24	1,2,3,4,5,6
IRH-7	REPAIR BAY	HIGH-INTENSITY INFRARED	-	-	-	15.8	ALUMINUM	NO	5.3	20	904	13	1.74 - 348	-	-	-	YES	-	-	0.48	24/160	NO	YES	24	1,2,3,4,5,6
IRH-8	REPAIR BAY	HIGH-INTENSITY INFRARED	-	-	-	15.8	ALUMINUM	NO	5.3	20	904	13	1.74 - 348	-	-	-	YES	-	-	0.48	24/160	NO	YES	24	1,2,3,4,5,6
IRH-9	DEGREASE ROOM LOW-INTENSITY INFRARED	SS. S.S.	4	15418	4.8	S.S.	YES	4.9	0	-	36.6	1.74 - 348	100	100	S.S.	-	YES	-	-	4.8	115/160	NO	NO	115	1,2,3,4,5,6
IRH-10	DEGREASE ROOM LOW-INTENSITY INFRARED	SS. S.S.	4	15418	4.8	S.S.	YES	4.9	0	-	36.6	1.74 - 348	100	100	S.S.	-	YES	-	-	4.8	115/160	NO	NO	115	1,2,3,4,5,6

PUMP SCHEDULE

TAG	SERVICE	LOCATION	TYPE	FLOW	HEAD	FLUID	POWER	POWER	RPM	MOTOR	VPH/HZ	NOTES
				l/s	kPa	HP	W					
P-1	B-1	BOILER ROOM 219	IN-LINE	2.30	128	WATER	0.58	1.0	1725	575/3/60		
P-2	B-2	BOILER ROOM 219	IN-LINE	2.30	128	WATER	0.58	1.0	1725	575/3/60		
P-3	REHEAT COIL	BOILER ROOM 219	IN-LINE	1.33	128	WATER	0.49	1.0	1725	575/3/60		
P-4	REHEAT COIL	BOILER ROOM 219	IN-LINE	1.33	128	WATER	0.49	1.0	1725	575/3/60		

NOTES:

1. HIGH EFFICIENCY CONDENSING S/S HEAT EXCHANGER
2. 5.1 TURNDOWN
3. SEALED COMBUSTION CHAMBER
4. PRE-MIX STAINLESS STEEL BURNER
5. DIRECT VENTING AIR INTAKE AND FLUE DISCHARGE PIPE PACKAGE

FILE: STN-811_HDR.dwg

DRAWING No. G85-314-N565

SHEET No.

SHEET No.

SCOPE REVIEW
DRAWING
NOT FOR CONSTRUCTION

Stantec HDR

McNICOLL BUS GARAGE
H.V.A.C
SCHEDULES

Sheet 6 of 7

Fix Date: 08-27-2014
JFC

Doc. No. G85-314-M565 Sheet No.

AIR CURTAIN SCHEDULE

TAG	SERVICE	SELECTION CRITERIA					OPERATING POINT	ELECTRICAL DATA	EQUIPMENT INTERLOCKS	CONTROL	WEIGHT	REMARKS										
		NOZZLE	CURTAIN	DOOR SIZE	AR	FAN																
		WIDTH	FLOW	MAX. VEL.	Avg. VEL.	CORE VEL.	DIST. FROM NOZZ.	WIDTH	HEIGHT	dB(A) AT 3.0 m	FLW U/s	SPEED rpm	POWER Kw	VOLTAGE Kv	PHYSICAL INTERLOCKS	Kg						
ACR-1	AIR CURTAN	CENTRIFUGAL	DIRECT	FRONT INTAKE BOTTOM DISCHARGE	3658	6164	22.9	15.6	6.37	3.96	4.2	4.3	68	6164	1160	-	5.59	600/360	YES	-	361	1,2,3,4,5,6
ACR-2	AIR CURTAN	CENTRIFUGAL	DIRECT	FRONT INTAKE BOTTOM DISCHARGE	3658	6164	22.9	15.6	6.37	3.96	4.2	4.3	68	6164	1160	-	5.59	600/360	YES	-	361	1,2,3,4,5,6
ACR-3	AIR CURTAN	CENTRIFUGAL	DIRECT	FRONT INTAKE BOTTOM DISCHARGE	3658	6164	22.9	15.6	6.37	3.96	4.2	4.3	68	6164	1160	-	5.59	600/360	YES	-	361	1,2,3,4,5,6
ACR-4	AIR CURTAN	CENTRIFUGAL	DIRECT	FRONT INTAKE BOTTOM DISCHARGE	3658	6164	22.9	15.6	6.37	3.96	4.2	4.3	68	6164	1160	-	5.59	600/360	YES	-	361	1,2,3,4,5,6
ACR-5	AIR CURTAN	CENTRIFUGAL	DIRECT	FRONT INTAKE BOTTOM DISCHARGE	3658	6164	22.9	15.6	6.37	3.96	4.2	4.3	68	6164	1160	-	5.59	600/360	YES	-	361	1,2,3,4,5,6
ACR-6	AIR CURTAN	CENTRIFUGAL	DIRECT	FRONT INTAKE BOTTOM DISCHARGE	3658	6164	22.9	15.6	6.37	3.96	4.2	4.3	68	6164	1160	-	5.59	600/360	YES	-	361	1,2,3,4,5,6
ACR-7	AIR CURTAN	CENTRIFUGAL	DIRECT	FRONT INTAKE BOTTOM DISCHARGE	3658	6164	22.9	15.6	6.37	3.96	4.2	4.3	68	6164	1160	-	5.59	600/360	YES	-	361	1,2,3,4,5,6
ACR-8	AIR CURTAN	CENTRIFUGAL	DIRECT	FRONT INTAKE BOTTOM DISCHARGE	3658	6164	22.9	15.6	6.37	3.96	4.2	4.3	68	6164	1160	-	5.59	600/360	YES	-	361	1,2,3,4,5,6

NOTES:

1. CURTAIN VELOCITY AT DISTANCE FROM DISCHARGE NOZZLE
2. ADJUST MOTOR SIZE TO SUIT FINAL SELECTION FOR LISTED CRITERIA
3. INCLUDES ALLOWANCE FOR DUCT ARRANGEMENT SYSTEM EFFECTS
4. FINAL MOTOR ELECTRICAL DATA TO BE COORDINATED WITH MOTOR STARTER
5. INVERTER DUTY MOTOR, SUIT FOR VFD.
6. REFER TO SPECIFICATION FOR FURTHER DETAILS

SPLIT AIR CONDITIONERS SCHEDULE

TAG	SERVICE	LOCATION		TYPE	COOLING CAPACITY (kW)	REFRIGERANT	DESIGN AMBIENT (°C)	ELECTRIC			REMARKS
		OUTDOOR	INDOOR					OUTDOOR	INDOOR	MCA	
AC-ID-1	AC-ID-1	ELECT/MCC 02 (229)	ROOF	ELECT/MCC 02 (229)	7.03	R410a	-10 ~ 46			208/160	
AC-ID-2	AC-ID-2	TELECOM ROOM 03 (228)	ROOF	TELECOM ROOM 03 (228)	7.03	R410a	-10 ~ 46			208/160	
AC-ID-3	AC-ID-3	LAN R/COM (220)	ROOF	LAN ROOM (220)	7.03	R410a	-10 ~ 46			208/160	
AC-ID-4	AC-ID-4	LAN R/COM 02 (808)	ROOF	LAN ROOM 02 (808)	3.52	R410a	-10 ~ 46			208/160	
AC-ID-5	AC-ID-5	MCC ROOM (807)	ROOF	MCC ROOM (807)	7.03	R410a	-10 ~ 46			208/160	
AC-ID-6	AC-ID-6	MAIN ELECTRICAL RM (710)	ROOF	MAIN ELECTRICAL RM (710)	10.6	R410a	-10 ~ 46			208/160	
AC-ID-7	AC-ID-7	MAIN TEL. ROOM (713)	ROOF	MAIN TEL. ROOM (713)	7.03	R410a	-10 ~ 46			208/160	
AC-ID-8.1	AC-ID-8.1	UPS (7'1)	ROOF	UPS (711)	10.6	R410a	-10 ~ 46			208/160	DUTY/ STAND-BY
AC-ID-8.2	AC-ID-8.2	IIPS (7'1)	ROOF	IIPS (711)	10.6	R410a	-10 ~ 46			208/160	DUTY/ STAND-BY
AC-ID-9.1	AC-ID-9.1	ELEVATOR MACHINE ROOM (241)	ROOF	ELEVATOR MACHINE ROOM (241)	7.03	R410a	-10 ~ 46			208/160	DUTY/ STAND-BY
AC-ID-9.2	AC-ID-9.2	ELEVATOR MACHINE ROOM (241)	ROOF	ELEVATOR MACHINE ROOM (241)	7.03	R410a	-10 ~ 46			208/160	DUTY/ STAND-BY
AC-ID-10	AC-ID-10	MCC ROOM (517)	ROOF	MCC ROOM (517)	10.6	R410a	-10 ~ 46	20	1.5HP	208/160	
AC-ID-11	AC-ID-11	MCC ROOM (516)	ROOF	MCC ROOM (516)	3.52	R410a	-10 ~ 46	13	1	208/160	
AC-ID-12	AC-ID-12	MCC ROOM (515)	ROOF	MCC ROOM (515)	3.52	R410a	-10 ~ 46	13	1	208/160	
AC-ID-13	AC-ID-13	STOCK ROOM SUPERVISOR (527)	ROOF	STOCK ROOM SUPERVISOR (527)	3.52	R410a	-10 ~ 46	13	1	208/160	
AC-ID-14	AC-ID-14	SENIOR STORE PERSONS OFFICE (526)	ROOF	SENIOR STORE PERSONS OFFICE (526)	3.52	R410a	-10 ~ 46	13	1	208/160	

NOTES:

1. DUCTED CEILING-CONCEALED
2. WIRED REMOTED CONTROLLER
3. C/W PRE-CARGED REFRIGERANT PIPE, CONFIRM PIPE LENGTH PRIOR TO ORDERING

PORTABLE WELDING EXHAUST SYSTEM SCHEDULE

TAG	LOCATION	TYPE	AIR FLOW U/s	PRESSURE Kpa	HOSE LENGTH mm	HOSE CONNECTION mm Dia	FILTER TYPE	TABLE DIMENSION H x W x D mm	MOTOR 15 A	ELECTRICAL VPHHZ	NOISE DBA	NOTES
PWEX-1	BODY SHOP	SINGLE EXTRACTION	26 ~ 54	18 ~ 23	24mm	45	POLYESTER	340 X 680 X 400	15 A	115/160	74	1,2,3,4,5
PWEX-2	BODY SHOP	SINGLE EXTRACTION	26 ~ 54	18 ~ 23	2400	45	POLYESTER	340 X 680 X 400	15 A	115/160	74	1,2,3,4,5
PWEX-3	BODY SHOP	SINGLE EXTRACTION	566	1.3	3000		CARTRIDGE, SPARK RESISTANT	978 X 1252 X 921	3 HP, 8.4A	208/3/60	75	4,5,6,7,9
PWEX-4	BODY SHOP	SINGLE EXTRACTION	566	1.3	3000		CARTRIDGE, SPARK RESISTANT	978 X 1252 X 921	3 HP, 8.4A	208/3/60	75	4,5,6,7,9

NOTES:

1. ROTARY AIR JET SYSTEM FOR FILTER CLEAN USING COMPRESSED AIR
2. AUTOMATIC START/STOP SENSOR TO PROVIDE EXTRACTION ONLY WHEN NEEDED
3. ACCESSORIES: TB
4. COMPRESSED AIR PROVIDED BY OTHERS
5. VIBRA-PULSE FILTER CLEAN
6. PRESSURE GAUGE KIT INDICATES FILTER CHANGES
7. SILENCER
8. SELF-CLEANING MECHANISM
9. HEPA FILTER (99.97%)



DESIGNED V. JOHN 28140615
 DRAWN S. CHENG 28140615
 CHECKED P. MARSH 28140615
 APPROVED _____

McNICOLL BUS GARAGE

H.V.A.C
SCHEDULES

Sheet 7 of 7



Doc. No. GBS-314-M566 Sheet No.

This page intentionally left blank
for 2-sided printing purposes


Appendix D

This page intentionally left blank
for 2-sided printing purposes



TRAFFIC IMPACT STUDY
TTC McNICOLL BUS GARAGE
CITY OF TORONTO

FIGURE 4-1 – FUTURE BACKGROUND TRAFFIC VOLUMES, A.M. & P.M. PEAK HOUR



LEGEND

- 95 (95) - Traffic Volume AM (PM)
- Stop Sign
- Traffic Signal

ORNAMENT - Sound Power Emissions & Source Heights

Ontario Road Noise Analysis Method for Environment and Transportation

Roadway	Time Period	% AADT ^[1]	Speed (kph)	Period (h)	Total Traffic Volumes ^[2]	Auto ^[1] %	Med ^[1] %	Hvy ^[1] %	Auto	Med	Heavy	Road Gradient (%)	Cadna/A Ground Absorption G	PWL (dBA)	Source Height, s (m)
Kennedy	AADT		60	24	28890	95.8%	2.3%	2.0%	27668	654	568	0	0.00	83.7	1.2
Kennedy	min 3am	0.38%	60	1	109	95.8%	2.3%	2.0%	105	2	2	0	0.00	73.3	1.2
Kennedy	min 6am	1.95%	60	1	564	95.8%	2.3%	2.0%	541	13	11	0	0.00	80.4	1.2
Kennedy	min day	4.30%	60	1	1244	95.8%	2.3%	2.0%	1191	28	24	0	0.00	83.8	1.2
Redlea	AADT		50	24	16840	95.8%	2.3%	2.0%	16127	381	331	0	0.00	79.6	1.2
Redlea	min 3am	0.38%	50	1	64	95.8%	2.3%	2.0%	61	1	1	0	0.00	69.2	1.2
Redlea	min 6am	1.95%	50	1	329	95.8%	2.3%	2.0%	315	7	6	0	0.00	76.4	1.2
Redlea	min day	4.30%	50	1	725	95.8%	2.3%	2.0%	694	16	14	0	0.00	79.8	1.2
McNicoll	AADT		50	24	22800	95.8%	2.3%	2.0%	21835	516	448	0	0.00	81.0	1.2
McNicoll	min 3am	0.38%	50	1	86	95.8%	2.3%	2.0%	83	2	2	0	0.00	70.6	1.2
McNicoll	min 6am	1.95%	50	1	445	95.8%	2.3%	2.0%	427	10	9	0	0.00	77.7	1.2
McNicoll	min day	4.30%	50	1	981	95.8%	2.3%	2.0%	940	22	19	0	0.00	81.1	1.2
Midland	AADT		50	24	16560	95.8%	2.3%	2.0%	15859	375	326	0	0.00	79.6	1.2
Midland	min 3am	0.38%	50	1	63	95.8%	2.3%	2.0%	60	1	1	0	0.00	69.2	1.2
Midland	min 6am	1.95%	50	1	324	95.8%	2.3%	2.0%	310	7	6	0	0.00	76.3	1.2
Midland	min day	4.30%	50	1	713	95.8%	2.3%	2.0%	683	16	14	0	0.00	79.7	1.2

Note: [1] from avg Toronto Traffic data

[2] from URS TTC McNicoll Bus Garage Traffic Impact Study (assuming AADT = Peak PM * 10)

Example Change Assessment

ORNAMENT - Sound Level Emissions Calculations

Ontario Road Noise Analysis Method for Environment and Transportation

Roadway	Time Period	% AADT ^[1]	Speed (kph)	Period (h)	Total Traffic Volumes ^[2]	Auto ^[1] %	Med ^[1] %	Hvy ^[1] %	Auto	Med	Heavy	Road Gradient (%)	Reference Leq (dBA)
Redlea	AADT		50	24	16840	95.8%	2.3%	2.0%	16127	381	331	0	64.6
Redlea	day	90%	50	16	15156	95.8%	2.3%	2.0%	14515	343	298	0	65.9
Buses	TOTAL Movements (220 buses)		50	24	591	0.0%	100.0%	0.0%	0	591	0	0	57.7
Buses	day		50	16	305	0.0%	100.0%	0.0%	0	305	0	0	56.6

Note: [1] from avg Toronto Traffic data

[2] from URS TTC McNicoll Bus Garage Traffic Impact Study (assuming AADT = Peak PM * 10)

INCREASE IN NOISE FROM REDLEA

24hr 0.8 dB
day 0.5 dB

Comparison of STAMSON and Cadna/A Modelling

Cadna/A Receptor Location

X 17636747.8
Y 4852541.8
Z 12.5

Time	Modelled Traffic Noise (dBA)	
	STAMSON	Cadna/A
Daytime Min	64	63
3am	53	53
6am	61	60

STAMSON 5.0 NORMAL REPORT Date: 10-11-2014 15:57:05
MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: NE_day.te Time Period: 1 hours
Description:

Road data, segment # 1: Redlea

Car traffic volume : 694 veh/TimePeriod
Medium truck volume : 16 veh/TimePeriod
Heavy truck volume : 14 veh/TimePeriod
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)

Data for Segment # 1: Redlea

Angle1 Angle2 : -90.00 deg 75.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0
Surface : 1 (Absorptive ground surface)
Receiver source distance : 15.00 m
Receiver height : 12.50 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00

Road data, segment # 2: McNicoll

Car traffic volume : 940 veh/TimePeriod
Medium truck volume : 22 veh/TimePeriod
Heavy truck volume : 19 veh/TimePeriod
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)

Data for Segment # 2: McNicoll

Angle1 Angle2 : -90.00 deg 0.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 64.00 m
Receiver height : 12.50 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00

Results segment # 1: Redlea

Source height = 1.18 m

ROAD (0.00 + 63.60 + 0.00) = 63.60 dBA
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj B.Adj SubLeq

-90 75 0.34 64.67 0.00 0.00 -1.07 0.00 0.00 0.00 63.60

Segment Leq : 63.60 dBA

Results segment # 2: McNicoll

Source height = 1.18 m

ROAD (0.00 + 56.69 + 0.00) = 56.69 dBA
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj B.Adj SubLeq

-90 0 0.00 66.00 0.00 -6.30 -3.01 0.00 0.00 0.00 56.69

Segment Leq : 56.69 dBA

Total Leq All Segments: 64.41 dBA

TOTAL Leq FROM ALL SOURCES: 64.41

STAMSON 5.0 NORMAL REPORT Date: 10-11-2014 15:59:03
MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: NE_3am.te Time Period: 1 hours
Description:

Road data, segment # 1: Redlea

Car traffic volume : 61 veh/TimePeriod
Medium truck volume : 1 veh/TimePeriod
Heavy truck volume : 1 veh/TimePeriod
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)

Data for Segment # 1: Redlea

Angle1 Angle2 : -90.00 deg 75.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0
Surface : 1 (Absorptive ground surface)
Receiver source distance : 15.00 m
Receiver height : 12.50 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00

Road data, segment # 2: McNicoll

Car traffic volume : 83 veh/TimePeriod
Medium truck volume : 2 veh/TimePeriod
Heavy truck volume : 2 veh/TimePeriod
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)

Data for Segment # 2: McNicoll

Angle1 Angle2 : -90.00 deg 0.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 64.00 m
Receiver height : 12.50 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00

Results segment # 1: Redlea

Source height = 1.12 m

ROAD (0.00 + 52.44 + 0.00) = 52.44 dBA
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj B.Adj SubLeq

-90 75 0.34 53.51 0.00 0.00 -1.07 0.00 0.00 0.00 52.44

Segment Leq : 52.44 dBA

Results segment # 2: McNicoll

Source height = 1.23 m

ROAD (0.00 + 46.55 + 0.00) = 46.55 dBA
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj B.Adj SubLeq

-90 0 0.00 55.86 0.00 -6.30 -3.01 0.00 0.00 0.00 46.55

Segment Leq : 46.55 dBA

Total Leq All Segments: 53.44 dBA

TOTAL Leq FROM ALL SOURCES: 53.44

STAMSON 5.0 NORMAL REPORT Date: 10-11-2014 16:01:06
MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: NE_6am.te Time Period: 1 hours
Description:

Road data, segment # 1: Redlea

Car traffic volume : 315 veh/TimePeriod
Medium truck volume : 7 veh/TimePeriod
Heavy truck volume : 6 veh/TimePeriod
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)

Data for Segment # 1: Redlea

Angle1 Angle2 : -90.00 deg 75.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0
Surface : 1 (Absorptive ground surface)
Receiver source distance : 15.00 m
Receiver height : 12.50 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00

Road data, segment # 2: McNicoll

Car traffic volume : 427 veh/TimePeriod
Medium truck volume : 10 veh/TimePeriod
Heavy truck volume : 9 veh/TimePeriod
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)

Data for Segment # 2: McNicoll

Angle1 Angle2 : -90.00 deg 0.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 64.00 m
Receiver height : 12.50 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00

Results segment # 1: Redlea

Source height = 1.16 m

ROAD (0.00 + 60.03 + 0.00) = 60.03 dBA
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj B.Adj SubLeq

-90 75 0.34 61.10 0.00 0.00 -1.07 0.00 0.00 0.00 60.03

Segment Leq : 60.03 dBA

Results segment # 2: McNicoll

Source height = 1.19 m

ROAD (0.00 + 53.35 + 0.00) = 53.35 dBA
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj B.Adj SubLeq

-90 0 0.00 62.66 0.00 -6.30 -3.01 0.00 0.00 0.00 53.35

Segment Leq : 53.35 dBA

Total Leq All Segments: 60.87 dBA

TOTAL Leq FROM ALL SOURCES: 60.87

Wang, Joanne

To: Marcello.Favaro@ttc.ca; Occhiogrosso, Leonard
Subject: RE: TPH Comment McNicoll Bus Garage EPR (Noise)

From: Howard Shapiro [hshapir@toronto.ca]

Sent: Tuesday, December 23, 2014 4:41 PM

To: Solange.Desautels@ontario.ca; Barbara Lachapelle; MacDonald, Jason; Dimovski, John

Cc: David McKeown; Jann Houston; Reg Ayre; Nagler, David; Romano, Lito; Favaro, Marcello

Subject: TPH Comment McNicoll Bus Garage EPR (Noise)

Hi John,

The following are TPH's comments with respect to the evaluation of noise from the proposed facility at McNicoll. Please contact myself or Barbara Lachapelle if you have any questions.

There is a growing body of evidence that noise at certain levels could result in health effects such as hearing impairment, sleep disturbance, cardiovascular disease, and annoyance. In the past (i.e. Billy Bishop Toronto City Airport Health Impact Assessment study) TPH used a variety of noise benchmarks representing different health endpoints to assess potential health impacts. These benchmarks have been developed by organizations such as the World Health Organization (WHO), Health Canada (HC) and the Health Council of the Netherlands. As many of these endpoint are especially relevant to sensitive receptors such as the elderly, we recommend the use of the same benchmarks for the McNicoll noise quality assessment.

Health Effect	Threshold/Guideline	Reference
Environmental insomnia	42 L _{Aeq, 8hr} (23-07 hr)	WHO, 2009
Sleep disturbance, outside bedrooms	45 L _{Aeq, 8hr} (23-07 hr)	WHO, 1999b
Sleep disturbance, night noise guideline	40 L _{Aeq, 8hr} (23-07 hr)	WHO, 2009
Sleep disturbance, interim target	55 L _{Aeq, 8hr} (23-07 hr)	WHO, 2009
Hypertension	70 L _{Aeq, 16hr} (06-22 hr)	Health Council of the Netherlands, 1999
Ischemic health disease	70 L _{Aeq, 16hr} (06-22 hr)	Health Council of the Netherlands, 1999
Sleep pattern	< 60 L _{Aeq, 8hr} (23-07 hr)	Passchier-Vermeer and Passchier, 2000
Subjective sleep quality	40 L _{Aeq, 8hr} (23-07 hr)	Health Council of the Netherlands, 1999
Mood next day	< 60 L _{Aeq, 8hr} (23-07 hr)	Health Council of the Netherlands, 1999
Increased avg. movement during sleep	42 L _{Aeq, 8hr} (23-07 hr)	WHO, 2009
Self-reported sleep disturbance	42 L _{Aeq, 8hr} (23-07 hr)	WHO, 2009
Use of sleep-aid drugs and sedatives	42 L _{Aeq, 8hr} (23-07 hr)	WHO, 2009
Moderate annoyance, outdoor living area	50 L _{Aeq, 16hr}	WHO, 1999b
Serious annoyance, outdoor living area	55 L _{Aeq, 16hr}	WHO, 1999b
Annoyance, difference between baseline and project	>6.5% difference in %HA	Health Canada, 2010

The background and the rationale for the use of the various benchmarks is outlined in the BBTCA Health Impact Assessment, here's the link:

<http://www1.toronto.ca/wps/portal/contentonly?vgnnextoid=06917b805ebe1410VgnVCM10000071d60f89RCRD>

It is listed under Golder Associates (approx. halfway down the page).

References

- Health Canada. 2010. Useful Information for Environmental Assessments.
Health Council of the Netherlands. 1999. Public health impacts of large airports.
Passchier-Vermeer, W., Passchier, W.F. 2000. Noise exposure and public health. *Environmental Health Perspectives*, 108(1), 123-131.
WHO. 1999b. Guideline for Community Noise. Edited by B. Berglund, T. Lindvall and D.H. Schwela. Geneva.
WHO. 2009. Night noise guidelines for Europe

Howard Shapiro MD MSc FRCPC
Associate Medical Officer of Health & Acting Director
Healthy Environments
Toronto Public Health
277 Victoria Street, 5th Floor
Toronto, Ontario M5B 1W2
Tel: 416-338-0478
hshapir@toronto.ca

The information transmitted is intended only for the person or entity to which it is addressed and may contain confidential and/or privileged material. Any review retransmission dissemination or other use of or taking any action in reliance upon this information by persons or entities other than the intended recipient or delegate is strictly prohibited. If you received this in error please contact the sender and delete the material from any computer. The integrity and security of this message cannot be guaranteed on the Internet. The sender accepts no liability for the content of this e-mail or for the consequences of any actions taken on the basis of information provided. The recipient should check this e-mail and any attachments for the presence of viruses. The sender accepts no liability for any damage caused by any virus transmitted by this e-mail. This disclaimer is property of the TTC and must not be altered or circumvented in any manner.



January 27, 2015

AECOM
4th Floor, 30 Leek Crescent
Richmond Hill, ON
L4B 4N4

Attn: Mrs .Joanne Wang joanne.wang@aecom.com

**Re: TTC McNicoll Bus Garage
Responses to Toronto Public Health Noise Health Questions
Novus File: 13-0054**

Novus Environmental Inc. (Novus) was retained by AECOM on behalf of the Toronto Transit Commission (TTC) to prepare an environmental noise assessment for the proposed McNicoll Bus Garage (Facility) located on McNicoll Avenue, east of Kennedy Road in the City of Toronto, Ontario.

This letter outlines our responses to the Toronto Public Health (TPH) comments provided in their December 23, 2014 email regarding with the subject “TPH Comment McNicoll Bus Garage EPR (Noise).” A copy of the TPH email can be found as Attachment A. In the email, TPH requests that predicted noise levels for the project be compared against a number of health effect criteria.

1.0 Criteria

In Ontario, applicable sound level limits are outlined in Ministry of the Environment and Climate Change (MOECC) Publication NPC-300. Publication NPC-300 criteria were developed by the MOECC in order to minimize the possibility of annoyance and “adverse effects” (as defined in the *Environmental Protection Act*) from stationary industrial and commercial noise sources, such as the proposed bus garage. A comparison of facility noise impacts versus Publication NPC-300 guidelines has been completed, and can be found in the Novus Report “TTC McNicoll Bus Garage TPAP, Environmental Noise Assessment, Toronto, ON” completed as part of the TPAP process. The Novus report shows that with the inclusion feasible noise mitigation measures, the NPC-300 noise guidelines will be met.

There are a number of other criteria which have been developed internationally, which relate to the health effects of noise. These criteria can be divided into three categories:

1. Disease
2. Annoyance
3. Sleep Disturbance

Modelled noise predictions have been calculated with and without the proposed facility for comparison against these criteria. We understand that the criteria generally represent “no effect levels”, and are thus very conservative.

Modelled noise levels have been calculated for each face (N, E, S, and W) of the Mon Shoeng Long Term Care Facility, and the Mon Sheong Court building. **Figure 1** shows the receptor façade locations.

2.0 Disease

Table 1 (attached) presents a comparison of predicted build and no-build sound levels versus published criteria for disease-related health effects, namely ischemic heart disease and hypertension. The criteria are from the Health Council of the Netherlands, and are based on potential public health impacts from large airports.

Noise levels with and without the project are well below the 70 dBA L_{eq} (16h, 6am-10pm) criteria. The maximum increase due to the project will be 1.2 dB. Thus, health impacts from the project in terms of an increase in measurable disease outcomes are highly unlikely.

3.0 Annoyance

Table 1 also provides a comparison with annoyance criteria published by the World Health Organization (WHO) and Health Canada.

The WHO criteria of 50 and 55 dBA for annoyance in outdoor amenity areas are exceeded for both the existing “no-build” condition, and with the project in place (cumulative impacts). However, the increase in noise levels due to the project is only 2.8 dB. In terms of human perception, an increase in noise level of this magnitude would generally be considered to be imperceptible.

Health Canada recommended that the effect of increase noise from a project be assessed in terms of its effect on the percent of people “highly annoyed” with noise in their environment, and recommends that projects should not result in an increase of more than 6.5 % in the number of highly annoyed individuals. The maximum predicted increase resulting from this project is less than 1%.

Therefore, in terms of noise annoyance, the project is unlikely to result in an adverse effect.

4.0 Sleep Disturbance

Table 1 also provides a comparison versus a number of published sleep disturbance thresholds, including criteria for sleep disturbance, increased movement, use of sleep aids, and insomnia. As with the other criteria discussed, the limits are based on sound levels outside of the building, in the plane of an open window. The sleep disturbance criteria can be broken down in to three ranges:

- 40 to 45 dBA L_{eq} Night (11pm to 7 am)

The sleep disturbance criteria in this range are based on “no effect” levels; thus, no measurable effect would be observed for outdoor noises meeting these limits. As can be seen in **Table 1**, both “without project” no-build noise levels and cumulative “with project” noise levels exceed these limits. In fact, 40 to 45 dBA night-time sound levels are not met in the majority of urban environments, and are more typical of noise levels one would receive in rural areas.

The change in sound levels due to the project ranges from 0 to 2.1 dB, which would generally be considered imperceptible.

- 55 dBA L_{eq} Night (11pm to 7 am)

Recognizing the difficulties of meeting the “no effect” guidelines in an urban environment, WHO has adopted 55 dBA as an interim target for sleep disturbance under their Nighttime Noise Guidelines for Europe. As shown in **Table 1**:

- a) Approximately 40% of the facades meet the interim target
- b) The maximum noise increase is only 1.0 dB, on the northern façade. Resulting sound levels at this location meet the 55 dBA interim target
- c) Only 25% of the facades exceed the interim target by more than 3 dB
- d) For the 60% of the façade locations where the interim target is exceeded (shown in **bold** in Table 1), the sound levels are driven by existing ambient noise levels, and not from noise due to the bus garage project. For these facades, the maximum increase in noise due to the project is only 0.2 dB.

The proposed project has no effect on -whether the interim target is met.

- 60 dBA L_{eq} Night (11pm to 7 am)

Passchier-Vermier et al. and the Health Council of the Netherlands have recommended that night-time noise levels be less than 60 dBA to avoid sleep pattern disturbance and effects on mood the next day.

The 60 dBA criterion is met at all but two facades, and is only exceeded at two locations by a maximum of 0.7 dB. At these two locations, the excess of the criteria is completely due to non-project related ambient noise levels. The increase in noise levels due to the project is 0 dB.

5.0 Summary and Conclusions

Based on the above, noise from the proposed project is unlikely to have a measureable effect on health.

We trust that this information will be helpful. If you have any further questions, please do not hesitate to contact us.

Sincerely,


Novus Environmental Inc.



R. L. Scott Penton, P.Eng.

Principal / Acoustical Specialist

Intrinsik Environmental Sciences Inc.



Glenn Ferguson, Ph.D., QPRA

Vice President – Eastern Region / Senior Scientist

References

- Health Canada. 2010. Useful Information for Environmental Assessments.
- Health Council of the Netherlands. 1999. Public health impacts of large airports.
- Passchier-Vermeer, W., Passchier, W.F. 2000. Noise exposure and public health. *Environmental Health Perspectives*, 108(1), 123-131.
- WHO. 1999b. Guideline for Community Noise. Edited by B. Berglund, T. Lindvall and D.H. Schwela. Geneva.
- WHO. 2009. Night noise guidelines for Europe.



Figure No. 1
Modelled Façade Locations

TTC McNicoll Bus Garage
Toronto, Ontario



Scale: 1: 750
Date: 14 / 01 / 27
File No.: 13-0054
Drawn By: KAC

novus
ENVIRONMENTAL

Table 1: TTC McNicoll Bus Garage Noise Assessment - Comparison Versus Health Effects Thresholds

Health Effect	Threshold/ Guideline	Reference	Period	Scenario	Outdoor Living Area	Mon Sheong Long Term Care Building Façade								Mon Sheong Court Building Façade							
						N		E		S		W		N		E		S		W	
DISEASE																					
Hypertension	70 L _{Aeq, 16hr} (06-22 hr)	Health Council of the Netherlands. 1999. Public health impacts of large airports.	Without Project Cumulative Change	6am-10pm	-	56.3 56.7 0.4	61.4 61.5 0.1	58.4 57.9 -0.5	66.7 66.7 0.0	64.5 64.5 0.0	66.6 66.6 0.0	54.5 54.6 0.1	63.0 63.0 0.0	51.0 52.2 1.2	63.9 63.9 0.0	56.8 57.3 0.5	63.2 63.3 0.1	64.0 64.0 0.0	68.0 68.0 0.0	64.9 64.9 0.0	68.1 68.1 0.0
					-	56.3 56.7 0.4	61.4 61.5 0.1	58.4 57.9 -0.5	66.7 66.7 0.0	64.5 64.5 0.0	66.6 66.6 0.0	54.5 54.6 0.1	63.0 63.0 0.0	51.0 52.2 1.2	63.9 63.9 0.0	56.8 57.3 0.5	63.2 63.3 0.1	64.0 64.0 0.0	68.0 68.0 0.0	64.9 64.9 0.0	68.1 68.1 0.0
					-	56.3 56.7 0.4	61.4 61.5 0.1	58.4 57.9 -0.5	66.7 66.7 0.0	64.5 64.5 0.0	66.6 66.6 0.0	54.5 54.6 0.1	63.0 63.0 0.0	51.0 52.2 1.2	63.9 63.9 0.0	56.8 57.3 0.5	63.2 63.3 0.1	64.0 64.0 0.0	68.0 68.0 0.0	64.9 64.9 0.0	68.1 68.1 0.0
ANNOYANCE																					
Moderate annoyance, outdoor living area	50 L _{Aeq, 16hr}	WHO. 1999b. Guidelines for Community Noise.	Without Project Cumulative Change	7am-11pm	62.4 65.2 2.8	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -			
					-	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -			
					-	62.4 65.2 2.8	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -			
Serious annoyance, outdoor living area	55 L _{Aeq, 16hr}	WHO. 1999b. Guidelines for Community Noise.	Without Project Cumulative Change	7am-11pm	62.4 65.2 2.8	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -			
					-	57.5 58.2 0.7	62.6 63.2 0.6	59.6 59.3 -0.2	67.9 68.0 0.1	65.7 65.7 0.0	67.8 67.8 0.1	55.7 55.9 0.2	64.2 64.2 0.0	52.2 53.9 1.7	65.1 65.2 0.1	58.0 58.7 0.8	64.4 64.5 0.1	65.2 65.2 0.0	69.2 69.2 0.0	66.1 66.1 0.0	69.3 69.3 0.0
					-	5.7 6.2 0.5	10.5 11.3 0.8	7.3 7.1 -0.2	19.1 19.3 0.2	15.0 15.0 0.0	18.9 19.0 0.1	4.5 4.6 0.1	12.7 12.7 0.0	2.9 3.6 0.1	14.1 14.2 0.0	6.0 6.6 0.1	13.0 13.1 0.1	14.2 14.2 0.0	21.9 21.9 0.0	15.8 15.8 0.0	22.1 22.1 0.0
Annoyance, difference between baseline and project	>6.5% difference in %HA	Health Canada. 2010. Useful Information for Environmental Assessments.	24 hrs		Without Project (L _{dn}) Cumulative (L _{dn}) Change	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -			
					Without Project %HA Cumulative %HA Change in %HA	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -	- -		
					- -	5.7 6.2 0.5	10.5 11.3 0.8	7.3 7.1 -0.2	19.1 19.3 0.2	15.0 15.0 0.0	18.9 19.0 0.1	4.5 4.6 0.1	12.7 12.7 0.0	2.9 3.6 0.1	14.1 14.2 0.1	6.0 6.6 0.1	13.0 13.1 0.1	14.2 14.2 0.1	21.9 21.9 0.1	15.8 15.8 0.1	22.1 22.1 0.1

... Continuned

Notes:

- All values are in dBA unless otherwise noted

- Values in **Bold** exceed threshold.

Table 1 Continued: TTC McNicoll Bus Garage Noise Assessment - Comparison Versus Health Effects Thresholds

Health Effect	Threshold/ Guideline	Reference	Period	Scenario	Outdoor Living Area	Mon Sheong Long Term Care Building Façade								Mon Sheong Court Building Façade							
						N		E		S		W		N		E		S		W	
SLEEP DISTURBANCE																					
Subjective sleep quality	40 L _{Aeq, 8hr} (23-07 hr)	Health Council of the Netherlands. 1999. Public health impacts of large airports.	Without Project Cumulative Change 11pm-7am	- - - 1.0	-	48.9	54.0	51.0	59.3	57.1	59.2	47.1	55.6	43.6	56.5	49.4	55.8	56.6	60.6	57.5	60.7
						49.9	55.0	51.0	59.5	57.1	59.3	47.3	55.6	45.7	56.6	50.4	55.9	56.6	60.6	57.5	60.7
						1.0	1.0	0.0	0.2	0.0	0.1	0.2	0.0	2.1	0.1	1.0	0.1	0.0	0.0	0.0	0.0
Sleep disturbance, night noise guideline	40 L _{Aeq, 8hr} (23-07 hr)	WHO. 2009. Night noise guidelines for Europe.	Without Project Cumulative Change 11pm-7am	- - - 1.0	-	48.9	54.0	51.0	59.3	57.1	59.2	47.1	55.6	43.6	56.5	49.4	55.8	56.6	60.6	57.5	60.7
						49.9	55.0	51.0	59.5	57.1	59.3	47.3	55.6	45.7	56.6	50.4	55.9	56.6	60.6	57.5	60.7
						1.0	1.0	0.0	0.2	0.0	0.1	0.2	0.0	2.1	0.1	1.0	0.1	0.0	0.0	0.0	0.0
Use of sleep-aid drugs and sedatives	40 L _{Aeq, 8hr} (23-07 hr)	WHO. 2009. Night noise guidelines for Europe.	Without Project Cumulative Change 11pm-7am	- - - 1.0	-	48.9	54.0	51.0	59.3	57.1	59.2	47.1	55.6	43.6	56.5	49.4	55.8	56.6	60.6	57.5	60.7
						49.9	55.0	51.0	59.5	57.1	59.3	47.3	55.6	45.7	56.6	50.4	55.9	56.6	60.6	57.5	60.7
						1.0	1.0	0.0	0.2	0.0	0.1	0.2	0.0	2.1	0.1	1.0	0.1	0.0	0.0	0.0	0.0
Increased avg. movement during sleep	42 L _{Aeq, 8hr} (23-07 hr)	WHO. 2009. Night noise guidelines for Europe.	Without Project Cumulative Change 11pm-7am	- - - 1.0	-	48.9	54.0	51.0	59.3	57.1	59.2	47.1	55.6	43.6	56.5	49.4	55.8	56.6	60.6	57.5	60.7
						49.9	55.0	51.0	59.5	57.1	59.3	47.3	55.6	45.7	56.6	50.4	55.9	56.6	60.6	57.5	60.7
						1.0	1.0	0.0	0.2	0.0	0.1	0.2	0.0	2.1	0.1	1.0	0.1	0.0	0.0	0.0	0.0
Self-reported sleep disturbance	42 L _{Aeq, 8hr} (23-07 hr)	WHO. 2009. Night noise guidelines for Europe.	Without Project Cumulative Change 11pm-7am	- - - 1.0	-	48.9	54.0	51.0	59.3	57.1	59.2	47.1	55.6	43.6	56.5	49.4	55.8	56.6	60.6	57.5	60.7
						49.9	55.0	51.0	59.5	57.1	59.3	47.3	55.6	45.7	56.6	50.4	55.9	56.6	60.6	57.5	60.7
						1.0	1.0	0.0	0.2	0.0	0.1	0.2	0.0	2.1	0.1	1.0	0.1	0.0	0.0	0.0	0.0
Environmental insomnia	42 L _{Aeq, 8hr} (23-07 hr)	WHO. 2009. Night noise guidelines for Europe.	Without Project Cumulative Change 11pm-7am	- - - 1.0	-	48.9	54.0	51.0	59.3	57.1	59.2	47.1	55.6	43.6	56.5	49.4	55.8	56.6	60.6	57.5	60.7
						49.9	55.0	51.0	59.5	57.1	59.3	47.3	55.6	45.7	56.6	50.4	55.9	56.6	60.6	57.5	60.7
						1.0	1.0	0.0	0.2	0.0	0.1	0.2	0.0	2.1	0.1	1.0	0.1	0.0	0.0	0.0	0.0
Sleep disturbance, outside bedrooms	45 L _{Aeq, 8hr} (23-07 hr)	WHO. 1999b. Guidelines for Community Noise.	Without Project Cumulative Change 11pm-7am	- - - 1.0	-	48.9	54.0	51.0	59.3	57.1	59.2	47.1	55.6	43.6	56.5	49.4	55.8	56.6	60.6	57.5	60.7
						49.9	55.0	51.0	59.5	57.1	59.3	47.3	55.6	45.7	56.6	50.4	55.9	56.6	60.6	57.5	60.7
						1.0	1.0	0.0	0.2	0.0	0.1	0.2	0.0	2.1	0.1	1.0	0.1	0.0	0.0	0.0	0.0
Sleep disturbance, interim target	55 L _{Aeq, 8hr} (23-07 hr)	WHO. 2009. Night noise guidelines for Europe.	Without Project Cumulative Change 11pm-7am	- - - 1.0	-	48.9	54.0	51.0	59.3	57.1	59.2	47.1	55.6	43.6	56.5	49.4	55.8	56.6	60.6	57.5	60.7
						49.9	55.0	51.0	59.5	57.1	59.3	47.3	55.6	45.7	56.6	50.4	55.9	56.6	60.6	57.5	60.7
						1.0	1.0	0.0	0.2	0.0	0.1	0.2	0.0	2.1	0.1	1.0	0.1	0.0	0.0	0.0	0.0
Sleep pattern	< 60 L _{Aeq, 8hr} (23-07 hr)	Passchier-Vermeer et al., 2000. "Noise exposure and public health". Env. Health Persp., 108(1), 123-131.	Without Project Cumulative Change 11pm-7am	- - - 1.0	-	48.9	54.0	51.0	59.3	57.1	59.2	47.1	55.6	43.6	56.5	49.4	55.8	56.6	60.6	57.5	60.7
						49.9	55.0	51.0	59.5	57.1	59.3	47.3	55.6	45.7	56.6	50.4	55.9	56.6	60.6	57.5	60.7
						1.0	1.0	0.0	0.2	0.0	0.1	0.2	0.0	2.1	0.1	1.0	0.1	0.0	0.0	0.0	0.0
Mood next day	< 60 L _{Aeq, 8hr} (23-07 hr)	Health Council of the Netherlands. 1999. Public health impacts of large airports.	Without Project Cumulative Change 11pm-7am	- - - 1.0	-	48.9	54.0	51.0	59.3	57.1	59.2	47.1	55.6	43.6	56.5	49.4	55.8	56.6	60.6	57.5	60.7
						49.9	55.0	51.0	59.5	57.1	59.3	47.3	55.6	45.7	56.6	50.4	55.9	56.6	60.6	57.5	60.7
						1.0	1.0	0.0	0.2	0.0	0.1	0.2	0.0	2.1	0.1	1.0	0.1	0.0	0.0	0.0	0.0

Notes:

- All values are in dBA unless otherwise noted

- Values in **Bold** exceed threshold.